


# **ALAKANUK, Alaska**

## **WATER AND WASTEWATER SYSTEM**

### **Feasibility and Cost Study**

**Prepared for the City of Alakanuk**



**U.S. DEPARTMENT OF HEALTH AND HUMAN SERVICES  
PUBLIC HEALTH SERVICE  
INDIAN HEALTH SERVICE  
ALASKA AREA NATIVE HEALTH SERVICE  
ENVIRONMENTAL HEALTH AND ENGINEERING BRANCH  
ANCHORAGE ALASKA**

**DECEMBER 1989**

**ALAKANUK, ALASKA**

**WATER AND WASTEWATER SYSTEM**

**FEASIBILITY AND COST STUDY**

**PREPARED FOR  
THE CITY OF ALAKANUK**

**U.S. DEPARTMENT OF HEALTH AND HUMAN SERVICES  
PUBLIC HEALTH SERVICE  
INDIAN HEALTH SERVICE  
ALASKA AREA NATIVE HEALTH SERVICE  
ENVIRONMENTAL HEALTH AND ENGINEERING BRANCH  
ANCHORAGE ALASKA**

**November 1989**

## TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTORY SUMMARY	1
INTRODUCTION AND HISTORY	2
Community Location	2
Project History & Need	2
COMMUNITY PROFILE	3
Origin	3
Location	3
Climate	3
Topography	4
Geology	4
Soil & Water Table	4
Flood & Seismic	4
Flora & Fauna	5
Population	5
Structures	6
Planned Capital Improvements	6
Income & Economy	6
Local Government & Corporation	8
Land Status	8
Communication	8
Transportation	8
Power	8
Community Contacts	9
COMMUNITY SANITATION PRIORITIES	10
Survey Results	10
EXISTING SANITATION FACILITIES	10
Water Supply	10
Sewage	11
Solid Waste	11
DESIGN & CONSTRUCTION CONSIDERATIONS	12
Permafrost	12
Foundations	12
Piping Material	12
Pipe Placement	12
Flood Considerations	13
Gravel/Select Fill	13
Drainage	13
Equipment	14
Labor	14
SANITATION ALTERNATIVES CONSIDERED	15
General	15
Watering Points & Honeybucket Haul	16
Trucked Water & Sewer	18
Piped Water & Sewer	20
RECOMMENDED SANITATION FACILITIES	26
SUMMARY AND CONCLUSIONS	27
REFERENCES	
APPENDIX A - SOIL INFORMATION & WELL LOGS	
APPENDIX B - COMMUNITY SURVEY RESULTS	

## LIST OF TABLES

<u>Table</u>	<u>Page or Preceding Page</u>
1 POPULATION OF ALAKANUK	5
2 CHARACTERISTICS OF WASTEWATER COLLECTION SYSTEMS	16
3 COSTS FOR SUMMER WATERING POINTS	16
4 COSTS FOR YEAR-ROUND WATERING POINTS	17
5 COSTS FOR EACH YEAR-ROUND WATERING POINT	17
6 COSTS FOR HONEYBUCKET HAUL SYSTEM	18
7 COSTS FOR WATER AND WASTEWATER HAUL	19
8 WATER DEMAND WITH A PIPED SYSTEM	20
9 COSTS FOR PIPED WATER AND VACUUM SEWER	22
10 COMPARISON OF VACUUM AND PRESSURE SEWAGE COLLECTION SYSTEMS	23
11 COSTS FOR WATER AND VACUUM SEWER BY CITY SECTION	23
12 DESCRIPTION OF CITY SECTIONS	23
13 COST OF PRESSURE SEWER AND WATER	24
14 COSTS FOR WATER AND PRESSURE SEWER BY CITY SECTION	25
15 COST SUMMARY/COMPARISON	28

## LIST OF FIGURES

<u>Figure</u>	<u>Follows Page</u>
1 PLOT OF PREDICTED POPULATION FOR ALAKANUK	5
2 HDPE PIPE COMPONENTS	12
3 UTILIDOR SECTIONS BEFORE CONNECTION	12
4 COMPLETED UTILIDOR PLACED ON THE GROUND	12
5 SEWAGE COLLECTION LINES ON PILING	13
6 TYPICAL SEWAGE LAGOON SECTION	15
7 SUMMER WATERING POINT	16
8 SUMMER WATERING POINT LAYOUT IN ALAKANUK	16
9 YEAR-ROUND WATERING POINT LAYOUT IN ALAKANUK	16
10 TRUCK FOR COLLECTION HONEYBUCKET WASTES	17
11 INDIVIDUAL HOUSE HOLDING TANK	18
12 WATER DELIVERY TRUCK PIPING AND EQUIPMENT DIAGRAM	18
13 VACUUM SEWAGE PUMPOUT VEHICLE	18
14 FILLING AND EMPTYING PROCEDURE FOR HOLDING TANK PUMPOUT TRUCKS	18
15 UTILIDOR CROSS-SECTION (VACUUM SYSTEM)	21
16 SERVICE CONNECTION FOR VACUUM SEWER	21
17 LAYOUT OF UTILIDOR WITH WATER AND SEWER LINES IN ALAKANUK	22
18 TYPICAL PUMP-GRINDER INSTALLATION	24
19 PUMP-GRINDER CHARACTERISTICS	24
20 TYPICAL GRINDER-PUMP UNIT	24

## SUMMARY

December 1988, the Public Health Service received a request from the City of Alakanuk for assistance in investigating available alternatives for water and sewer facilities and determining their feasibility. It was determined that the study scope would be to evaluate the technical and economic issues of providing the City of Alakanuk with varying levels of sanitation service. The alternatives considered included expansion of the existing water delivery system with the addition of wastewater haul, additional watering points, a honeybucket haul system, and a piped water and wastewater system. Particular attention was given to the estimated cost for construction of each alternative, as well as the level of economic and technical support required at the community level to provide for long term operation and maintenance of the completed facilities.

This report discusses the background, evaluations and findings developed through the sanitation facility planning process. Its intent is to provide sufficiently detailed engineering information to allow local residents to make informed and knowledgeable decisions about their future utility systems.

Piped water and sewer is feasible, and may be the best solution to the community's sanitation problems, but it would be very expensive. The capital cost to provide the entire city with service would be approximately \$10 million, though the cost could be lowered if some outlying areas were not served. The cost to operate this type of system would exceed \$100 per family per month. This fee is in excess of what a survey of the community's residents indicated they could pay.

An alternative to a piped system would be a water and wastewater haul system to service the entire community for approximately \$1.9 million. It is recommended that sanitation facilities be developed in a phased approach. Phase schedules are included in this report. The phasing can be scheduled to permit the work to be accomplished as a logical expansion of services throughout the community.

## INTRODUCTION AND HISTORY

### Community location

The City of Alakanuk is located near the mouth of the Lower Yukon River, 162 air miles from Bethel, Alaska.

### Project History & Need

In 1976, the Alaska Department of Environmental Conservation's Village Safe Water Program (VSW) funded the construction of a centrally located washeteria with water supply, wastewater treatment, laundry, shower, and sauna facilities.

In 1977, the Indian Health Service (IHS) undertook well drilling project AN-77-625b to put in a well for the BIA school in Alakanuk. No producing aquifer was found.

PHS project AN-81-237A implemented a small honeybucket haul system. The system consisted of honeybuckets, 16 polyethylene collection containers, and haul trailers. A dump site was fenced for the disposal of solid waste and honeybucket wastes. Operational problems with this system resulted in sewage being spilled out while being hauled to the dump site. This resulted in sewage all over the city's roads, an unsanitary and undesirable situation. Also there were problems accessing the homes in the winter and handling the frozen waste. The city abandoned the honeybucket haul system in 1985.

In 1984, Alakanuk received \$840,000 from the State of Alaska under Senate Bill 162 for water and sewer improvements. The city used this money to improve the washeteria facilities and build a sewage lagoon to serve the washeteria and school facilities.

The City of Alakanuk has a definite need for an improvement in their sanitation facilities. Last winter there were several illnesses such as hepatitis reported in the city, which are related to poor sanitary conditions. Presently, the residents are dumping their honeybucket wastes in the Alakanuk slough, in holes dug behind individual homes, or among the alders along the roadside. The spring floods tend to spread the sewage around the village, exposing villagers to diseases.

## COMMUNITY PROFILE

### Origin

Yup'ik Eskimos have lived in the vicinity of the modern village of Alakanuk since prehistoric times. The area was chosen because of the diverse subsistence resources of the Yukon Delta. In recent years, commercial fishing, a cannery at the mouth of the slough, the establishment of schools, and federal housing construction have played an important role in the growth of the village. The village is 94% Yup'ik Eskimo.

### Location

The City of Alakanuk is located at the mouth of the Lower Yukon River, 162 air miles from Bethel, Alaska. A majority of the community extends approximately 3 miles along the south side of Alakanuk Pass (a channel of the Yukon River) near its juncture with Kwikluak Pass, a major channel of the river. Alakanuk is approximately 15 miles upstream from the Bering Sea. Nearby communities of the Yukon Delta area include Emmonak and Sheldon's Point. St. Mary's, a transportation hub for the Lower Yukon area, is 80 miles upstream.

### Climate

Alakanuk is located in a zone of transitional climate, with marine influences causing moderately cool summers, and ice pack in the winter providing for more continental conditions. High winds are frequent. The last day of freezing temperature in the spring is usually in late May, and the first freezing temperature in the autumn is usually in early September.

#### Approximate Climatic Data

Mean Annual Precipitation, inches	19
Mean Annual Snowfall, inches	60
Mean Annual Temperature, F	28
Mean Daily Maximum Temperature, July, F	65
Mean Daily Minimum Temperature, December, F	0
Thawing Index, days	2,000
Freezing Index, days	3,750
Design Freezing Index, 1 year in 10	4,750

### Topography

The topography is fairly flat with only slight variations in local relief within the surrounding village site. Elevations range from about five to ten feet above sea level. The terrain is characterized by numerous thaw lakes and inter-connecting slough channels.

### Regional Geology

The Yukon-Kuskokwim Delta region is an alluvial plain built up of deposited silts, sands, and gravels. The deposits which may be up to 300 feet thick, are underlain by interbedded marine and terrestrial deltaic and eolian deposits. Bedrock crops out in isolated areas. The most common rock types are mafic volcanics deposited as lava sheets or cinder cones.

### Soil & Water Table Conditions

Soils in the area are characterized as poorly drained peat or peaty surface layer with a shallow permafrost table preventing drainage. In addition, the area usually floods each spring. As a result, the area can be generally classified as wetlands. Surficial organics average about one foot in depth in the vicinity of the village, but have been generally scraped off in the village site itself. Soils are clay, silts, and sand with a high organic and moisture content (Appendix A).

Well logs for Alakanuk and test holes indicate the presence of surface frost rather than the permafrost expected in the area, though some pockets of permafrost do exist (see soil logs in Appendix A). The frost depth is reported to be less than 4 feet. Test holes dug in the harbor and airport area in early March had an average water depth of 6 ft with the minimum 3 ft. The average frost depth was 3 ft with a maximum of 6 ft. The community is likely on the thaw bulb of the Yukon River. Well logs from the drilling attempt at the high school show a frost depth of 2 feet, and water at 15 feet at the end of May. The well log for the abandoned BIA school well indicates a static water level of 3.5 feet. Well logs are included in the appendix.

### Flood & Seismic Evaluation

The U.S. Army Corps of Engineers Flood Plain Management Services Branch rates the flood hazard at Alakanuk as very high, with flooding over the entire community anticipated on a frequency greater than once every five years. In reality, the community has flooded at least once or twice every year in the historic past. Typically, flood waters cover the community to a depth of three to four feet. Flooding is of major importance because of the damage it can cause by floating pipes that are not anchored down. Design consideration must be given to design systems that can withstand flooding. The airport, located on higher ground, is rarely flooded. Alakanuk is located in seismic zone 2, as defined by the Uniform Building Code, and considered to have a risk of moderate damage to structures due to earthquakes. No earthquakes have been reported in the area.



### Flora and Fauna

The wet tundra of Alakanuk is characterized by an almost continuous cover of grasses and sedges rooted in mosses and lichens. Berries and low shrubs are also typical. Birds and waterfowl are the most important fauna in the area; the Yukon-Kuskokwim Delta is one of the two largest waterfowl breeding grounds in North America. Moose may be present within the general area, but large mammals are generally absent from the wet tundra of the Yukon Delta. Smaller mammals, including shrews, hares, squirrels, foxes, and wolves can be found around Alakanuk.

### Population

Alakanuk's present population is approximately 573, with 119 Native families, and 10 Non-Native families. In past years, the population has grown steadily as can be seen in Table 1 below. From 1940-1970, there was substantial immigration from smaller camps and villages in the area. The attractions were the opening of the Yukon River to commercial fishing, the cannery established in 1941, and the BIA school in 1967. Corporation statistics indicate that the true population in 1970 was closer to 440, rather than the figure of 265 given below. More recently, the village has also experienced emigration as the youth leave to attend school or work, many of these, don't return to live in Alakanuk. In spite of this, the village continues to slowly grow, due to high birth rates, improved health care and lower mortality among the elderly and infants. Another fact that must be considered is that about 10 percent of the population of Alakanuk live across the river, and would be difficult to serve by any new sanitation facilities.

A plot of the past population (Figure 1) yielded a prediction of 750 people for the 20 year design population.


Table 1  
Population, Household, and Family Characteristics

(Sources: U.S. Dept. of Commerce, Bureau of the Census, Special Tabulations, 1980; Alaska Dept. of Labor, Alaska Population Overview, 1985 Estimates, April 1987.)

Year	Population			Households		Families	
	Total	Native	Other	Total	Avg. size	Total	Avg. size
1939	197						
1950	158						
1960	190						
1970	265*	247	18	45	6	41	6.5
1980	522	491	31	105	5	95	5.5
1984	515						
1985	556						
1989	573						

\*1970 population really closer to 440; 1989 population estimated

# Alakanuk, Alaska



PLOT OF PREDICTED POPULATION

FIGURE 1

### Structure & Buildings

Alakanuk has 131 homes, 123 of these are inhabited full time, 25 are HUD homes, 16 are BIA renovated homes, and 9 are teacher's trailers with water and sewer hook-up. Across the river are 11 homes, which will be difficult to serve with any new sanitation facilities. There are 12 non-residential buildings.

The following public, commercial, and government facilities exist in Alakanuk:

- LYSD High School
- LYSD Headstart School
- LYSD Elementary School
- Alakanuk Native Corp. Store
- Airstrip Shelter
- Alakanuk City Office
- Alakanuk City Police
- Alakanuk Village Health Clinic
- Alascom, Inc.
- Alaskan Village Electric Cooperative Power Plant
- Aistrom's Store
- Assembly of God Church
- Catholic Church
- Community Hall
- DF Jorgensen Co. (store)
- Recreation Hall
- U.S. Postal Service
- United Utilities Inc.
- Yupik Star Fisheries

In 1989, there are approximately 167 students and 14 teachers in Alakanuk.

### Planned Capital Improvements

The only known plans that will effect sanitation improvements are the sewer and water hook-up at the clinic, which is almost done, and the planned hook-up of the Headstart school. Recently, a garage near the clinic was attached to the water line.

### Income & Economy

Alakanuk's economy is predominately subsistence based, though a significant cash income results from commercial fishing and cannery employment during the fishing season. Regulations prevent the commercial salmon fishing from expanding to employ more of the village's residents. Nearly all families are represented at subsistence fish camps. Hunting, fishing and gathering activities provide a significant portion of most residents' diets. Year round employment is available to very few and is largely dependent on public sector funding. While the population is growing, employment opportunities in Alakanuk are not increasing significantly, causing an increase in unemployment. Government transfer payments make up a large portion of the community's income.

Average Household Income by Source, 1986  
(Sources: Field Protocol; U.S. Department  
of Commerce, Bureau of Economic Analysis)

	<u>Dollars</u>
<u>Earned Income</u>	
Nonwage Self Employment	3,089
Private Sector	2,757
Government:	
Federal	1,109
State	2,188
Local	2,466
Institutional	<u>557</u>
Subtotal	12,166
<u>Unearned Income</u>	
Governmental Transfers:	
Permanent Fund	2,805
Other	3,982
Interest/Dividends/Rent	<u>24</u>
TOTAL	\$18,977

Average Household Consumption Expenditures, 1986  
(Sources: Field Protocol; 1987 Statistical Abstract)

	<u>Dollars</u>
Housing	272
Utilities:	
Heating Oil	537
Electricity	376
Water	391
Other	88
Groceries	4008
Transportation	2022
Hunting/Fishing Gear	335
Insurance	20
Medical	7
Clothing & Accessories	<u>780</u>
TOTAL	8736

### Local Government & Corporation

Alakanuk, a member of the Calista Native Corporation, was incorporated as a second class city in 1969, and is governed by a mayor/5 member city council. The community has a 5 member traditional council which is elected to serve terms ranging from 2-4 years. The city assesses a two percent sales tax. See Appendix C for planned city set aside funds.

### Land Status

The land from the airport to the end of the village is owned by several entities. The land belongs to the city, individuals (both restricted and unrestricted parcels) and the State of Alaska. The Department of Education owns several lots for the School, and the Department of Transportation owns several lots as well. The Townsite Trustee still retains title to Block 11 of Tract "B" and Block 5 of Tract "A". Before any construction begins Right-Of-Ways would have to be obtained. A good place to start researching land status is the Bureau Of Land Management's Townsite Trustees Office in Anchorage, telephone # (907) 271-3788.

### Communication

Telephone service is provided by Alascom, Inc., based in Anchorage. The city office telephone number is 238-3313.

Alakanuk receives KICK and KNOB radio stations from Nome and television stations from the State Satellite System. Cable television is also available for hook-up.

Mail is delivered to Alakanuk an average of 5 days per week by one of the local air carriers.

### Transportation

Alakanuk is dependent on air and boat transportation in the summer months. The village also has several gravel roads within the city limits. Once winter arrives, snowmobiles, three-wheelers, and plane service become the main forms of transportation. Air travel from Bethel is available year-round through scheduled and charter air services. The community is equipped with a 2,470 foot sand and gravel airstrip and receives barge service an average of twice a year from Seattle and Nenana.

### Power

Houses are supplied with electricity through connection to the community's Alaska Village Electrical Cooperative (AVEC) generating system. AVEC operates a 695 kW diesel generator with 124,000 gallons of fuel storage capacity. They use 80,000 gallons each year. In 1978, total village fuel storage, including AVEC, was 332,000 gallons. In 1989 the City Manager reported 153,000 gallons of total storage, while another city resident reported 284,000 gallons. This discrepancy should be investigated further before a fuel intensive sanitation facility is installed. Residents heat their homes with wood or fuel oil. Fuel oil costs \$1.50 per gallon. The average household expenditure in 1986 for electricity was \$376 and \$537 for heating oil (Sources: Field Protocol; 1987 Statistical Abstract). The washeteria facility used approximately \$10,000 of heating fuel in the first half of fiscal year 1989.

## Community Contacts

### Alakanuk City Council

Mr. Peter Black, Mayor 238-3621  
Mr. Ray Oney, Voce Mayor 238-3714  
Ms. Elizabeth Chikagak, Secretary/Treasurer 238-3415  
Mr. Paul Phillip, Council Member 238-3624  
Ms. Mary Ayunerak, Council Member 238-3622  
Ms. Zita Chikagak, Council Member 238-3315  
Ms. Paula Ayunerak, Council Member 238-2312

### Traditional Council

Mr. Dennis Shelden, President  
Mr. Paul Ayunerak, Vice-President  
Ms. Mary Augustine, Secretary/Treasurer  
Mr. Charles Harry, Council Member  
Ms. Monica Murphy, Council Member  
Ms. Paula Ayunerak, Administrator

### City Manager

Mr. Dave Morgan, 238-3313

### City Clerk

Ms. Martina Post, 238-3313

### Community Health Aides

Ms. Theresa Edmund, Primary  
Ms. Ida Duny  
Ms. Alma Hanson  
Ms. Rose Kameroff, Alt.  
Ms. Martha Joseph, Alt.

### Village Public Safety Officer/Lay Vaccinator

Mr. Tony Simmons, 238-3324

### Village Police Officer

Mr. Ralph Teeluk  
Mr. Thomas Okitkun

### Water Plant Operators

Mr. Charles Smith, Manager  
Mr. Cyprian Augline

### Advisory School Board

Seven Member Board

### Community Sanitation Priorities

All city council members and residents attending a July 1989 meeting with PHS engineers, indicated that they would like to have piped water and sewer service in Alakanuk. Realizing that this would take several years even after funds are found, the city emphasized that some kind of immediate solution to the health problems caused by honeybucket waste disposal is needed. To better understand the desires and attitudes of all the village's residents concerning sanitation facilities improvements, a survey was taken in July 1989. A summary of this survey appears below, and the actual questions with results are included in Appendix B. See Appendix C for City resolutions and supporting documents regarding sanitation facilities development.

#### Survey Results

Most of the residents responding to the survey indicated a desire for piped water and sewer, and want to pay less than \$35/month for it. Few wanted the honeybucket haul system restarted. Many would like year-round watering points, because the existing watering point is so far from their homes. Many people also expressed concerns about bad road conditions and snow hindering water delivery and the honeybucket haul if it is restarted.

### Existing Sanitation Facilities

#### Water Supply

Traditional water sources used include rainwater, snow and ice. The city water treatment plant and washeteria facility get water from the Alakanuk Slough via a 3 inch copper pipe encased in arctic pipe. The intake floats on the water surface in summer and is placed through the ice during the winter. The original water treatment facility constructed under a 1976 VSW project. In 1984, the system was renovated by Quadra Engineering (now merged with Montgomery) and a Neptune Microfloc SWB-50 unit was installed. This package plant will treat 50,000 gallons of water per day, or 35 gpm. Presently the city treats approximately 5,000-6,000 gallons per day, so it is operating far below its capacity. As water enters the two-compartment mechanical flocculator, alum is added to clarify the raw water by providing a hydrous floc which entraps suspended matter. A polyelectrolyte is added as a flocculent aid to make the coagulated particles larger and enhance settling. From the flocculator, the water flows through a settling chamber and then a mixed media gravity filter containing anthracite coal, silica sand and garnet sand. In the final steps, dense soda ash is added to stabilize pH levels and reduce pipe corrosion, along with chlorine and fluoride.

The city washeteria is equipped with a toilet, showers, washers, dryers, two saunas, a 200,000 gallon water storage tank and a watering point. The plant has three pressure pumps, hot water heaters, a backup furnace to heat air, and two Well McLain boilers with 1,380,000 BTU/hr output. The 400 gallon water delivery truck delivers water to the residents three times per week, but has problems getting to some areas because of muddy roads and deep snow in the winter.

The City of Alakanuk charges residents for water service and washeteria use based on the following schedule:

Water delivery	\$.08 per gallon, plus \$2.00 delivery charge
Water at watering point	\$.05 per gallon
Clothes washers	\$3.00 per 30 pounds, \$2.00 per 18 pounds
Showers and sauna	\$1.50 per child, \$2.50 per adult

During the first half of the 1989 fiscal year, the washeteria facility spent \$67,268 and collected \$84,624 for a net revenue of \$17,356.

Some of the 25 HUD homes have piped water from collected rainwater; most others in the village have no plumbing. Of the 40 households responding to the July 1989 survey, 60% have room for a 6 by 10 foot bathroom.

The water treatment plant seems to be in good condition and should be able to meet the future needs of the village if properly maintained and operated.

#### Sewage

The laundry, sauna, and shower facility and the school and teacher's housing have piped water service, and discharge wastewater into a single cell total retention sewage lagoon. The clinic hook-up to the system is underway and should be finished soon. The 125 ft x 265 ft sewage lagoon was designed in 1983 by Peratrovich, Nottingham and Drage, Inc., with provisions for the addition of a second cell of the same size. The excavation depth elevation is 4 ft, with the berm height above the 15 foot flood level. The operating depth is 5 ft. The lagoon easily meets present needs because of its limited use, but it is not large enough to accommodate all of the village's waste. If it is to be used in conjunction with a honeybucket haul or piped sewer system, it would need to be enlarged.

#### Solid Waste

PHS project AN-81-237 provided the city with a fenced solid waste disposal site, a haul vehicle, and 250 individual garbage cans. The city operates the garbage collection and disposal service with no direct charge to residents. Although the dumpsters, which are dispersed throughout the city, became even more dispersed during the spring floods of 1989, they were retrieved and the system seems to be working well. If the system is managed well, it should meet existing and future needs.



## Design and Construction Considerations

### Permafrost

It appears that there is minimal permafrost in Alakanuk, although pockets of permafrost do exist between 4-15 ft (see soil logs in appendix A). March test holes in the airport and port area had an average seasonal frost depth of 3 ft and a maximum of 6 ft.

### Foundations

One of the most important aspects of designing a piped system or any other structure is choosing an appropriate foundation. Soils in the Alakanuk area are wet silts and sandy silts (see Appendix A). Typically, wet silty soil has very low bearing capacity, high settlement potential, and high frost susceptibility. Foundation loads should be as light and dispersed as possible. Large structures should have the capability to withstand substantial settlement and to be releveled as required. Large pads of non-frost susceptible material could be used for foundations but these can be prohibitively expensive. Gravel is not locally available in Alakanuk and the price of gravel delivered to Alakanuk is approximately \$35/ton. Surcharge loads with drainage structures are also a possibility. Piling foundations are generally the foundation of choice in this type of soil, however, the expense of piling construction maybe prohibitive. Typical soil logs from the Alakanuk area are included in Appendix A.

### Piping Materials

The recommended piping material for buried lines in all sanitation facilities discussed is insulated high density polyethylene (HDPE). See Figure 2 for a typical pipe section. This pipe is excellent because it is able to expand and contract with the freeze-thaw cycles without breaking. Heat tracing can be used, but provisions should be made for hot water thawing should the system freeze.


### Pipe Placement

In other arctic and sub-arctic areas, burial of pipes is the accepted method of system installation, but in Alakanuk, it is an unlikely choice because it would be extremely difficult to bury any system in the wet fine grained soils that are found in Alakanuk. Buried utilities in these type of soils are subject to substantial ground movement during annual freeze/thaw cycles.

Since the soil conditions in Alakanuk won't allow for a buried pipe system, an above ground pipe or utilidor system could be considered. Foundation possibilities are as follows:


#### 1. Laying the Pipe or Utilidor on the Ground

The advantage of this foundation is that it could be constructed with minimal disturbance of the existing ground surface and vegetation (Figures 3 and 4). It would also be accessible for maintenance and, due to the low profile, would not be as obtrusive as an above ground utilidor system on sills or piles. The pipe could be buried at road crossings and ramps or mounds could be provided to allow snowmobiles and other off-road vehicles to cross at various locations. Disadvantages are that the pipe is exposed to view and is subject to vandalism, frost movement, vehicular damage, and would require maintenance to maintain grade. Also, due to its buoyant characteristic, the pipe would float during a flood. System damage because of this problem could be minimized by anchoring the pipe. Laying the utilidor or pipe on the ground would also impede surface



PE JACKET PIPE SERIES CLASSIFICATION	INNER CORE PIPE O.D.	MINIMUM OUTER JACKET I.D.
SIX - INCH	6.625"	12" ± 1/4"
FOUR - INCH	4.5"	12" ± 1/4"
THREE - INCH	3.5"	12" ± 1/4"
TWO - INCH	2.375"	10" ± 1/4"

± LRS. TOLERANCES



NOTE: DRAWINGS NOT TO SCALE

#### OUTER JACKET

- 16 GAGE ALUMINUM
- WATER TIGHT HELICAL SEAMS UNDER 5 FT HEAD
- CORRUGATED AS PER SPECIFICATIONS

#### INSULATION

- LOW DENSITY CLOSED CELL RIGID URETHANE
- $K = 0.13 \text{ BTU-IN/HR FT}^2 \text{ } ^\circ\text{F INITIAL}$
- ASTM D 2341 76- 550674970034

#### INNER CORE PIPE

- HIGH DENSITY POLYETHYLENE
- ASTM D-2837 76 PRESSURE RATING MINIMUM OF 160 psi (+73°F, SERVICE FACTOR 0.8)
- CAPABLE OF WITHSTANDING CYCLIC PRESSURE FREEZE-THAW TESTING AS PER THIS SPECIFICATION
- NOT APPROVED FOR POTABLE WATER USE

FIGURE 2

HDPE PIPE



UTIDOR SECTIONS BEFORE CONNECTION

FIGURE 3



SMALL (0.4 m by 0.5 m) UTILIDOR PLACED DIRECTLY ON THE TUNDRA SURFACE CARRYING WATER, SEWER AND GLYCOL LINES, NOORVIK, ALASKA

### FIGURE 4

water movement and cause damming of water behind the pipe during annual floods. This alternative is the least "permanent" of any system and can be easily relocated, altered, or repaired if needed. It is the least expensive alternative.

## 2. Sill Supported Pipe or Utilidor

Sills would provide support for the utilidor or pipe system. The sills may be either of wood construction or be an earthen or gravel berm. Wood sill construction is easier and faster to install, does not create substantial dams which hinder drainage, and normally has a lower profile compared to a gravel sill. Gravel berms are less susceptible to frost jacking or settlement problems than is wood sill construction. The primary disadvantage to both sill systems is that they impede pedestrian and vehicular travel and would require transition zones where crossing under or over roads. Also, a gravel sill creates water drainage problems. Both types of sills would be susceptible to flood damage.

## 3. Pile Supported

The pile supported pipeline or utilidor system would offer the best protection against flood damage to the system. It would also offer good access to the pipelines for maintenance and repairs if it were designed with this in mind. However, the piles, utilidors and/or pipes can have high construction and maintenance costs. The primary disadvantage to utilidor on piles is that they are extremely conspicuous and impede travel within the community (Figure 5). The piles can be of steel, wood, or even thermal piles. Thermal piles are the most effective against frost heaving, but are expensive to construct and maintain. Any pile system is "permanent" and not easily moved or rerouted.

## Flood Considerations

The U.S. Army Corp of Engineers rates the flood hazard in Alakanuk "very high". The villagers report that floods occur every year. A recent flood (1989) in near-by Emmonak caused by an ice jam has caused damage to their piped system. Design considerations such as the following must be made to protect the sanitation facilities from flood damage.


- \* An adequate anchoring system ought to be able to withstand at least the buoyant force of the pipe or utilidor and allow movement at hose connections.
- \* The utilidor could be placed above the seasonal flood level.
- \* Weak links could be built in the pipe or utilidor, allowing sections to break away in high hazard areas in case ice flow or of flood. This would help protect the rest of the system from being damaged.
- \* Any system should be designed to facilitate repairs if flood damage does occur. This can be done by using commonly available construction materials, a simple design, and modular construction.

## Gravel/Select Fill

There is no gravel available in Alakanuk. In 1986, the village bought gravel from Pitkas Point for \$34-\$40 per ton. Gravel is also available from St. Mary's. The silty loam soil used to build the sewage lagoon was taken from the lagoon site itself.

## Drainage

Drainage is poor, and flooding frequent.



SEWAGE COLLECTION LINES ON PILING,  
BETHEL, ALASKA

FIGURE 5

### Equipment

The following equipment is available for rental from the city, though the current prices would be somewhat higher than those listed:

14 C Dozer	\$125/hr	or	\$5000/week
75 A Loader	\$55/hr	or	\$2200/week
65 B Grader	\$55/hr	or	\$2200/week
480 C Backhoe	\$45/hr	or	\$1800/week
City Truck (10 yd)	\$30/hr	or	\$1200/week
City Lodge	\$30/night		

The State of Alaska's Village Safe Water (VSW) and Matching Grants programs are directed to use specific equipment rental rates per Department of Environmental Conservation Policies and Procedures Manual Field Directive dated 2/1/89. Equipment rental rates should be discussed with VSW if State funds are used.

### Labor

Labor is available in the village. The sewage lagoon was built primarily with local workers.

## SANITATION IMPROVEMENT ALTERNATIVES

### General

#### Water Systems:

If the existing treatment plant continues to be well maintained and operated, it can provide all needed water for any water distribution alternative selected.

#### Wastewater Systems:

Table 2 lists some of the possible wastewater collection systems and their characteristics and benefits to the community.

Regardless of which wastewater collection alternative is chosen, a treatment scheme needs to be developed, as the present wastewater lagoon is too small to serve the community. The best wastewater treatment facility for small isolated communities is one that has low operational costs, low maintenance requirements, and meets the standards established by regulatory agencies. In Alakanuk, a facultative lagoon would best fulfill these requirements. The present facultative lagoon will have to be expanded. A typical lagoon cross-section is shown in figure 6.

The following water and wastewater system alternatives are discussed in this report:


1. Watering Points & Honeybucket Haul
  - A. Summer watering points
  - B. Year-round Watering Points
2. Trucked Water & Sewer
3. Piped Water & Sewer
  - A. Piped water and vacuum sewer
  - B. Piped water and pressure sewer

TABLE 2

## CHARACTERISTICS OF WASTEWATER COLLECTION SYSTEMS

Type	Soil Conditions	Topography	Economics	Other
Gravity	Non frost susceptible or Slightly frost susceptible with gravel backfilling material.	Gently sloping to prevent deep cuts and lift station.	Initial construction costs high but operational costs low unless above ground or lift stations used.	Low maintenance. High health and convenience improvements. Most hold grades. Flushing of low use lines may be necessary. Large diameter pipes necessary.
Vacuum	Most useful for frost susceptible or bedrock conditions, but can be used with any soil conditions.	Level or gently sloping.	Initial construction cost moderately high. Operational costs moderate.	Pipes laid in sawtooth profile to fit into utilidor. Can be used with any low flush toilet. One interface valve can serve a large school or motel. Requires a vacuum station for every 200 to 500 services. Pumps at vacuum station deliver sewage to treatment plant. Can separate blackwater and graywater. Uses 76-, 101-, and 152-mm pipe. No exfiltration.
Pressure	Most useful for frost susceptible or bedrock conditions, but can be used with any soil conditions.	Level, gently sloping or hilly.	Initial construction costs moderate. Operational costs moderately high.	Water saving if low water use fixtures are installed. High health and convenience improve- No central facility necessary - units are in individual buildings. No infiltration. Uses small pipes.
Vehicle-Haul	Year-round roads must be available.	Level, gently sloping or hilly.	Initial construction costs low. Operation costs very high.	Low water use and moderate health and convenience improvements. Operational costs must be subsidized.
Individual-Haul	Used with any soil conditions but boardwalks are necessary in some swampy conditions.	Level, gently sloping or hilly.	Initial construction cost and operation costs very low.	Low usage by inhabitants and thus low health and convenience improvements.





TYPICAL SEWAGE LAGOON SECTION

FIGURE 6

## 1. Watering Points and Honeybucket Haul

### A. Summer Watering Points:

Water would be carried from the water treatment facility to seven remote watering points throughout the village by non-circulating uninsulated small diameter pipes. The watering points wouldn't be enclosed (figure 7), and the system would be drained for the winter. See figure 8 for one possible watering point placement scheme. There would need to be some plumbing and pumping modifications done at the water treatment plant.

TABLE 3  
ESTIMATED COSTS FOR SUMMER WATERING POINTS

#### Capital Costs

Item	Quantity	Installed Unit Cost \$	Total Cost \$
Summer Watering Point	7ea	1000 each	7,000
2 inch PE Pipe	13,850 ft	7/ft	96,950
Pumphouse Modifications	1 job	10,000	10,000
Engineering at 12%			13,674
Contingency at 10%			11,395
TOTAL			\$ 139,019


#### Increased Yearly Operation & Maintenance


Electric	2000 kw	.34/kw	680
Fuel	100 gallons	1.50/gal	150
Labor	49 hr	12/hr	588
Repairs	1	1000	1000
TOTAL			\$ 2,418

### B. Year-round Watering Points:


Unlike the summer watering points, these would be enclosed, and operate the whole year. Water would be circulated through insulated water pipes laid on top of the ground and anchored. If properly designed these pipes could later be incorporated into a piped water system, allowing phased development as money becomes available. Keeping this in mind, the pipes should be sized large enough to accommodate the future demand of a piped water system. With this option, there would also need to be some plumbing and pumping modifications done at the water treatment plant.


Watering point locations are shown in figure 9, but this is just one possible placement scheme. It would also be possible to have a system with some summer and some winter watering points. With either summer or year-round watering points, input from the village residents concerning locations of the watering points should be incorporated into the final design. Table 4 outlines the cost of the total system, but if not enough money is available to construct the whole system at once, table 5 breaks the costs down by watering point, so the cost of phased construction can be seen.













**TABLE 4**  
**ESTIMATED COSTS FOR YEAR-ROUND WATERING POINTS**

**Capital Costs**

Item	Quantity	Installed Unit Cost \$	Total Cost \$
Pumphouse Modifications	1	25,000	25,000
Year-round Watering Point	7	6,400 each	44,800
4 Inch Insulated, anchored PE Pipe	29,540 ft	85/ft	2,510,900
Engineering at 12%			309,684
Contingency at 10%			289,038
<b>TOTAL</b>			<b>\$ 3,179,422</b>
<b>Increased Yearly Operation &amp; Maintenance</b>			
Labor	300 hr	12/hr	3,600
Electricity	3,500 kWh	.34/kWh	1,190
Repairs	6	3,000	18,000
Fuel	700 gal	1.50/gal	1,050
Pump Replacement Fund	1	1,000	1,000
<b>TOTAL</b>			<b>\$ 24,840</b>


**TABLE 5**  
**YEAR-ROUND WATERING POINT CAPITAL COSTS BROKEN DOWN BY POINTS**

Watering Point	Pipe (ft)	Cost \$	Cost with Eng. & Cont. \$	Location
1	2880	251,605	308355	Osler & Anderson
2	3200	279,561	344419	Between Fourth & Fifth
3	3960	345,957	426219	Between Fifth & Sixth
4	2880	251,605	308355	Seventh & Anderson
5	3720	324,999	400396	Anderson & First?
6	5700	497,969	613498	West Bend St
7	7200	629,013	777758	Native Store East of town
<b>TOTAL</b>		<b>29,540 ft</b>	<b>2,580,709</b>	<b>\$3,179,422</b>

**Honeybucket Haul:**

For pickup of honeybucket wastes, a heavy duty four wheel drive truck with at least a 500 gallon tank is needed. The wastes would be picked up at each house and poured in the tanker truck (Figure 10). The use of a truck with a holding tank should eliminate the spillage problems that were the downfall of the first haul system tried in Alakanuk. The truck would dump the waste into the sewage lagoon, which would have to be enlarged. Completion of the second cell should provide sufficient lagoon surface area and volume. A new garage must be built or the old garage renovated.





TRUCK FOR COLLECTING HONEYBUCKET  
WASTES, BARROW, ALASKA

FIGURE 10

**TABLE 6**  
**ESTIMATED COSTS FOR HONEYBUCKET HAUL**

**Capital Costs**

Item	Quantity	Installed Unit Cost \$	Total Cost \$
Honeybucket Haul Truck	1ea	50,000	50,000
Lagoon Modifications	1ea	70,000	125,000
Truck Garage	1job	75,000	75,000
Engineering at 12%			30,000
Contingency at 10%			<u>25,000</u>
<b>TOTAL</b>			<b>\$ 305,000</b>

**Yearly Operation & Maintenance**

Truck Replacement Fund	1	11,000	11,000
Labor	3800 hr	12/hr	45,600
Fuel	350 gal	2.00/gal	700
Repairs/maintenance	1	4000	4000
Insurance-Liability	1	1150	<u>1150</u>
<b>TOTAL</b>			<b>\$ 62,500</b>

Assumes truck replaced every 4 years.


**2. Trucked Water and Sewer:**

**General:**

This option should be considered if the City of Alakanuk decides not to have piped water and sewer installed in the near future. The trucks and individual holding tanks represent a substantial investment which would be largely obsolete if a piped system was built.


Under this system, each participating homeowner would have two insulated, heated tanks, one for water and one for wastewater (see Figure 11). The existing water truck could be used to get water from the washeteria and deliver it to the individual homeowners, pumping into their water tanks (Figure 12). Each home would be fitted with a low water use toilet, sink and shower. The wastewater would flow by gravity into the insulated holding tank and be pumped out periodically by the wastewater truck (Figures 13 and 14) into its tank and trucked to the sewage lagoon. Operation and maintenance costs for this type of system would tend to be high because the vehicles generally have a short life. There would probably be additional costs related to road improvement and maintenance. Garages must be built to house the vehicles.

**Trucks:** The efficiency and operation costs of this type of collection system depend on the size of the house and truck tanks, and on the hauling distance. The larger the truck tanks, the fewer trips, but the condition of the roads can limit the size of trucks used. The trucks should hold about 1000 gallons. Tanks on both trucks need to be insulated or surrounded by heated enclosures to keep the pump, piping and connections from freezing in the winter. The present water haul vehicle could be used as a back-up, but larger ones would probably be needed to do the bulk of the hauling.




INDIVIDUAL HOUSE HOLDING TANK

FIGURE 11




WATER DELIVERY TRUCK TANK PIPING AND EQUIPMENT DIAGRAM

FIGURE 12



VACUUM SEWAGE PUMPOUT VEHICLE

FIGURE 13



FILLING AND EMPTYING PROCEDURE FOR HOLDING TANK PUMPOUT TRUCKS

FIGURE 14

House Tanks: The house water tank should hold enough water for a 5 day supply and the sewage tank 7 days. The water and sewage tanks should have different sized hose connections to avoid mistaken cross connection. The extra structural support required in the house to carry the tank loads needs to be provided. The tank must have a large manhole with removable cover so that it can be easily removed and the tank cleaned out at least once a year to prevent buildup of solids in the bottom. The tanks must also be kept warm and well insulated to prevent freezing, either by being in or under a heated portion of the building, or by using heating coils.

Water Use and Lagoon Size: Water consumption would be no more than 35 gal/person/day and wastewater production no more than 25 gal/person/day. With a wastewater concentration of 200 mg/L, lagoon loading of 20 lb BOD/acre/day, and the design population of 750 people, the lagoon would need 1.8 acres of surface area. But for the lagoon to have enough volume for a 240 day retention, it would have to be 2.4 acres and 6 feet deep. This could be achieved by building a second, larger cell.

Costs: Costs for installing and running the system are shown in table 7. If funding isn't available for the full project, the city could start with just one water and one wastewater truck, serve only a portion of the city and expand as money becomes available.

**TABLE 7**  
**ESTIMATED COSTS FOR WATER AND WASTEWATER HAUL**

**Capital Costs**

<u>Item</u>	<u>Quantity</u>	<u>Installed Unit Cost \$</u>	<u>Total Cost \$</u>
Water Haul Truck	2	50,000	100,000
Wastewater Haul Truck	2	50,000	100,000
House Water & Wastewater Tanks	110	4,500	500,000
Household Plumbing and Fixtures	110	4,000	440,000
Lagoon Modifications	1	170,000	170,000
Four Vehicle Garage	1	225,000	225,000
Engineering at 12%			184,200
Contingency at 10%			<u>153,500</u>
<b>TOTAL</b>			<b>\$1,872,700</b>

**Yearly Operation & Maintenance**

Truck Replacement Fund	1	52,000	52,000
Labor	10,400 hr	12/hr	124,800
Fuel	2,400 gal	2.00/gal	4,800
Repairs/maintenance	4	2,500	10,000
Insurance-Liability	1	1500	<u>1,500</u>
<b>TOTAL</b>			<b>\$193,150</b>

\* Assumes trucks replaced every 4 years.

### 3. Piped Water and Sewer

A piped water and sewer system would provide the best level of service for the community, but it would also be the most expensive to install. The system could be installed in phases, as money is available. When water lines are installed, sewer lines need to be installed also.

#### Water consumption:

Water use in Alaska varies widely with the availability and cost of water, the type, size and location of the community, and the culture. Total community use ranges from 15 to 130 gallons per capita per day when a piped system is used. Water use in Alakanuk will probably be somewhere in the middle of that range. Initial water consumption will be lower, but increase as the residents become accustomed to a dependable, high quality water supply. Assuming that low water use fixtures will be installed and that few families own washing machines, the average daily per capita water consumption can be kept below 65 gallons. Water system design flows for both the present design population and the 20 year design population are shown in table 8.

**Table 8**  
**Piped Water System Demand**

Period of Demand (Peak Factor)	Present		Future	
	gpm	MGD	gpm	MGD
Average (1.0)	26	.0374	34	.0488
Maximum Hour (3.0)	78	.1121	100	.1462
Maximum Day (2.0)	52	.0748	68	.0975

#### Sewage Production & Lagoon Size:

If the daily per capita consumptive use is 65 gallons, the daily per capita wastewater discharge would be about 55 gallons. Assuming a BOD concentration of 200 mg/L, and loading of 20 lb/acre/day, a minimum surface area of 3.5 acres is needed. But this wouldn't provide enough volume capacity for a 240 day retention time. For that, the lagoon would have to be 5 acres and 6 feet deep.

#### Water Distribution:

To keep water distribution systems from freezing when exposed to arctic environments, circulating water mains have been used successfully in many northern communities. This approach could be used for water delivery in Alakanuk. Circulating pumps would be necessary to circulate water through the mains and back to the pumphouse for reheating. The pumps are sized to circulate the water at a velocity that would return it to the pumphouse before its temperature drops to freezing. The water heating boiler is sized to provide enough heat to prevent the water from freezing during extremely cold temperatures and to remain efficient when only small amounts of heat are needed. The heat control system should be automatic and only add heat when absolutely necessary. Maintenance would in part consist of servicing and monitoring of boiler operation. The operator of the water plant could do these tasks.

Three types of house service connections have been installed in other communities having circulating water mains.

1. Dual-Pipe system (hi/low pressure lines):

This type of system consists of a large diameter water supply line and a small-diameter return line. Service lines tap into the main and water is returned via the return line of the service connection by the pressure differential between the two mains. Control mechanisms for this type of system tend to be difficult, because varying consumption in different locations results in fluctuating pressure and flow rates in the supply and return mains. See figure 15 for dual-pipe system with vacuum sewer utilidor.

2. Extended Mains:

In an extended main distribution system, the water main runs directly to every house. Service lines are short and do not circulate. The major advantages to this system are that water in the main doesn't have to be circulated as much as with the pitorifice system, therefore pumping costs are lower, and that the short service lines are usually within the heated subfloor of the house and are better protected from freezing. The disadvantages of the extended main system are that it requires cutting into the main and extending it for each new house connection and that in most cases, the main doesn't follow rights-of-ways, but must cross through each served lot. New construction can be planned to minimize the visual impact and the obstructiveness of the main.

3. Pitorifice Connections:

In a system using a pitorifice connection to the main, individual service lines are typically around 70 feet long. The water service connection is a loop of 3/4 or 1 inch line inside a utilidor or an insulated pipe that leads to the house from the main. The pitorifice is the special connection between the main and service line that allows circulating water to be driven from the main through the service line loop and back to the main. The primary advantage of this system is the ability to keep the water mains in designated city rights-of-ways, although above ground service lines would cut through the homeowner's property. Also, future connections are easily accomplished by merely adding service saddles to the main rather than by cutting and adding main for each new home served. The major disadvantage to using the pitorifice connection is that the circulation rate of the main must be much higher than that of the extended main in order to drive the water through the service line loop. If homeowners run water continuously rather than plug in electric heat traces, expensive treated water is wasted.




FIGURE 15 UTILIDOR CROSS-SECTION




FIGURE 16 SERVICE CONNECTION



SECTION 8

SECTION 6

SECTION 5


SECTION 4

SECTION 3

SECTION 1

SECTION 7

SECTION 2



### Sewage Collection:

Due to the lack of topographical relief and poor soil conditions in Alakanuk, gravity dependent sewage collection is not feasible. There are two piped system alternatives; they are pressure and vacuum sewage collection. The relative advantages and disadvantages of each sewer system are shown in Table 10. One drawback to both of these systems is that they can't operate when the community power system fails.

#### A. Vacuum Sewage Collection:

In a vacuum collection system, the collection main is kept at a constant vacuum. Figures 15 and 16 show a typical utilidor cross-section and service connection. Household wastes are automatically released into the system through special vacuum seal valves along with a small charge of air. The air flows through the line, pushing the wastes along the main to a central collection point. Wastes are then pumped to the final treatment or disposal point. In Emmonak, close to Alakanuk, installation of a water system with a vacuum sewer system cost \$10 million, and operation and maintenance costs \$120/month/household. Approximate costs for the whole town are given in Table 9. The system could be built in phases as shown in Figure 17, and described in Table 12, with the costs broken down in Table 11. Even if built in phases, the initial costs of the vacuum station, and pumphouse and lagoon modifications wouldn't vary.

**TABLE 9**  
**ESTIMATED COSTS FOR PIPED WATER AND VACUUM SEWER**

<u>Capital Cost</u>		Installed	Total
Item	Quantity	Unit Cost	Cost
		\$	\$
Pumphouse Modifications	1	50,000	50,000
Lagoon Modifications	1	430,000	430,000
Vacuum Station	1	250,000	350,000
Anchored Utilidor	31,000 ft	190/ft	5,890,000
Household Plumbing & Fixtures	115	8,800	1,012,000
House Service Connections	115	4,500	517,500
Sub-total			8,249,500
Engineering at 12%			989,940
Contingency at 10%			991,140
<b>TOTAL</b>			<b>\$10,230,580</b>
<u>Yearly Operation &amp; Maintenance</u>			
<u>Water</u>			
Labor	2080 hr	\$12/hr	24,960
Utilidor Heating	9,600 gal	1.50/gal	14,400
Emergency Repairs	3 Job	5,000	15,000
Electric	34,400 kWh	.34/kWh	11,696
Heating Fuel	7,130 gal	1.50/gal	10,700
Miscellaneous	1	3,500	3,500
Circulating Pump Replacement Fund	1	2,200	2,200
<u>Sewer</u>			
Labor	2080hr	\$12/hr	24,960
Electric	18,000 kWh	.34kWh	6,120
Heating Fuel	400 gal	1.50/gal	600
Miscellaneous	1	3,500	3,500
Pump Replacement Fund	1	1,700	1,700
<b>TOTAL</b>			<b>\$119,336</b>

## PRESSURE SEWAGE COLLECTION

### Advantages

1. Operates independent of major grade changes compared to vacuum system
2. Will transport larger volumes of wastewater compared to vacuum system
3. Lower electrical operational cost compared to vacuum system

### Disadvantages

1. Structural modification may be required to support house lift station
2. Requires qualified operational personnel available to homeowner for pump maintenance
3. Power source required in each house to operate system
4. Maximum complexity for individual homeowner
5. Requires back-up individual pumps and heating of utilidor
6. Water and sewer mains in common utilidor may not meet State codes

## VACUUM SEWAGE COLLECTION

### Advantages

1. Uses minimum amount of water for blackwater transport
2. No power source is required in home for fixture operation-all valves are air operated
3. Complexity of operation is under community responsibility
4. Sewer mains operate under vacuum and minimize danger of contamination of utilidor or water system in cross connection situation
5. Structural modifications to existing homes are minimized
6. Vacuum valve components are easily changed
7. Sewage discharge lines can be surface mounted near ceiling of home if necessary

### Disadvantages

1. Relatively complex community operational requirement
2. Requires qualified personnel to operate
3. Requires back-up power supply, pumps, and heating for community facilities
4. System requires second pump station to discharge liquids from vacuum tank

## Comparison of Vacuum and Pressure Sewage Collection Systems

TABLE 10

**TABLE 11**  
**BREAKDOWN OF PIPED WATER AND VACUUM SEWER SYSTEM COSTS BY SECTION OF CITY**

Section Number of City	Number of Connections	Pipe (ft)	Pipe Cost \$	Service Connect. \$	All other non-eng. costs \$	SUB- TOTAL \$	TOTAL WITH ENG. & CONT. \$
1	9	1910	372400	40500	168678	581,578	740,000
2	7	2560	486400	31500	151100	669,000	831,675
3	25	4200	798000	112500	309450	1,219,950	1,510,500
4	18	2880	547200	81000	247875	876,075	1,086,800
5	13	2450	465500	58500	203900	727,900	904,250
6	10	1660	315400	45000	177500	537,900	670,200
7	16	5030	955700	72000	230250	1,257,950	1,557,300
8	12	3990	758100	54000	195000	1,007,100	1,248,300
9	5	6400	1216000	22500	133547	1,372,047	1,681,555
TOTALS:	115	31130	5914700	517500	1817300	8,249,500	10,230,580

**TABLE 12**  
**DESCRIPTION OF CITY BREAKDOWN FOR WATER AND SEWER**

City Section Served	Description of Section
1	North of water plant, between Front and Third streets
2	West of Water Plant, to point where Anderson St turns
3	From turn at Anderson to Fifth St
4	Between Fifth and Sixth St
5	Between Sixth and Seventh St
6	Between Seventh and Eighth St
7	East of water plant, to houses just past First(?) St
8	Between Eighth and Tenth St
9	East to Native store

#### B. Pressure Sewage Collection:

In a pressure collection system, the collection main is under constant pressure. The primary cost of operating the positive pressure sewer system is heating the mains. Unlike the water system, the sewer mains wouldn't circulate, and the sewage must be kept above freezing by using a heat trace or a "bleed" system. Due to the cost of bleeding treated water, heat tracing is probably the most economical solution, and is assumed for the cost estimate. In the final design, both bleeding and heat tracing should be considered as should the possibility of using waste heat from the AVEC generators. Each household in Alakanuk would be equipped with a collection tank and small grinder pump (Figures 18-20). The pumps would activate individually when a large enough volume of wastewater had been collected in the sump. They must be installed lower than the building plumbing fixtures, and still be accessible for maintenance and repair. The grinder pumps must also well insulated and heated to protect them against freezing. Costs associated with the grinder pumps are the power requirement for daily operation, regular inspection, and repair every 5 to 10 years. Again, the system could be built in phases as shown in figure 17, with total costs in table 13, and broken down costs in table 14. The pumphouse and lagoon modifications must be included in phase 1, and homes not served should have honeybucket haul service.

TABLE 13  
ESTIMATED COSTS FOR PIPED WATER AND PRESSURE SEWER

#### Capital Costs

Item	Quantity	Installed Unit Cost \$	Total Cost \$
Lagoon Modifications	1 job	430,000	430,000
Pumphouse Modifications	1 job	50,000	50,000
Anchored Utilidor	31,000 ft	190/ft	5,890,000
Sump/Grinder Pump	115 ea	3,400/home	391,000
House Service Connection	115 ea	4,500/home	517,500
Household Plumbing and Fixtures	115 ea	4,000/home	460,000
Engineering at 12%			928,620
Contingency at 10%			866,712
TOTAL			\$9,533,832


#### Yearly Operation & Maintenance

##### Water

Labor	2080 hr	\$12/hr	24,960
Utilidor Heating	9,600 gal	1.50/gal	14,400
Emergency Repairs	1 job	5,000	5,000
Electric	34,400 kWh	.34/kWh	11,696
Heating Fuel	7,130 gal	1.50/gal	10,700
Miscellaneous	1	3,500	3,500
Circulating Pump Replacement Fund	1	2,200	2,200


##### Sewer

Labor	2080 hr	\$12/hr	24,960
Grinder Pump Operation & Maintenance	115 pumps	81/pump	9,315
Sewer Line Heating	31,000 ft	1.60/ft	49,600
TOTAL			\$156,331




TYPICAL PUMP-GRINDER INSTALLATION

FIGURE 18



PUMP-GRINDER CHARACTERISTICS  
(adapted from Environment/One Corp. Ltd.)

FIGURE 19



<sup>®</sup> FRP - FIBERGLASS REINFORCED POLYESTER

DIAGRAM SOURCE: Grinder Pumps for Low Pressure Sewer Systems, Environment One Corp., New York, 1978.

## TYPICAL GRINDER PUMP UNIT

FIGURE 20



TABLE 14

## BREAKDOWN OF PIPE WATER AND PRESSURE SEWER SYSTEM COSTS BY SECTION OF CITY

Section Number	Pipe of Connections	Pipe (ft)	Pipe Cost \$	Service Connect. \$	All other non-eng. costs \$	Sump Pump \$	TOTAL WITH ENG.&CONT. \$
1	9	1960	372400	40500	86600	30600	530100 652712
2	7	2560	486400	31500	78000	23800	619700 764087
3	25	4200	798000	112500	150500	85000	1146000 1401053
4	18	2880	547200	81000	122000	61200	811400 1001529
5	13	2450	465500	58500	102000	44200	670200 826037
6	10	1660	315400	45000	91000	34000	485400 597619
7	16	5030	955700	72000	111000	54400	1193100 1473095
8	12	3990	758100	54000	98500	40800	951400 1171854
9	5	6400	1216000	22500	75700	17000	1331200 1645846
TOTALS:	115	31130	5914700	517500	915300	391000	7738500 9533832

### Recommendations

The installation of a complete high level-of-service water and sewer facility may require a multi-step process and it is likely that all of the steps would take several years to accomplish. The steps are listed below could be undertaken by the City of Alakanuk.

1. At this point in time, the water delivery system seems to be working well, the most pressing problem that the city needs to address is indiscriminate honeybucket dumping. A honeybucket haul system would be the quickest and least expensive system that could be developed to address this problem. The other two wastewater disposal options, piped sewer or trucked haul service with individual holding tanks, could be built in sections as the need and funds dictate.
2. Piped water and sewer maybe the best solution for a city the size of Alakanuk from a sanitary point of view, but not necessarily from an economic standpoint. The community must establish this project as their priority for several years. They must determine if they can obtain the money necessary to install this type of system. If not, then the trucked water and wastewater is probably the best solution. The total cost of this type of system would be approximately \$1.9 million (Table 7).
3. The community may elect to start a piped utility system by building year-round watering points with circulating water pipes that can later be incorporated into the water and sewer system. As stated earlier in this report there is a potential for flood and ice damage with above ground pipes. A detailed study would be required to aid in flood protection.
4. The next step would be to design and construct a portion of the proposed water and sewer improvements in an area having the highest development density and greatest number of potential customers. This would be section 1 shown in figure 17.
5. After an evaluation of the performance of this initial section, the system could be expanded into other areas having an adequate number of potential customers, starting with section 2, then section 3 and so on. The total cost of the system would be around \$10 million if all sections of the city were developed (Tables 9-14).

### Conclusions

Piped water and sewer is feasible, and may be the best solution to the community's sanitation problems, but it would be very expensive. The capital cost to provide the entire city with service would be approximately \$10 million, though the cost could be lowered if some outlying areas were not served. The cost to operate this type of system would exceed \$100 per family per month. This fee is in excess of what a survey of the community's residents indicated they could pay.

An alternative to a piped system would be a water and wastewater haul system to service the entire community for approximately \$1.9 million.

Table 15 on the following page summarizes and compares the capital and operational costs of the systems covered in this report. The capital and operational cost estimates included in this report can be used to decide which option to pursue. Regardless of which option is chosen, a source of funding must be found to finance the sanitation facilities required for Alakanuk. The project could be done in phases as funding permits. Some phasing schemes have been included in the report, but other alternatives are certainly possible.

TABLE 15 TABLE OF SYSTEM SUMMARY/COMPARISON

<u>SYSTEM DESCRIPTION</u>	<u>CAPITAL COST</u> (rounded)	<u>INCREASE ANNUAL O&amp;M COST</u>	<u>INCREASED ANNUAL/ (MONTHLY) O&amp;M COST PER HOUSEHOLD</u>
<u>Summer watering points</u>	\$139,000	\$2,418	\$24 (\$2)
<p>Advantages: Increased water distribution during the summer months. Residents would have easier access to water during the summer months.</p> <p>Disadvantages: This option does not address the sewage disposal problem that exists in the community. Water distribution would not be improved in the winter months.</p> <p>Summary this option: The slight increase in service provided under this option would not satisfy the community desire for upgraded service and does not address the pressing problem sewage disposal.</p>			
<u>Year-round watering points</u>	\$3,179,400	\$24,840	\$248 (\$21)
<p>Advantages: Improved year-round water distribution system would provide the community would easier access to water all year. Improvements made under this project could be used in future water development projects; the arctic pipe and the plumbing modifications in the pumphouse could be used in a piped system providing service to individual houses.</p> <p>Disadvantages: This option does not address the sewage disposal problem that exists in the community.</p> <p>Summary this option: This option would greatly improve the access most residents would have to their water supply and could be used as an intermediate step in a phased water development plan. Sewage disposal would continue to be a health problem in the community.</p>			
<u>Trucked honeybucket haul</u>	\$305,000	\$62,500	\$625 (\$52)
<p>Advantages: Addresses the sewage disposal problem that exists in the community. A tanker truck with a covered holding tank would eliminate the problem of sewage spillage as it is being hauled to the lagoon. This was a problem in the haul system that was previously operated in the community.</p> <p>Disadvantages: Access to houses must be maintained year-round in order for the trucked service to operate properly. Snow removal would be essential in order for this system to operate properly. Truck maintenance would be required and is expensive. This option would not improve water distribution in the community.</p> <p>Summary this option: If properly operated this option could eliminate problems with sewage disposal in the community and could be used as a temporary measure until more funds are located for a higher level of service. This option does not improve the water distribution system in the community. Maintenance of the haul vehicles is expensive.</p>			
<u>Trucked delivery service for water and wastewater.</u>	\$1,873,000	\$193,150	\$1,932 (\$161)
<p>Advantages: Provides a relatively high level of service for a relatively low investment. This option would eliminate the sewage disposal problem.</p> <p>Disadvantages: High operation and maintenance costs. Good road maintenance would be essential to effective operation of the system.</p> <p>Summary this option: Operation and maintenance cost required for this option would be difficult to collect from the community. Phased development possible.</p>			
<u>Piped water and vacuum sewer</u>	\$10,231,000	\$119,336	\$1,193 (\$99)
<p>Advantages: Provides highest level of service. Phased development possible.</p> <p>Disadvantages: Extremely expensive capital cost; approximately \$100,000 per house.</p> <p>Summary this option: Vacuum sewer technology is operating in near-by Emonak. The villages could possibly share O&amp;M responsibilities.</p>			
<u>Piped water and pressure sewer</u>	\$9,534,000	\$156,331	\$1,563 (\$130)
<p>Advantages: Provides highest level of service. Phased development possible.</p> <p>Disadvantages: Extremely expensive capital cost; approximately \$100,000 per house.</p> <p>Summary this option: Slightly higher O&amp;M costs than the vacuum sewer option.</p>			

#### REFERENCES

Ott Water Engineers, Inc., Alexander Lake Water and Sewer Study, Preliminary Report, Anchorage Alaska, August 1982, pp 17-22.

USPHS, Emmonak, Alaska. Conceptual design and cost study for piped community water and sewer service., Anchorage, Alaska, June 1983, pp 6-15.

Quadra Engineering, Inc., City of Goodnews Bay, Water Planning Study, Anchorage, Alaska, January 1985, pp 1,34-35,71-73.

Alaska DOT, Materials Section, Engineering Geology and Soils Report, Anchorage, Alaska, March 1988.

U.S. Dept of Interior, MMS, Village Economics In Rural Alaska, Anchorage, Alaska, November 1988, pp 23-45.

D.W. Smith et al, Cold Climate Utilities Manual, 1986, Sections 8 & 9.

**APPENDIX A**  
**SOIL INFORMATION & WELL LOGS**


Alakanuk, Alaska

WELL LOG

U.S. PUBLIC HEALTH SERVICE, DIVISION OF INDIAN HEALTH

LOCATION Abandoned BIA School Well DATE STARTED 8-13-62  
 DATE COMPLETED 8-31-62 CREW Russell Cotten  
 TOTAL DEPTH OF WELL 89' FT. CASING INSTALLED 91' 2" DIAMETER 4"  
 GROUT - SCREEN SIZE .010 MFG. - LENGTH 10' 2"  
 STATIC WATER LEVEL 3' 6" ground HRS. PUMPED - @ - GPM DRAWDOWN - FT

DEVELOPMENT PROCEDURES -



DATE	DEPTH FROM - TO	FORMATION
	0' - 27'	Thawed grey clay, hard sand
	27' - 31'	Fine sand
	31' - 39'	Pure grey sand
	39' - 45' 3"	Dark grey sandy mud
	45' 3" - 49'	Dark grey sandy mud
	49' - 70' 3"	Fine grey sand
	70' 3" - 89'	Fine sand

WATER DATA FIELD TEST

TASTE - APPEARANCE FRESH Dark Brown

AFTER 24 HOURS - IRON - CHLORIDES -

TDS - ALKALINITY - pH -

SPECIAL NOTES:

Test pumped at an unknown rate, but rate known to be greater than 5 gpm. Water dark brown when boiled, produced a dark brown, precipitate, greasy


2/1/85

## TEST PIT AND TEST HOLE LOG EXPLANATION

STATE OF ALASKA

DEPARTMENT OF TRANSPORTATION &amp; PUBLIC FACILITIES

MATERIALS SECTION



## Abbreviations

Bk = Black w/ = with

Bn = Brown sa. = some

Bl = Blue tr. = trace

Gn = Green sl. = slightly

Gr = Gray G.S. = Grab Sample

Or = Orange S.S. = Split Spoon

Rd = Red S.T. = Shelby tube

Tn = Tan M.S. = Modified Shelby Tube

## Soil Size Distribution

Based on U.S. Standard Sieve Sizes:

Boulders > 10"

Cobbles 3"-10"

Gravel #10-#3"

Sand #200-#10

Silt/Clay < #200

## Plan View Symbols

Power Auger

Hand Auger

Surface Sample

Hand Probe Depth & Location

Hand Dug Test Pit

Dozer/Backhoe Pit

Berm

Terrace or Bank

Swamp

Graphic Symbols (Two or more soil symbols may be used together to indicate a combination of soil types.)

Organics (Org)

Gravel (Grl)

Sand (Sa)

Silt (Si)

Clay (Cl)

Ice (Ica)

Bedrock (Bx)

Cobbles and/or Boulders



## LOG OF BORING 1

## LABORATORY TESTS

GROUP TEMP. BLOWS/FOOT MOISTURE CONTENT (%) DRY DENSITY (pcf) DEPTH (ft) SAMPLE FROZEN

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 2/27/82

A 112.6

Brown SILT W/FIBROUS PEAT layering  
ML, F-4, saturated

Frozen to 3.0'

D 1.7°C 34.2

Grey SILT, ML, F-4  
wet

B 2.0°C 36.5

Grey coarse SILT W/AMORPHIC PEAT  
layering, M, F-4  
wet to saturated

▼ Free water observed while drilling  
at 12.0'

B 2.0°C 41.9

TOTAL DEPTH OF BORING - 15.0'  
Boring sloughed to 3.5' after drilling

## LOG OF BORING 2

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 3/6/82

Organic Content 2.47% A 95.8

Organic Content 2.03% A -0.3°C 106.5

A -0.2°C 63.7

D -0.3°C 38.8

G -0.3°C 25.3

E -0.2°C 26.5

Brown SILT W/FIBROUS PEAT layering  
ML, F-4  
wet to saturated

Visible ice crystals'

Grey SILT, ML, F-4

Grey SAND, SP-SM

Grey SILT, ML, F-4

Grey SILTY SAND, SM, F-2, wet  
TOTAL DEPTH OF BORING - 15.5'  
PVC installed to 14.0'

**JML** LAMBE AND ASSOCIATES

Soils Laboratory and Geotechnical Engineering

no. 82-292.05 Appr. JML Date 3/19/82

## LOG OF BORING

Alakanuk Road and Dock Project  
Peratrovich & Nottingham  
Anchorage Alaska

PLATE


2

# LABORATORY TESTS

GROUP  
TEMP.  
BLOWS/FOOT  
MOISTURE  
CONTENT (%)  
DRY  
DENSITY (pcf)  
DEPTH (ft)  
SAMPLE  
FROZEN

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 2/27/82

A 124.0  
A 0.2°C 53.9  
B 0.5°C 36.8  
B 0.5°C 46.2




Frozen to 1.0'  
Brown SILT W/FIBROUS PEAT layering, ML  
F-4, wet to saturated  
▼ Free water observed after drilling  
at 3.0'  
Grey SILT W/AMORPHIC PEAT layering, ML  
F-4, saturated  
TOTAL DEPTH OF BORING - 15.0'  
Boring sloughed to 3.5' after drilling

## LOG OF BORING 4

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 3/9/82

A 100.4  
A -0.3°C 81.0  
G -0.5°C 25.5  
B -0.5°C 38.5



Brown-grey SILT W/FIBROUS PEAT layering  
ML, F-4, saturated  
Visible ice crystals  
Grey SAND, SP-SM, wet  
Grey SILT W/AMORPHIC PEAT LAYERING, ML  
F-4, wet to saturated  
TOTAL DEPTH OF BORING - 15.0'  
No free water observed  
PVC installed

Chemical Analysis  
Fanic Contents 5.19%

**JML** LAMBE AND ASSOCIATES

Soils Laboratory and Geotechnical Engineering

File no. 82-292.05 Appr. JML Date 3/19/82

## LOG OF BORING

Alakanuk Road and Dock Project  
Peratrovich & Nottingham

Anchorage

Alaska

PLATE

**3**

# LABORATORY TESTS

GROUP	TEMP.	BLOWS/FOOT	MOISTURE CONTENT (%)	DRY DENSITY (pcf)	DEPTH (ft)	SAMPLE FROZEN
A			99.7		0	
A	0.0°C		85.0		5	
B	0.1°C		42.7			
B	0.2°C		46.0		10	
B	0.2°C		35.0		15	

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 3/27/82

Frozen to 1.5'  
Free water observed while drilling at 2.5'  
Free water observed after drilling at 3.4'  
Brown SILT W/FIBROUS PEAT layering, F-4, saturated  
Grey to brown SILT W/AMORPHIC PEAT layering, ML, F-4, saturated  
TOTAL DEPTH OF BORING - 15.0'

## LOG OF BORING 6

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 3/9/82

A	0.0°C	128.6
A	0.2°C	53.5
B	3.5°C	49.7
E	0.0°C	40.5

Frozen to 1.75' /  
Grey SILT W/FIBROUS PEAT LAYERING, ML F-4, saturated  
Grey SILT W/AMORPHIC PEAT LAYERING, ML, F-4, saturated  
Stiff drilling at 13.0'  
Grey SILTY SAND, SM, F-2, saturated  
Frozen from 13.0 - 15.0'  
TOTAL DEPTH OF BORING 15.0'  
PVC installed

**JML** LAMBE AND ASSOCIATES

Soils Laboratory and Geotechnical Engineering

No. 82-292.05 Appr. JML Date 3/19/82

## LOG OF BORING

Alakanuk Road and Dock Project  
Peratrovich & Nottingham  
Anchorage Alaska

PLATE  
**4**

# LABORATORY TESTS

GROUP  
TEMP.


BLOWS/FOOT

MOISTURE  
CONTENT (%)

DRY  
DENSITY (pcf)  
DEPTH (ft)  
SAMPLE  
FROZEN

EQUIPMENT B-24 Track  
ELEVATION Exist Ground DATE 2/27/82

A 142.1  
A 126.4  
A -0.2°C 81.5  
B 0.0°C 50.8  
B -0.5°C 58.7



Brown-grey SILT W/FIBROUS PEAT layering  
ML, F-4, wet to saturated

Frozen to 5.5' 7


Grey SILT W/AMORPHIC PEAT layering, ML  
F-4, wet

Frozen from 8.5 to 10.5'  
TOTAL DEPTH OF BORING 10.5'  
No free water observed

## LOG OF BORING 8

EQUIPMENT B-24 Track  
ELEVATION Exist Ground DATE 3/9/82

A 124.8  
B -0.2°C 41.2  
F -0.1°C 35.1  
F -0.5°C 35.5



Brown SILT W/FIBROUS PEAT layering, ML  
F-4  
Frozen to 1.5' 1

Grey coarse SILT W/AMORPHIC PEAT  
layering, ML, F-4, wet

Grey SANDY SILT, ML, F-4  
wet to saturated

Frozen from 4.0' to 15.0"

TOTAL DEPTH OF BORING - 15.0'  
PVC installed

**JML** LAMBE AND ASSOCIATES

Soils Laboratory and Geotechnical Engineering

No. 82-292.05 Appr. JML Date 3/19/82

## LOG OF BORING

Alakanuk Road and Dock Project  
Peratrovich & Nottingham

Anchorage,

Alaska

PLATE

5

## LABORATORY TESTS


GROUP TEMP. BLOWS/FOOT  
MOISTURE CONTENT (%)  
DRY DENSITY (pcf)  
DEPTH (ft)  
SAMPLE FROZEN

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 2/27/82

Mechanical Analysis

Organic Content 5.10%  
Mechanical Analysis  
Specific Gravity

A 99.6  
F 1.0°C 35.7  
D 0.7°C 35.7  
F 1.2°C 42.8  
B 0.2°C 45.4




Brown SILT W/FIBROUS PEAT layering  
ML, F-4  
Frozen to 2.0' /  
Grey SANDY SILT TO SILT, ML, F-4, wet  
Saturated below 6.5'  
Free water observed at 6.5', after  
drilling  
Free water observed at 7.0' while  
drilling  
Grey SILT W/AMORPHIC PEAT layering, ML  
F-4  
TOTAL DEPTH OF BORING 10.5'  
Boring sloughed to 6.5' after drilling

EQUIPMENT B-24 Track  
ELEVATION Exist. Ground DATE 3/9/82

Organic Content  
2.51%

A -0.5°C 70.0  
B 1.0°C 36.5  
B 2.5°C 38.8  
B 2.0°C 46.3



Brown SILT W/FIBROUS PEAT layering, ML  
F-4  
Frozen to 2.0' /  
Grey SILT W/AMORPHIC PEAT layering,  
ML, F-4, saturated  
TOTAL DEPTH OF BORING 15.0'  
PVC installed

JML LAMBE AND ASSOCIATES

Soils Laboratory and Geotechnical Engineering

No. 82-292.05 Appr. JML Date 3/19/82

## LOG OF BORING

Alakanuk Road and Dock Project  
Peratrovich & Nottingham

Anchorage

Alaska

PLATE

6

**APPENDIX B**

**COMMUNITY SURVEY RESULTS**

### SANITARY SURVEY FOR ALAKANUK

This survey was developed by the Public Health Service in the summer of 1989. It was given to the City who distributed and then collected the survey forms in the city and then returned them to the Public Health Service. There were 40 responses from the approximately 130 households.

- 1) Do you think water supply improvements are needed?

Yes	<u>40</u>
No	<u>0</u>

- 2) Do you think sewer improvements are needed?

Yes	<u>39</u>
No	<u>1</u>

- 3) In general, do present water sources and waste disposal practices adequately protect the health of local residents?

Yes	<u>12</u>
No	<u>28</u>

- 4) Which of the following sanitation systems would you like to see constructed in Alakanuk?

Waste Disposal Bunkers	<u>2</u>	
Honey Bucket Haul System	<u>3</u>	
Piped Water and Sewer System	<u>37</u>	
Summer only watering points	<u>0</u>	
Year round watering points	<u>14</u>	
Existing water delivery expanded or upgraded		<u>5</u>
All of the above	<u>2</u>	
Other suggestions		

- 5) Do any of the following washeteria facilities need improvement?

Showers	<u>11</u>
Laundry	<u>16</u>
Watering point	<u>12</u>
Other	<u>Present facility too small; dryers not hot enough.</u>

- 6) What were the problems with the honeybucket haul system which is no longer used?

Too expensive	<u>3</u>
Not collected regularly	<u>13</u>
Too inconvenient	<u>14</u>
Smells from lagoon in summer	<u>12</u>
Other	<u>Too small; spillage; health hazard. 6</u>

7) Should the honeybucket haul system be restarted?

Yes	<u>7</u>
No	<u>28</u>

Reason why or why not:

Disease and smells caused by spillage; Never collected in some areas;  
Deep snow in winter doesn't allow pick-up.

8) Where do you presently dispose of human wastes?

Pits by home	<u>25</u>
Bunker	<u>1</u>
Outhouse	<u>0</u>
Slough	<u>11</u>
VSW Washeteria wastewater facility	<u>1</u>
On the ground near home	<u>11</u>
Fenced solid waste site	<u>3</u>
In alders along roadside	<u>1</u>
Other location <u>Anywhere; trash bins.</u>	<u>2</u>

9) What do you presently use as your source of drinking water?

Washeteria watering point	<u>16</u>
Water delivery	<u>23</u>
Slough	<u>4</u>
Rainwater	<u>32</u>
Ice melt	<u>7</u>
Other source <u>School facilities; anything convenient.</u>	

10) Describe any problems or suggestions concerning the water delivery system or watering point.

Delivery stops during the cold months; It is too expensive; Danger of  
contamination; Don't know when in operation; No delivery in some areas due  
to road conditions; Not enough water or personnel; Too much salt and  
chlorine in water; Not delivered often enough.

11) If you haul water, how much is collected each time?

5 gal	<u>4</u>
10 gal	<u>6</u>
15 gal	<u>4</u>
20 gal	<u>6</u>
30 gal	<u>9</u>
more than 30 gal	<u>26</u>



12) How often do you collect water?

1 - 2 times/week	15
3 times/ week	2
Daily	9
Twice daily	3
When it rains	1

13) How far is your house from the watering point?

2 - 3 miles	8
1 - 1.5 miles	8
.25 - .5 mile	9
Very close	2

14) If you don't use the water supply, please indicate why.

Traditional source more convenient	5
Water supply too expensive	5
Water from supply tastes bad	9
Consider water supply unhealthy	2
Conditions at water point unsanitary	3
Supply is unreliable	4
Supply point too far from home	12

Other Water from supply stains clothes. 1

15) Is your house large enough to install a 6 foot by 10 foot bathroom?

Yes	25
No	14

16) Which bathroom fixtures are installed in your home?

Kitchen sink	24
Bathroom sink	26
Tub/Shower	23
Water Closet	10
N/A	7

17) How many people live in your house?

2 - 3	4
4 - 5	13
6 - 7	11
8 - 9	6
10 - 11	3

18) How many months during the year is your whole family away from your house?

More than 3	5
2 - 3	0
1 - 2	1
Less than 1	33

19) How do you heat your house?

Oil	<u>28</u>
Wood	<u>23</u>

20) Once constructed, sanitation facilities are sometimes very expensive to operate and maintain. How much could you afford to spend to help operate and maintain sanitation facilities in Alakanuk?

Less than \$20 per month	<u>11</u>
\$21 - \$35 per month	<u>11</u>
\$36 - \$50 per month	<u>7</u>
\$51 - \$65 per month	<u>2</u>
\$66 - \$79 per month	<u>0</u>
More than \$80 per month	<u>3</u>
Don't know	<u>3</u>

21) How much do you presently spend for utilities (electricity, fuel oil etc.)?

\$20 - \$40 per month	<u>3</u>
\$40 - \$60 per month	<u>6</u>
\$60 - \$80 per month	<u>6</u>
\$80 - \$100 per month	<u>10</u>
More than \$100 per month	<u>16</u>

22) Should the City of Alakanuk help pay to operate and maintain sanitation facilities?

Yes	<u>33</u>
No	<u>5</u>

23) Would you support a 1 - 2 percent increase in the City sales tax to help operate and maintain sanitation facilities in Alakanuk?

Yes	<u>31</u>
No	<u>6</u>
Don't know	<u>2</u>

24) Where do you dispose of your trash?

Fenced solid waste disposal site	<u>20</u>
Along river banks	<u>2</u>
Other <u>Dumpsters</u>	<u>19</u>

25) Please add any other problems or suggestions you have concerning sanitation facilities in Alakanuk.

The city should try to do something about indiscriminate honeybucket dumping. Something should be done about diseases. More trash dumpsters are needed, especially by the laundromat and pool hall. Water delivery needs improvement.