

# Executive Summary

---

## Introduction

CRW Engineering Group, LLC was hired to prepare assessments of communities throughout Alaska that do not have piped water and sewer systems. These communities are considered “unserved” as their current water and sewer service consists of small-haul, self-haul and/or honey buckets. Assessment work included drafting conceptual-level layouts of piped water and sewer systems, estimating the size of needed associated infrastructure and estimating both the O&M and capital costs of these systems.

Initially 36 village were identified as being “unserved.” A few more were added for a total of 38 communities. This executive summary provides a brief overview of how the assessments were prepared and what conclusions could potentially be derived from the analysis. This was a desk-top level effort. Site visits were not included as part of the effort. The basis for the assessments was previous community information provided by VSW, available mapping from the DCCED and limited input from the communities and currently assigned engineers/project managers for those communities.

## Sizing Model

The first step was to develop a system sizing model. Using industry-standard rules of thumb, we developed an excel-based spreadsheet that used the following:

- 20 year population growth of 1.5%
- Water demand of 50 gallons per person per day
- Max circulating water loop length 10,000 feet
- Water treatment facility-additions of 800 square feet for “good water” i.e. groundwater with minimal-required treatment and 1,200 for “poor water”, i.e. surface water or groundwater high in iron and manganese
- Water storage tanks were sized based on daily demand, fire flows and 3 days of storage reserve. If the source is surface water, chlorine contact time was also factored into the sizing.
- Commercial, residential and school service numbers were obtained from the HITS database and a review of the DCCED Community Maps
- Upgraded two-cell sewage lagoons were sized to provide secondary treatment based on organic loading rates of 0.17 lbs of BOD5 per capita per day or hydraulic loading, whichever was greater

## Soils & Foundation

We hired Golder Associates Inc. who provided us with a summary of soils information for each community. The recommendations for above grade vs below grade piping and the foundation type for buildings and water storage tanks, were based on the following:

- A review of the soils information from Golder. Generally speaking:
  - Soft, poorly drained soils or discontinuous permafrost = Pile foundations
  - Firm soils or continuous permafrost = Thermosyphon stabilized gravel pads
  - Stiff soils and no permafrost = Gravel pads
- Photographic research of existing foundations within the community (i.e. the school)
- Unique circumstances i.e. some communities may have soils suitable for a buried system but have a significant amount of buried historical resources, posing problems for a below grade system.

### Water Mains & Services

All the water mains were laid out to be circulating loops with a max length of 10,000 feet. Multiple loops were used in several communities. All water services were assumed to be an average length of 75 feet and all use circulating pumps.

### Gravity vs. Pressure Sewer

Most of the unserved communities are in flatter areas with ice-rich silty soils that are not conducive to gravity sewer systems. Where topo showed suitable elevation gain and soils were better, we proposed buried gravity sewer mains and service lines in combination with community lift stations as needed to pump waste to the lagoon. Systems in flatter areas are shown with above grade, pressure systems that use individual sewage pump stations at each structure. The systems for some communities included a combination of gravity and pressure sewer systems.

### Capital and O&M Costs

The system components were input in the state-provided capital cost model, last updated in 2010. Additional costs were added for items not included in the model including sewage grinder pump stations and electrical service upgrades. Each capital cost estimate includes inflation (3%), 15% construction contingency and 20% for design and construction administration.

The O&M costs are a function of the population, number of services and local energy costs. Administration costs are fixed at \$500 per month. Labor costs are a function of the size of the system (i.e. less than 50 services equates to 24 hours per week of operator time, etc.). Repair/replacement costs were calculated at 5% of the labor, fuel and electricity. Because of the desk-top nature of these assessments, it is not recommended that decision-making be solely based on the estimated O&M costs.

### User Fees

Each assessment includes an estimate of the user fees that would be required to cover the costs of operating the piped water and sewer system. The user fee breakdown generally follows ARUC averages. As directed by the state, the following percentages were used:

- Residential Rate                      59% of total O&M cost
- Commercial Rate                    14.5% of total O&M cost
- School Rate                            26.5% of total O&M cost

Since proposed user fees are based on the O&M estimates and the above directed percentages, it is not recommended that decision-making be solely based on these numbers. Those systems that show residential user fees within 10% to 20% of the estimated users' ability to pay, may benefit from future study.



## Findings & Conclusions

The attached Chart 1 lists the communities in order by population, along with the estimated residential user fee and the Homeowners' ability to pay the fee. The ability to pay is based on 5% of the median household income for that community (obtained from US Census data). As can be seen on the chart, there is a clear and obvious relationship between the population and residential O&M costs. The smaller the community, the higher the user fee and vice versa. Based on the results of the assessment and with a few exceptions, Chart 1 generally shows that a piped system is unlikely to be affordable for a community with less than 100 residents.

Chart 2 lists the communities in order of population density, along with the overall population and estimated capital costs of the piped water and sewer system. Density was calculated as a function of population over the length of circulating water mains. The general trend of higher capital costs per person with lower community density can be seen. This shows the benefit to more dense community planning, in order to keep costs down for future projects. Additionally, some variation was found in the graph trend aside from density, which could usually be explained by the increased cost of transporting workers and materials to more remote communities.


Finally, there are a handful of other factors that can impact the costs of building and maintaining a piped water and sewer system:

- 1) Seasonal Water Source – A piped water system requires year round flows. Many communities use a seasonal water source. In these cases, we assumed a large raw water reservoir (storage tank) would be needed to provide the flows for a piped system. Heat add and circulation of such a large tank increases O&M costs. If this community has poor soils, a large tank could require a pile supported foundation which drives the costs up even further.
- 2) Functioning School – Because of the user fee breakdown, not having a school to cover almost 30% of the system O&M means residential and commercial customers carry a higher financial burden.
- 3) Community Population – As noted above, the population base covers the cost of operating and maintaining the system. The smaller the population, the larger the user fee.
- 4) Community Layout/Density – If the community is spread out, pipe runs are longer which translates to increased capital costs. Longer pipe runs also increase the costs of heating and circulating, which means higher O&M costs.

Generally speaking, those communities that have a year-round water source, a functioning school and are densely populated are good candidates for further study of a piped water and sewer system.


Attachments: Chart 1 – Population, Estimated Monthly Residential Fee & Ability to Pay  
Chart 2 – Population, Capital Cost per Capita & Density

**VSW Unserved Communities Project 2016**  
 Chart 1 - Population, Estimated Monthly Residential Fee and  
 Ability to Pay (5% Median Household Income)



# VSW Unserved Communities Project 2016

## Chart 2 - Population, Capital Cost per Capita & Density



# Alatna, Alaska

## Community Information & Existing Infrastructure

The Village of Alatna is an Inupiaq community of 21 people located on the north bank of Koyukuk River, southwest of its junction with the Alatna River. There are 17 residential units and 4 commercial/public facilities for a total of 21 services. The existing water and sewer services provided in Alatna consist of self-haul system from the central watering point attached to the water treatment plant and honey buckets. Only the washeteria/clinic discharge to the lagoon through a force main. The existing water and sewer infrastructure consists of the following:

- Well Water – 10 gpm transfer pump
- Treated Water Storage – 4,800 gallons
- Water Treatment Plant/Multi-Purpose Building – 2,312 SF, built in 2008
- Water Treatment – Filtration, chlorination, and potassium permanganate
- Sewage Lagoon – Two Cell, 1.2 acres

Soils around Alatna consist of non-plastic silt material with permafrost approximately 8-18 feet below surface.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 8,500 feet of pipe, and the pressure sewer system approximately 5,900 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	2	10	-
<b>Water Storage (gallons)</b>	40,200	4,800	35,400
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	0.4	1.2	-
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,840	-	1,840
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	8,500	-	8,500
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,900	-	5,900
Individual Grinder Pump Stations (GPS) (ea)	21	-	21
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	1,600	-	1,600
Pressure Sewer Service Lines (lf)	1,600	-	1,600

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Alatna. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village	
				Alatna	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	21	\$28,096.69	\$590,031
3	Sewage collection mains or services (gravity or force), above ground	LF	7,500	\$323.17	\$2,423,773
12	Water distribution, mains or services, above ground	LF	10,100	\$435.26	\$4,396,125
14	Water storage tank, no foundation	Gal	35,400	\$12.80	\$453,226
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
18	Foundation - freeze back piles	SF	1,840	\$692.10	\$1,273,464
Total Estimated Cost in 2010 dollars (rounded):					<b>\$12,112,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$14,462,400</b>
27	Individual Grinder Pump Stations	EA	21	\$30,000	\$630,000
28	Electrical Service Upgrades	EA	21	\$5,500	\$115,500
Subtotal					<b>\$15,207,900</b>
29	Construction Contingency (15%)	LS	1	\$2,281,200	\$2,281,200
30	Design & Construction Administration Services (20%)	LS	1	\$3,041,600	\$3,041,600
Total					<b>\$20,530,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$40,500
Electricity	\$21,900
Other (R&R, Training, etc.)	\$13,000
<b>Total</b>	<b>\$106,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Alatna are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 432	17	85%	\$ 74,900
Public/Commercial Service	\$ 648	4	100%	\$ 31,100
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 106,000</b>



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Alatna.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
ALATNA

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
1



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 2/26/2016  
 Community Alatna  
 Input

**Existing Community & System Data**

2015 Population	21
2015 Number of Services	21
HITS Database (E1 & H1-H7)	17
DCED Mapping Commerical/Public Facilities/School	4
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	4800
Water Treatment Capacity	10
Existing Sewage Lagoon Size	1.2

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	5854	8464
Gravity Sewer Main		0	
Pressure Sewer Main	x	5854	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Alatna

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	2	
Req Water Storage (gallons) (less existing)	35,400	640 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	-	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,840	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	8,500	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	5,900	
	Individual Grinder Pump Stations (GPS) (ea)	21	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	1,600	
	Pressure Sewer Service Lines (lf)	1,600	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	2	10	-
Water Storage (gallons)	40,200	4,800	35,400
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	0.4	1.2	-
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,840	-	1,840
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	8,500	-	8,500
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,900	-	5,900
Individual Grinder Pump Stations (GPS) (ea)	21	-	21
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	1,600	-	1,600
Pressure Sewer Service Lines (lf)	1,600	-	1,600



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	2/26/2016	
Community	Alatna	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	21 people	2015 ADOL
2015 Number of Services	21 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	26 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	10 gpm	
Average Day (ADD)	1,281 gpd	50 gallons per Capita
Max Day (MDD)	2,562 gpd	2 x ADD
Peak Hour	5 gpm	3 x MDD
Treatment Capacity	2 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	2 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	4,800 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	2,562 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	7,687 gallons	3 days x DO
Water Storage Tank Volume	40,250 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	9,077 gallons	CT/RCxPeak Hour/BF
Required Water Storage	40,200 gallons	
Required Additional Storage	35,400 gallons	0
Estimate of Min Platform Size (3' clearance around)	640 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	3 acres	
Organic Loading Based Size check	0.2 acres 79.1	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	0.4 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	0.4 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Alatna**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	21	\$28,096.69	\$590,031
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	7,500	\$323.17	\$2,423,773
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	10,100	\$435.26	\$4,396,125
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	35,400	\$12.80	\$453,226
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,840	\$692.10	\$1,273,464
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$12,112,277**

# O&M Cost Estimate Piped Water & Sewer System

4/12/2016

**Community:** Alatna

## General Community Data

Current population	21	persons
Average number of people per house	1.2	
Service Connections		
Number of houses	17	
Number of public/commerical buildings	4	
Number of schools	0	
Total number of service connections	21	
Burdened labor rate	\$20	hr
Electricity cost (Public facility)	\$0.66	kWh
Electricity cost (Residential service)	\$0.24	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	1280 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	3512 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	40,200 gallons
Length of water line to/ from tank	75 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	8500 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	
Total length of sewer mains	4810 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	990 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

4/12/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

4/12/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,076 /month	\$8,609.51
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$77 /month	\$919.30
Water storage tank	\$37 /month	\$293.30
Water storage tank line	\$16 /month	\$131.33
Water mains	\$1,860 /month	\$14,884
Service lines	\$345 /month	\$2,758
<u>Wastewater system</u>		
Sewer mains	\$1,053 /month	\$8,423
Service lines	\$345 /month	\$2,758
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$217 /month	\$1,734
	Subtotal	\$40,500
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$676 /month	\$8,118
HVAC/hydronic system	\$676 /month	\$5,412
Water treatment	\$11 /month	\$126
Pumps		
Intake or well	\$11 /month	\$126.40
WST circulation	\$89 /month	\$713
Pressure/booster	\$16 /month	\$189.60
Main line circulation	\$709 /month	\$5,671
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$177 /month	\$1,415
Lagoon discharge pump	\$152 /year	\$152
	Subtotal	\$21,900
<b>Other Costs</b>		
Equipment R&R	\$4,368 /year	\$4,368
Miscellaneous materials & supplies	\$2,621 /year	\$2,621
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$13,000

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$40,500
Electricity	\$21,900
Other	\$13,000
<b>Total</b>	<b>\$106,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 432	17	85%	\$ 74,900
Public/Commerc	\$ 647.92	4	100%	\$ 31,100
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 106,000</b>

# Allakaket, Alaska

---

## Community Information & Existing Infrastructure

The City of Allakaket is a Koyukon community of 111 people located on the south bank of the Koyukuk River, southwest of the Alatna River junction. There are 68 residential units, 13 commercial/public facilities and one school for a total of 82 services. The existing water and sewer services provided in Allakaket consist of self-haul system from watering points and honey buckets. The water treatment plant and washeteria discharge to the lagoon through a force main. The existing water and sewer infrastructure consists of the following:

- Well Water – 20 gpm transfer pump
- Treated Water Storage – 100,000 gallons
- Water Treatment Plant/Washeteria – 2,048 SF, built in 1996
- Water Treatment – Addition of chlorine and fluoride
- Sewage Lagoon – Two Cell, 0.8 acres

City of Allakaket is located within the continuous permafrost region of Alaska. Most areas are underlain by fine-grained frozen soils varying in depth.

## Piped System Description

The piped water and sewer system will be a combination of above and below grade piping. The northern part of the community is flat terrain and would best be served by an above ground pressure sewer system (10,600 LF) and circulating water loop (16,300 LF). The southern area of the community is built on a hillside and can likely accommodate a buried gravity sewer system (7,600 linear feet) and circulating water main (11,600 LF). A total of 22 services will be connected to the buried gravity sewer will not require individual grinder pump stations (GPS). Approximately 55 homes and buildings on the north side would require GPS units. The pressure sewer system including the force main will require two sewer main lift stations, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 800 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	20	-
Water Storage (gallons)	84,200	100,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	-	800
Sewage Lagoon Size (acre)	2.4	0.8	1.6
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	800	-	800
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	27,900	-	27,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	20,200	-	20,200
Individual Grinder Pump Stations (GPS) (ea)	55	-	55
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	6,200	-	6,200
Pressure Sewer Service Lines (lf)	4,200	-	4,200
Gravity Sewer Service Lines (lf)	2,000	-	2,000

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Allakaket. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village	
				Allakaket	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	82	\$28,096.69	\$2,303,929
2	Sewage collection mains or services (gravity or force), buried	LF	9,600	\$585.53	\$5,621,061
3	Sewage collection mains or services (gravity or force), above ground	LF	16,800	\$308.62	\$5,184,824
4	Sewage lift station	EA	2	\$1,172,426.77	\$2,344,854
10	Sewage lagoon, barrow, local material	Acre	1.6	\$1,157,613.17	\$1,852,181
12	Water distribution, mains or services, above ground	LF	34,100	\$426.53	\$8,701,122
13	Water distribution, mains or services, buried	LF	13,700	\$594.07	\$8,138,772
15	Water treatment plant, no foundation	SF	800	\$2,542.06	\$2,033,649
19	Foundation - thermosyphen stabilized gravel pad	SF	800	\$1,049.95	\$839,957
Total Estimated Cost in 2010 dollars (rounded):					<b>\$37,020,000</b>

VSW - Unserved Communities Project  
Allakaket Piped Water & Sewer Assessment

Estimated Capital Costs (cont.)					
Total with Inflation (3% per year for 6 years)					<b>\$44,203,800</b>
27	Individual Grinder Pump Stations	EA	60	\$30,000	\$1,650,000
28	Electrical Service Upgrades	EA	82	\$5,500	\$451,000
<b>Subtotal</b>					<b>\$46,304,800</b>
29	Construction Contingency (15%)	LS	1	\$6,945,700	\$6,945,700
30	Design & Construction Administration Services (20%)	LS	1	\$9,261,000	\$9,261,000
<b>Total</b>					<b>\$62,511,500</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$26,600
Fuel	\$116,700
Electricity	\$38,100
Other (R&R, Training, etc.)	\$20,500
<b>Total</b>	<b>\$207,900</b>


The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Allakaket are listed below:

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 177	68	85%	<b>\$ 122,995</b>
Public/Commercial Service	\$ 186	13	100%	<b>\$ 29,046</b>
School Service	\$ 6,206	1	100%	<b>\$ 55,858</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 207,900</b>

Due to the layout of the community and the required water main length needed to serve the north and south sections of town, this project would be ideal for the incorporation of a heat recovery system.



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Allakaket.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

3/4/2016  
Allakaket

**Existing Community & System Data**

2015 Population	111
2015 Number of Services	82
HITS Database (E1 & H1-H7)	68
DCED Mapping Commerical/Public Facilities/School	14
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Good
Water Storage Tank	100000
Water Treatment Capacity	20
Existing Sewage Lagoon Size	0.8

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	20200	27900
Gravity Sewer Main	x	7600	
Pressure Sewer Main	x	12600	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      Allakaket

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	9	
Req Water Storage (gallons) (less existing)	-	- sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	800 sf
Req Sewage Lagoon Size (acre) (less existing)	1.6	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	800	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	27,900	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	20,200	
	Lift Stations for Gravity Sewer Mains	2	
	Individual Grinder Pump Stations (GPS) (ea)	55	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	6,200	
	Gravity Sewer Service Lines (lf)	2,000	
	Pressure Sewer Service Lines (lf)	4,200	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	20	-
Water Storage (gallons)	84,200	100,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	-	800
Sewage Lagoon Size (acre)	2.4	0.8	1.6
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	800	-	800
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	27,900	-	27,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	20,200	-	20,200
Individual Grinder Pump Stations (GPS) (ea)	55	-	55
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	6,200	-	6,200
Pressure Sewer Service Lines (lf)	4,200	-	4,200
Gravity Sewer Service (lf)	2,000	-	2,000

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/4/2016	
Community	Allakaket	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	111 people	2015 ADOL
2015 Number of Services	82 services	Only 55 will require GPS units
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	135 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	6,772 gpd	50 gallons per Capita
Max Day (MDD)	13,544 gpd	2 x ADD
Peak Hour	28 gpm	3 x MDD
Treatment Capacity	9 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	9 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	100,000 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	13,544 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	40,632 gallons	3 days x DO
Water Storage Tank Volume	84,176 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{(-0.0693T)}) \times (e^{(0.361PH)}) \times (e^{(0.113RC)})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	47,980 gallons	CT/RCxPeak Hour/BF
Required Water Storage	84,200 gallons	
Required Additional Storage	- gallons	0
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{(1/2)}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Good	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	800 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.8 acres	
Organic Loading Based Size check	1.2 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	181.8	
Hydraulic Loading Based Size	2.4 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	2.4 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

Allakaket

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	82	\$28,096.69	\$2,303,929
2	Sewage collection mains or services (gravity or force), buried	LF	9,600	\$585.53	\$5,621,061
3	Sewage collection mains or services (gravity or force), above ground	LF	16,800	\$308.62	\$5,184,824
4	Sewage lift station	EA	2	\$1,172,426.77	\$2,344,854
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.6	\$1,157,613.17	\$1,852,181
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	20,400	\$426.53	\$8,701,122
13	Water distribution, mains or services, buried	LF	13,700	\$594.07	\$8,138,772
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	800	\$2,542.06	\$2,033,649
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	800	\$1,049.95	\$839,957
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$37,020,349**

# O&M Cost Estimate Piped Water & Sewer System

9/12/2016

**Community:** Allakaket (North Side Plus)

## General Community Data

Current population	111	persons
Average number of people per house	2.4	
Service Connections (North Side)		
Number of houses	46	
Number of public/commerical buildings	8	
Number of schools	1	
Total number of service connections	55	
Burdened labor rate	\$16	hr
Electricity cost (Public facility)	\$0.66	kWh
Electricity cost (Residential service)	\$0.24	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	2532 ft
Water line heated for freeze protection (Yes or No)	Y
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	2848 sf
Raw water quality (Good or Poor)	Good

### Water Storage

Size of tank(s)	100,000 gallons
Length of water line to/ from tank	60 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main (North Side)	16300 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	51
Number of facilities served by lift/pump station #2	82
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains (North Side)	10600 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	1970 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/12/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/12/2016

## Estimated O&M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$26,624
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$873 /month	\$6,981.75
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$405 /month	\$4,859.14
Water storage tank	\$91 /month	\$729.60
Water storage tank line	\$13 /month	\$105.06
Water mains	\$3,568 /month	\$28,542
Service lines	\$903 /month	\$7,223
<u>Wastewater system</u>		
Sewer mains	\$2,320 /month	\$18,561
Service lines	\$903 /month	\$7,223
Lift/pump station buildings	\$306 /month	\$2,451.46
Force main to lagoon	\$431 /month	\$3,450
	Subtotal	\$80,100
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$549 /month	\$6,583
HVAC/hydronic system	\$549 /month	\$4,389
Water treatment	\$11 /month	\$134
Pumps		
Intake or well	\$56 /month	\$668.13
WST circulation	\$89 /month	\$713
Pressure/booster	\$84 /month	\$1,002.20
Main line circulation	\$709 /month	\$5,671
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$193 /month	\$2,311
HVAC/hydronic system	\$193 /month	\$1,541
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$193 /month	\$2,318.12
Sewer/force main glycol circulation	\$177 /month	\$1,415
Lagoon discharge pump	\$802 /year	\$802
	Subtotal	\$27,500
<b>Other Costs</b>		
Equipment R&R	\$6,711 /year	\$6,711
Miscellaneous materials & supplies	\$4,027 /year	\$4,027
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$16,700

### Summary (North Side Plus)

Administration	\$6,000
Labor	\$26,600
Fuel	\$80,100
Electricity	\$27,500
Other	\$16,700
<b>Total</b>	<b>\$157,000</b>

### Summary (North & South)

Administration	\$6,000
Labor	\$26,600
Fuel	\$116,700
Electricity	\$38,100
Other	\$20,500
<b>Total</b>	<b>\$207,900</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 177	68	85%	\$ 122,995
Public/Commerc	\$ 186.19	13	100%	\$ 29,046
School Service	\$ 6,206.50	1	100%	\$ 55,858
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 207,900</b>

# O&M Cost Estimate Piped Water & Sewer System

9/12/2016

**Community:** Allakaket (South Side)

## General Community Data

Current population		persons
Average number of people per house	0.0	
Service Connections (South Side)		
Number of houses	22	
Number of public/commerical buildings	5	
Number of schools	0	
Total number of service connections	27	
Burdened labor rate	\$16	hr
Electricity cost (Public facility)	\$0.66	kWh
Electricity cost (Residential service)	\$0.24	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))		
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Treatment

Size of water treatment plant building		sf
Raw water quality (Good or Poor)		

### Water Storage

Size of tank(s)		gallons
Length of water line to/ from tank		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ	
Number of circulating water loops	1	
Total length of Water Main	11600	ft
Water mains heated for freeze protection (Yes or No)	Yes	
Location of the mains (Above ground (AG) or Buried)	Buried	
Average service line length	75	ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure	
Number of individual facility pump stations		
Number of community lift/pump stations		
Number of facilities served by lift/pump station #1		
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations		sf
Total length of sewer mains	7600	ft
Sewer mains heated for freeze protection (Yes or No)	Yes	
Number of circulating glycol loops	1	
Location of the mains (Above ground (AG) or Buried)	Buried	
Average service line length	75	ft

### Wastewater Treatment / Disposal

Length of force main		ft
Force main heated for freeze protection (Yes or No)		
Location of force main (Above ground (AG) or Buried)		
Lagoon discharged seasonally with pump (Yes or No)		



# O&M Cost Estimate

## Piped Water & Sewer System

9/12/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management		/month
-----------------------------	--	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/12/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$0 /month	\$0
<b>Labor</b> (WTP Operator)	24 hrs/week	\$0
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$0 /month	\$0.00
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$0 /month	\$0.00
Water storage tank	\$0 /month	\$0.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$1,523 /month	\$18,281
Service lines	\$266 /month	\$3,191
<u>Wastewater system</u>		
Sewer mains	\$998 /month	\$11,977
Service lines	\$266 /month	\$3,191
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$0 /month	\$0
	Subtotal	\$36,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Water treatment	\$0 /month	\$0
Pumps		
Intake or well	\$0 /month	\$0.00
WST circulation	\$0 /month	\$0
Pressure/booster	\$0 /month	\$0.00
Main line circulation	\$709 /month	\$8,506
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$177 /month	\$2,123
Lagoon discharge pump	\$0 /year	\$0
	Subtotal	\$10,600
<b>Other Costs</b>		
Equipment R&R	\$2,360 /year	\$2,360
Miscellaneous materials & supplies	\$1,416 /year	\$1,416
Water quality testing	\$0 /year	\$0
Operator training	\$0 /year	\$0
Insurance	\$0 /year	\$0
	Subtotal	\$3,800

## Summary (South Side)

Administration	\$0	Covered in North Plus Estimate
Labor	\$0	Covered in North Plus Estimate
Fuel	\$36,600	
Electricity	\$10,600	
Other	\$3,800	
<b>Total</b>	<b>\$51,000</b>	

# Arctic Village, Alaska

---

## Community Information & Existing Infrastructure

Arctic Village is a Gwich'in community of 192 people located on a terrace above the east fork of the Chandalar River, a tributary of the Yukon River. There are 59 residential units, 15 commercial/public facilities and one elementary/high school for a total of 75 services. The existing water and sewer services provided in Arctic Village consist of self-haul water system from the water treatment building and outhouses. The water treatment plant/washeteria and school are served with piped water and sewer. The existing water and sewer infrastructure consists of the following:

- Chandalar River – 25 gpm portable transfer pump
- Treated Water Storage – 100,000 gallons
- Water Treatment Plant/Washeteria – 2,158 SF, built in 2015/2016
- Water Treatment – Conventional filtration and chlorination
- Sewage Lagoon – Single Cell, 0.8 acres

Arctic Village is situated on the northern edge of the Porcupine Plateau Physiographic Province just south of the eastern Brooks Range. The area is generally underlain by frozen sand and silt. The thickness of the permafrost ranges from 5 to 10 feet deep.

## Piped System Description

The piped water and sewer system will be buried and consist of approximately 22,000 feet of circulating water mains, and 13,100 feet of pressure sewer mains. The water system will consist of three circulating loops. The pressure sewer system would require individual grinder pump stations at each building, glycol heat trace for freeze protection, and one lift station to transport wastewater to the lagoon. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 600 sf facility is included to house the equipment needed for water distribution equipment. The existing 100,000 gallon water storage tank is sufficient to meet the CT-required volume of 83,000 gallons and provide a small reserve for fire flows.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	16	25	-
Water Storage (gallons)	83,000	100,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	600	-	600
Sewage Lagoon Size (acre)	4.1	0.8	3.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	600	-	600
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	22,000	-	22,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	13,100	-	13,100
Individual Grinder Pump Stations (GPS) (ea)	74	-	74
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,600	-	5,600
Pressure Sewer Service Lines (lf)	5,600	-	5,600

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Arctic Village. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs			Village Arctic Village		
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	74	\$28,096.69	\$2,079,155
2	Sewage collection mains or services (gravity or force), buried	LF	12,750	\$566.33	\$7,220,716
3	Sewage collection mains or services (gravity or force), above ground	LF	350	\$860.09	\$301,030
4	Sewage lift station	EA	1	\$1,097,461.43	\$3,292,384
10	Sewage lagoon, barrow, local material	Acre	3.3	\$997,504.08	\$3,291,763
12	Water distribution, mains or services, above ground	LF	27,600	\$424.29	\$11,710,440
15	Water treatment plant, no foundation	SF	600	\$2,604.41	\$1,562,645
19	Foundation - thermosyphen stabilized gravel pad	SF	600	\$1,329.95	\$797,967
Total Estimated Cost in 2010 dollars (rounded):					<b>\$30,256,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$36,127,200</b>
27	Individual Grinder Pump Stations	EA	75	\$30,000	\$2,220,000
28	Electrical Service Upgrades	EA	75	\$5,500	\$407,000
Subtotal					<b>\$38,754,200</b>
29	Construction Contingency (15%)	LS	1	\$5,813,100	\$5,813,100
30	Design & Construction Administration Services (20%)	LS	1	\$7,750,800	\$7,750,800
Total					<b>\$52,318,100</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$26,600
Fuel	\$177,100
Electricity	\$44,600
Other (R&R, Training, etc.)	\$25,900
<b>Total</b>	<b>\$280,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Arctic Village are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 253	59	85%	<b>\$ 152,382</b>
Public/Commercial Service	\$ 266	15	100%	<b>\$ 47,857</b>
School Service	\$ 8,862	1	100%	<b>\$ 79,761</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 280,000</b>



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Arctic Village.dwg



LEGEND:

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP



HOME ADDITION FROM HITS MAP



PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
ARCTIC VILLAGE

DATE  
MAR 2015

SCALE  
GRAPHIC

FIGURE  
3



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/6/2016  
Community Arctic Village  
Input

**Existing Community & System Data**

2015 Population	192
2015 Number of Services	75
HITS Database (E1 & H1-H7)	59
DCED Mapping Commerical/Public Facilities/School	16
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	100000
Water Treatment Capacity	25
Existing Sewage Lagoon Size	0.8

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	13100	22000
Gravity Sewer Main		0	
Pressure Sewer Main	x	13100	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Arctic Village

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	16		
Req Water Storage (gallons) (less existing)	-	-	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	600	600	sf
Req Sewage Lagoon Size (acre) (less existing)	3.3		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	600	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	22,000	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	13,100	
	Individual Grinder Pump Stations (GPS) (ea)	74	
			school already connected
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	5,600	
	Pressure Sewer Service Lines (lf)	5,600	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	16	25	-
Water Storage (gallons)	83,000	100,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	600	-	600
Sewage Lagoon Size (acre)	4.1	0.8	3.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	600	-	600
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	22,000	-	22,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	13,100	-	13,100
Individual Grinder Pump Stations (GPS) (ea)	74	-	74
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,600	-	5,600
Pressure Sewer Service Lines (lf)	5,600	-	5,600

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/6/2016	
Community	Arctic Village	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	192 people	2015 ADOL
2015 Number of Services	74 services	Decrease to 74 because the school is already served
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	234 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	25 gpm	
Average Day (ADD)	11,714 gpd	50 gallons per Capita
Max Day (MDD)	23,428 gpd	2 x ADD
Peak Hour	49 gpm	3 x MDD
Treatment Capacity	16 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	16 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	100,000 gallons	
Demand Based Volume (if source is GW)	Check Min CT Requirements	
Daily Operation (DO) (gallons)	23,428 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	70,283 gallons	3 days x DO
Water Storage Tank Volume	123,711 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$L \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	82,992 gallons	CT/RCxPeak Hour/BF
Required Water Storage	83,000 gallons	Existing Tank is larger than CT-Required Tank
Required Additional Storage	- gallons	0
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	600 sf	Good Water Quality (no treatment other than CL) = 800 sf The WTP is brand new. Additional space of 600 sf is sufficient to accommodate distribution system equipment.
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.8 acres	
Organic Loading Based Size check	2.0 acres 239.1	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	4.1 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	4.1 acres	Either organic loading based or hydraulic, whichever is greater



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Arctic Village**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	74	\$28,096.69	\$2,079,155
2	Sewage collection mains or services (gravity or force), buried	LF	12,750	\$566.33	\$7,220,716
3	Sewage collection mains or services (gravity or force), above ground	LF	350	\$860.09	\$301,030
4	Sewage lift station	EA	3	\$1,097,461.43	\$3,292,384
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	3.3	\$997,504.08	\$3,291,763
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	27,600	\$424.29	\$11,710,440
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	600	\$2,604.41	\$1,562,645
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	600	\$1,329.95	\$797,967
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$30,256,100**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Arctic Village

## General Community Data

Current population	192 persons
Average number of people per house	3.3
Service Connections	
Number of houses	59
Number of public/commerical buildings	15
Number of schools	1
Total number of service connections	75
Burdened labor rate	\$16 hr
Electricity cost (Public facility)	\$0.54 kWh
Electricity cost (Residential service)	\$0.36 kWh
Cost per gallon for heating oil	\$12.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	600 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	2758 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	100,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	3
Total length of Water Main	22000 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	75
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	12750 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	350 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$26,624
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,690 /month	\$13,522.23
Raw water line	\$263 /month	\$2,101.25
Raw water heat addition	\$1,401 /month	\$11,206.66
Water storage tank	\$182 /month	\$1,459.20
Water storage tank line	\$22 /month	\$175.10
Water mains	\$5,778 /month	\$69,341
Service lines	\$1,477 /month	\$17,729
<u>Wastewater system</u>		
Sewer mains	\$3,349 /month	\$40,186
Service lines	\$1,477 /month	\$17,729
Lift/pump station buildings	\$306 /month	\$2,451.46
Force main to lagoon	\$153 /month	\$1,226
	Subtotal	\$177,100
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$435 /month	\$5,216
HVAC/hydronic system	\$435 /month	\$5,216
Water treatment	\$79 /month	\$946
Pumps		
Intake or well	\$79 /month	\$945.56
WST circulation	\$73 /month	\$583
Pressure/booster	\$118 /month	\$1,418.34
Main line circulation	\$1,740 /month	\$20,879
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$79 /month	\$946
HVAC/hydronic system	\$79 /month	\$630
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$120 /month	\$1,442.38
Sewer/force main glycol circulation	\$434 /month	\$5,210
Lagoon discharge pump	\$1,135 /year	\$1,135
	Subtotal	\$44,600
<b>Other Costs</b>		
Equipment R&R	\$12,416 /year	\$12,416
Miscellaneous materials & supplies	\$7,450 /year	\$7,450
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$25,900

## Summary

Administration	\$6,000
Labor	\$26,600
Fuel	\$177,100
Electricity	\$44,600
Other	\$25,900
<b>Total</b>	<b>\$280,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 253	59	85%	\$ 152,382
Public/Commerc	\$ 266	15	100%	\$ 47,857
School Service	\$ 8,862	1	100%	\$ 79,761
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 280,000</b>

# Atmautluak, Alaska

---

## Community Information & Existing Infrastructure

Atmautluak is a Yup'ik community of 319 people located on the west bank of the Pikmiktalik River, 20 miles northwest of Bethel within the Yukon-Kuskokwim Delta. There are 63 residential units, 19 commercial/public facilities, one elementary school and one high school for a total of 84 services. The existing water and sewer services provided in Atmautluak consist of self-haul system from a watering point located at the water treatment plant, and sewage bunkers throughout the community. The existing water and sewer infrastructure consists of the following:

- Well Water – 20 gpm transfer pump
- Treated Water Storage – 10,000 gallons
- Water Treatment Plant/Washeteria – 2,048 SF, built in 1980
- Water Treatment – Greensand filter and potassium permanganate

The community currently utilizes a tundra honeybucket lagoon and pond, which equates to a little over 10 acres to dispose of the community's waste. While not uncommon in the region, tundra sewage lagoons can be extremely difficult to quantify, properly maintain, and permit. For the purposes of this assessment, the tundra lagoons are not included as an existing "usable" facility.

The area around Atmautluak is generally underlain by continuous permafrost with thawed areas adjoining large bodies of water. The soil is characterized as poorly drained, medium loam with a medium erosion potential. The surface layer consists of poorly drained, non-arable fibrous peat.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 14,900 feet of pipe, and the pressure sewer approximately 8,700 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house, glycol heat treat for freeze protection, and a lift station to transport wastewater to the lagoon. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	27	20	7
Water Storage (gallons)	185,700	10,000	175,700
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	6.8	-	6.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	3,620	-	3,620
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	12,400	-	12,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,500	-	9,500
Individual Grinder Pump Stations (GPS) (ea)	84	-	84
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	6,300	-	6,300
Pressure Sewer Service Lines (lf)	6,300	-	6,300

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Atmautluak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30):

Estimated Capital Costs					
Village					
Atmautluak					
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	84	\$26,403.25	\$2,217,873
3	Sewage collection mains or services (gravity or force), above ground	LF	15,800	\$200.95	\$3,174,979
4	Sewage lift station	EA	1	\$678,792.59	\$678,793
10	Sewage lagoon, barrow, local material	Acre	6.8	\$694,724.45	\$4,724,126
12	Water distribution, mains or services, above ground	LF	18,700	\$331.68	\$6,202,500
14	Water storage tank, no foundation	Gal	175,700	\$2.73	\$479,969
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
18	Foundation - freeze back piles	SF	3,620	\$326.71	\$1,182,688
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$20,777,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$24,808,800</b>
27	Individual Grinder Pump Stations	EA	84	\$30,000	\$2,520,000
28	Electrical Service Upgrades	EA	84	\$5,500	\$462,000
<b>Subtotal</b>					<b>\$27,790,800</b>
29	Construction Contingency (15%)	LS	1	\$4,168,600	\$4,168,600
30	Design & Construction Administration Services (20%)	LS	1	\$5,558,200	\$5,558,200
<b>Total</b>					<b>\$37,517,600</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$33,300
Fuel	\$87,100
Electricity	\$33,900
Other (R&R, Training, etc.)	\$18,300
<b>Total</b>	<b>\$179,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Atmautluak are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 144	63	85%	<b>\$ 92,613</b>
Public/Commercial Service	\$ 151	19	100%	<b>\$ 34,503</b>
School Service	\$ 2,882	2	100%	<b>\$ 51,884</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 179,000</b>

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

2/29/2016  
Atmautluak

**Existing Community & System Data**

2015 Population	319
2015 Number of Services	84
HITS Database (E1 & H1-H7)	63
DCED Mapping Commercial/Public Facilities/School	21
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	10000
Water Treatment Capacity	20
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<input checked="" type="checkbox"/>	9450	12400
Gravity Sewer Main		0	
Pressure Sewer Main	<input checked="" type="checkbox"/>	9450	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      **Atmautluak**

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	27		
Req Water Storage (gallons) (less existing)	175,700	2,420	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	6.8		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	3,620	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	12,400	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	9,500	
	Individual Grinder Pump Stations (GPS) (ea)	84	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	6,300	
	Pressure Sewer Service Lines (lf)	6,300	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	27	20	7
Water Storage (gallons)	185,700	10,000	175,700
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	6.8	-	6.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	3,620	-	3,620
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	12,400	-	12,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,500	-	9,500
Individual Grinder Pump Stations (GPS) (ea)	84	-	84
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	6,300	-	6,300
Pressure Sewer Service Lines (lf)	6,300	-	6,300



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	2/29/2016	
Community	Atmautluak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	319 people	2015 ADOL
2015 Number of Services	84 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	389 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	19,462 gpd	50 gallons per Capita
Max Day (MDD)	38,924 gpd	2 x ADD
Peak Hour	81 gpm	3 x MDD
Treatment Capacity	27 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	27 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	10,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	38,924 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	116,772 gallons	3 days x DO
Water Storage Tank Volume	185,696 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	137,888 gallons	CT/RCxPeak Hour/BF
Required Water Storage	185,700 gallons	
Required Additional Storage	175,700 gallons	
Estimate of Min Platform Size (3' clearance around)	2,420 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size check	3.3 acres 308.2	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	6.8 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	6.8 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**


**Village  
Atmautluak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	84	\$26,403.25	\$2,217,873
2	Sewage collection mains or services (gravity or force), buried	LF		#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	15,800	\$200.95	\$3,174,979
4	Sewage lift station	EA	1	\$678,792.59	\$678,793
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	5.2	\$704,910.88	\$3,665,537
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	18,700	\$331.68	\$6,202,500
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	175,700	\$2.73	\$479,969
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	3,620	\$326.71	\$1,182,688
19	Foundation - thermosyphen stabilized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$19,718,648**



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Atmautluak.dwg





# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Atmautluak

### General Community Data

Current population	319 persons
Average number of people per house	5.1
Service Connections	
Number of houses	63
Number of public/commerical buildings	19
Number of schools	2
Total number of service connections	84
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.54 kWh
Electricity cost (Residential service)	\$0.36 kWh
Cost per gallon for heating oil	\$6.50 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	500 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	3248 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	185,700 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	12400 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	84
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	8360 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	1140 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,078 /month	\$8,625.86
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,261 /month	\$10,085.50
Water storage tank	\$183 /month	\$1,467.77
Water storage tank line	\$24 /month	\$189.70
Water mains	\$2,940 /month	\$23,522
Service lines	\$1,494 /month	\$11,951
<u>Wastewater system</u>		
Sewer mains	\$1,982 /month	\$15,859
Service lines	\$1,494 /month	\$11,951
Lift/pump station buildings	\$166 /month	\$1,327.87
Force main to lagoon	\$270 /month	\$2,163
	Subtotal	\$87,100
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$512 /month	\$6,142
HVAC/hydronic system	\$512 /month	\$4,095
Water treatment	\$131 /month	\$1,571
Pumps		
Intake or well	\$131 /month	\$1,571.01
WST circulation	\$73 /month	\$583
Pressure/booster	\$196 /month	\$2,356.52
Main line circulation	\$1,160 /month	\$9,279
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$79 /month	\$946
HVAC/hydronic system	\$79 /month	\$630
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$209 /month	\$2,513.62
Sewer/force main glycol circulation	\$289 /month	\$2,316
Lagoon discharge pump	\$1,886 /year	\$1,886
	Subtotal	\$33,900
<b>Other Costs</b>		
Equipment R&R	\$7,714 /year	\$7,714
Miscellaneous materials & supplies	\$4,628 /year	\$4,628
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,300

## Summary

Administration	\$6,000
Labor	\$33,300
Fuel	\$87,100
Electricity	\$33,900
Other	\$18,300
<b>Total</b>	<b>\$179,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 144	63	85%	\$ 92,613
Public/Commerc	\$ 151.33	19	100%	\$ 34,503
School Service	\$ 2,882.45	2	100%	\$ 51,884
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 179,000</b>

# Beaver, Alaska

## Community Information & Existing Infrastructure

The village of Beaver is a predominately mixed Gwitchin/Koyukuk Athabascan and Inupiat community of 58 people located along the north bank of the Yukon River in north-central Alaska. There are 27 residential units (2 additional units are out of the service area range, and were not included in the model), 13 commercial/public facilities and one school for a total of 41 services. The existing water and sewer services provided in Beaver consist of large truck haul. The existing water and sewer infrastructure consists of the following:

- Well Water – 6-10 gpm transfer pump
- Treated Water Storage – 66,000 gallons
- Water Treatment Plant/Washeteria – 1,708 SF, built in 1978 and refurbished in 1990
- Water Treatment – Filtration, chlorine, and polymer
- Sewage Lagoon – Two Cell, 0.74 acres (too close to the runway to be considered usable)

The area around Beaver consists of permafrost soil conditions. Layer of frozen silts sits between stable sand and gravel layer typically found 6 feet deep.

## Piped System Description

The piped water and sewer system will be a below grade system. The water system will consist of approximately 12,200 feet of pipe, and the sewer system approximately 14,300 feet of pipe. The water system will consist of two circulating loops. The gravity sewer system would require glycol heat treat for freeze protection, and 5 lift stations to collect and transport wastewater to the lagoon. The limitations posed by the runway and the Joe Guay Slough, would likely require the new lagoon to be sited one mile north of the community off the existing road to the landfill. It is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	5	8	-
<b>Water Storage (gallons)</b>	58,300	66,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	1.2	-	1.2
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	12,200	-	12,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,300	-	14,300
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,100	-	3,100
Gravity Sewer Service Lines (lf)	3,100	-	3,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Beaver. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30):

Estimated Capital Costs			Village Beaver		
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	41	\$28,096.69	\$1,151,964
2	Sewage collection mains or services (gravity or force), buried	LF	17,400	\$550.70	\$9,582,112
4	Sewage lift station	EA	5	\$1,037,489.17	\$5,187,446
10	Sewage lagoon, barrow, local material	Acre	1.2	\$1,261,213.17	\$1,513,456
13	Water distribution, mains or services, buried	LF	15,300	\$588.38	\$9,002,171
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
Total Estimated Cost in 2010 dollars (rounded):					<b>\$30,337,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$36,224,000</b>
28	Electrical Service Upgrades	EA	41	\$5,500	\$225,500
Subtotal					<b>\$36,449,500</b>
29	Construction Contingency (15%)	LS	1	\$5,467,400	\$5,467,400
30	Design & Construction Administration Services (20%)	LS	1	\$7,289,900	\$7,289,900
Total					<b>\$49,206,800</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$22,500
Fuel	\$101,600
Electricity	\$41,600
Other (R&R, Training, etc.)	\$19,300
<b>Total</b>	<b>\$191,000</b>




The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Beaver are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 308	27	85%	<b>\$ 84,951</b>
Public/Commercial Service	\$ 324	13	100%	<b>\$ 50,526</b>
School Service	\$ 6,169	1	100%	<b>\$ 55,523</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 191,000</b>



File: J:\Jobsdata\31303.00\_Vsw - Assessment Of Unserved Communities\00\_CADD\01\_Working Set\01\_Civil\31303.00 Beaver.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
BEAVER

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
5



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

3/4/2016  
Beaver

**Existing Community & System Data**

2015 Population	58
2015 Number of Services	41
HITS Database (E1 & H1-H7)	27
DCED Mapping Commercial/Public Facilities/School	14
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	66000
Water Treatment Capacity	8
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	14300	12200
Gravity Sewer Main	x	9000	
Pressure Sewer Main		5300	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
**Beaver**

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	5	
Req Water Storage (gallons) (less existing)	-	- sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	1.2	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	12,200	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	14,300	
	Lift Stations for Gravity Sewer Mains	5	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	3,100	
	Gravity Sewer Service Lines (lf)	3,100	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	5	8	-
Water Storage (gallons)	58,300	66,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.2	-	1.2
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	12,200	-	12,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,300	-	14,300
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,100	-	3,100
Gravity Sewer Service Lines (lf)	3,100	-	3,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		3/4/2016 Beaver	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	58 people	2015 ADOL	
2015 Number of Services	41 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	71 people	Px(1+i)^n	
<b>Water Demand Estimates</b>			
Existing Capacity	8 gpm		
Average Day (ADD)	3,539 gpd	50 gallons per Capita	
Max Day (MDD)	7,077 gpd	2 x ADD	
Peak Hour	15 gpm	3 x MDD	
Treatment Capacity	5 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	5 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	66,000 gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	7,077 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	21,231 gallons	3 days x DO	
Water Storage Tank Volume	58,308 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	LI x (5.057) x (e^(0.0693T))x(e^(0.361PH))x(e^(0.113RC))	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	25,071 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	58,300 gallons		
Required Additional Storage	(7,700) gallons	0	
Estimate of Min Platform Size (3' clearance around)	- sf	D = 0.103xVg^(1/2) H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	6	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Thermosyphon stabilized gravel pad (sf)	Pile Foundation
Firm soils, or continuous permafrost	x		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Circulating Water Main with Pitorifices (lf)	Static Water Mains
Above ground system or buried with permafrost	x		Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Sewer Main with Glycol Heat Trace (lf) Lift Stations for Gravity Sewer Mains(ea)	Bare sewer main, no heat trace
Above ground or buried with permafrost	x		Sewer main with glycol heat trace
Gravity Sewer Main	x		Lift stations for gravity sewer mains
Pressure Sewer Main	0		Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Circulating Water Service Lines (lf) Gravity Sewer Service Lines (lf)	Static Water Service Line
Circulating Water Main	x		Circulating Water Service Lines
Gravity Sewer Main	x		Gravity Service Line
Pressure Sewer Main	0		Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	0.6 acres 131.4	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	1.2 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	1.2 acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Beaver**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	41	\$28,096.69	\$1,151,964
2	Sewage collection mains or services (gravity or force), buried	LF	17,400	\$550.70	\$9,582,112
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	5	\$1,037,489.17	\$5,187,446
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.2	\$1,261,213.17	\$1,513,456
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	15,300	\$588.38	\$9,002,171
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$30,336,742**

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

**Community:** Beaver

### General Community Data

Current population	58 persons
Average number of people per house	2.1
Service Connections	
Number of houses	27
Number of public/commerical buildings	13
Number of schools	1
Total number of service connections	41
Burdened labor rate	\$18 hr
Electricity cost (Public facility)	\$0.54 kWh
Electricity cost (Residential service)	\$0.36 kWh
Cost per gallon for heating oil	\$9.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	335 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

#### Water Treatment

Size of water treatment plant building	2908 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	66,000 gallons
Length of water line to/ from tank	25 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	12200 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	5
Number of facilities served by lift/pump station #1	6
Number of facilities served by lift/pump station #2	19
Number of facilities served by lift/pump station #3	30
Number of facilities served by lift/pump station #4	38
Number of facilities served by lift/pump station #5	41
Number of facilities served by lift/pump station #6	
Size of lift stations	500 sf
Total length of sewer mains	9000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	5300 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$22,464
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,337 /month	\$10,693.25
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$317 /month	\$3,808.51
Water storage tank	\$90 /month	\$722.30
Water storage tank line	\$0 /month	\$0.00
Water mains	\$2,403 /month	\$28,840
Service lines	\$606 /month	\$7,269
<u>Wastewater system</u>		
Sewer mains	\$1,773 /month	\$21,275
Service lines	\$606 /month	\$7,269
Lift/pump station buildings	\$1,149 /month	\$9,192.96
Force main to lagoon	\$1,044 /month	\$12,529
	Subtotal	\$101,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$458 /month	\$5,499
HVAC/hydronic system	\$458 /month	\$5,499
Water treatment	\$24 /month	\$286
Pumps		
Intake or well	\$24 /month	\$285.64
WST circulation	\$73 /month	\$583
Pressure/booster	\$36 /month	\$428.46
Main line circulation	\$1,160 /month	\$13,919
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$394 /month	\$4,728
HVAC/hydronic system	\$394 /month	\$3,152
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$142 /month	\$1,701.14
Sewer/force main glycol circulation	\$434 /month	\$5,210
Lagoon discharge pump	\$343 /year	\$343
	Subtotal	\$41,600
<b>Other Costs</b>		
Equipment R&R	\$8,283 /year	\$8,283
Miscellaneous materials & supplies	\$4,970 /year	\$4,970
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$19,300

## Summary

Administration	\$6,000
Labor	\$22,500
Fuel	\$101,600
Electricity	\$41,600
Other	\$19,300
<b>Total</b>	<b>\$191,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 308	27	85%	\$ 84,951
Public/Commerc	\$ 323.89	13	100%	\$ 50,526
School Service	\$ 6,169.25	1	100%	\$ 55,523
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 191,000</b>



# Birch Creek, Alaska

## Community Information & Existing Infrastructure

The village of Birch Creek is a Dendu Gwichin Athabascan community of 22 people located along the Birch Creek River. There are 18 residential units and 8 commercial/public facilities for a total of 26 services. The existing water and sewer services provided in Birch Creek consist of self-haul system and waste disposal at the sewage lagoon or backyard pit privies. The existing water and sewer infrastructure consists of the following:

- Underneath Birch Creek River – 20 gpm transfer pump
- Treated Water Storage – 80,000 gallons
- Water Treatment Plant/Washeteria – 640 SF, built in 1988
- Water Treatment – Sand filters and chlorination
- Sewage Lagoon – Single Cell, 0.3 acres

Soil investigations in the Birch Creek area revealed a fairly consistent subsurface of frozen soils made up of sandy silt and silty sand with gravel with no groundwater to a depth of approx. 25 feet.

## Piped System Description

The piped water and sewer system will be a below grade system. The water system will consist of approximately 5,700 feet of pipe, and the sewer system approximately 3,800 feet of pipe. The water system will consist of two circulating loops. The gravity sewer system would require glycol heat treat for freeze protection, and two lift stations to collect and transport wastewater to the lagoon. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	2	20	-
<b>Water Storage (gallons)</b>	40,700	80,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	0.5	-	0.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	5,700	-	5,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	3,800	-	3,800
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,000	-	2,000
Gravity Sewer Service Lines (lf)	2,000	-	2,000

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Birch Creek. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30):

Estimated Capital Costs				Village Birch Creek	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	26	\$28,096.69	\$730,514
2	Sewage collection mains or services (gravity or force), buried	LF	5,800	\$636.43	\$3,691,317
4	Sewage lift station	EA	3	\$1,097,461.43	\$3,292,384
10	Sewage lagoon, barrow, local material	Acre	0.5	\$1,841,373.17	\$920,687
13	Water distribution, mains or services, buried	LF	7,700	\$636.50	\$4,901,027
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
Total Estimated Cost in 2010 dollars (rounded):					<b>\$17,436,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$20,819,500</b>
28	Electrical Service Upgrades	EA	26	\$5,500	\$143,000
Subtotal					<b>\$20,962,500</b>
29	Construction Contingency (15%)	LS	1	\$3,144,400	\$3,144,400
30	Design & Construction Administration Services (20%)	LS	1	\$4,192,500	\$4,192,500
Total					<b>\$28,299,400</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$30,900
Electricity	\$33,100
Other (R&R, Training, etc.)	\$13,100
<b>Total</b>	<b>\$108,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Birch Creek are listed below:

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 361	18	85%	\$ 66,361
Public/Commercial Service	\$ 434	8	100%	\$ 41,639
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 108,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Birch Creek.dwg



**LEGEND:**

PROPOSED WATER MAIN	— W —
PROPOSED SEWER/FORCE MAIN	— S —
PROPOSED LIFT STATION	○
EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP	▨
EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP	▩
HOME ADDITION FROM HITS MAP	▧

**CRW**  
ENGINEERING GROUP, LLC

PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF UNSERVED COMMUNITIES BIRCH CREEK		DATE MAR 2015
		SCALE GRAPHIC
		FIGURE 6



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community Input	<div style="text-align: center;">3/5/2016 Birch Creek</div> <div style="border: 1px solid black; height: 15px; width: 100%;"></div>		
<b>Existing Community &amp; System Data</b>			
2015 Population	22		
2015 Number of Services	26		
HITS Database (E1 & H1-H7)	18		
DCED Mapping Commercial/Public Facilities/School	8		
Type (surface water or groundwater)	SW		
Water quality (Poor or Good)	Poor		
Water Storage Tank	80000		
Water Treatment Capacity	20		
Existing Sewage Lagoon Size	0		
<b>Soil Conditions (check only one)</b>			
Soft poorly drained soils or discontinuous permafrost	<input type="checkbox"/>		
Firm soils, or continuous permafrost	<input checked="" type="checkbox"/>		
Stiff soils, no permafrost	<input type="checkbox"/>		
<b>Piping Configurations (check all that apply)</b>			
	<b>Sewer Main Length (ft)</b>	<b>Water Main Length (ft)</b>	
Buried system with no permafrost			
Above ground system or buried with permafrost	x	3750	5700
Gravity Sewer Main	x	3300	
Pressure Sewer Main		450	
Typical Service Line Length (ea)		75	75
<b>Piped System Requirements</b>			
Community	Birch Creek		
Output for Cost Model (calculated)			
	<b>Foundation Size</b>		
Water Treatment Capacity (gpm)	2		
Req Water Storage (gallons) (less existing)	- sf		
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200 sf		
Req Sewage Lagoon Size (acre) (less existing)	0.5		
	Quantity	Notes	
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	5,700	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	3,800	
	Lift Stations for Gravity Sewer Mains	2	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	2,000	
	Gravity Sewer Service Lines (lf)	2,000	
System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	2	20	-
Water Storage (gallons)	40,700	80,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	0.5	-	0.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	5,700	-	5,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	3,800	-	3,800
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,000	-	2,000
Gravity Sewer Service Lines (lf)	2,000	-	2,000

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date Community		
3/5/2016 Birch Creek		
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	22 people	2015 ADOL
2015 Number of Services	26 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	27 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	1,342 gpd	50 gallons per Capita
Max Day (MDD)	2,684 gpd	2 x ADD
Peak Hour	6 gpm	3 x MDD
Treatment Capacity	2 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	2 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	80,000 gallons	
Demand Based Volume (if source is GW)	Check Min CT Requirements	
Daily Operation (DO) (gallons)	2,684 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	8,053 gallons	3 days x DO
Water Storage Tank Volume	40,738 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	9,510 gallons	CT/RCxPeak Hour/BF
Required Water Storage	40,700 gallons	
Required Additional Storage	- gallons	0
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)
Pressure Sewer Main	0	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)
Pressure Sewer Main	0	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size check	0.2 acres 80.9	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	0.5 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	0.5 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Birch Creek**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	26	\$28,096.69	\$730,514
2	Sewage collection mains or services (gravity or force), buried	LF	5,800	\$636.43	\$3,691,317
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	3	\$1,097,461.43	\$3,292,384
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.5	\$1,841,373.17	\$920,687
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	7,700	\$636.50	\$4,901,027
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$17,435,522**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Birch Creek

## General Community Data

Current population	22 persons
Average number of people per house	1.2
Service Connections	
Number of houses	18
Number of public/commerical buildings	8
Number of schools	0
Total number of service connections	26
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.55 kWh
Electricity cost (Residential service)	\$0.40 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	290 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	2340 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	80,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	5700 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	15
Number of facilities served by lift/pump station #2	27
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	3300 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	450 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$717 /month	\$5,736.41
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$80 /month	\$963.07
Water storage tank	\$73 /month	\$583.68
Water storage tank line	\$11 /month	\$87.55
Water mains	\$749 /month	\$8,983
Service lines	\$256 /month	\$3,073
<u>Wastewater system</u>		
Sewer mains	\$433 /month	\$5,201
Service lines	\$256 /month	\$3,073
Lift/pump station buildings	\$306 /month	\$2,451.46
Force main to lagoon	\$59 /month	\$709
	Subtotal	\$30,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$376 /month	\$4,507
HVAC/hydronic system	\$376 /month	\$4,507
Water treatment	\$9 /month	\$110
Pumps		
Intake or well	\$9 /month	\$110.35
WST circulation	\$74 /month	\$594
Pressure/booster	\$14 /month	\$165.53
Main line circulation	\$1,181 /month	\$14,177
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$161 /month	\$1,926
HVAC/hydronic system	\$161 /month	\$1,284
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$26 /month	\$308.99
Sewer/force main glycol circulation	\$442 /month	\$5,306
Lagoon discharge pump	\$132 /year	\$132
	Subtotal	\$33,100
<b>Other Costs</b>		
Equipment R&R	\$4,448 /year	\$4,448
Miscellaneous materials & supplies	\$2,669 /year	\$2,669
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$13,100

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$30,900
Electricity	\$33,100
Other	\$13,100
<b>Total</b>	<b>\$108,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 361	18	85%	\$ 66,361
Public/Commerc	\$ 433.73	8	100%	\$ 41,639
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 108,000</b>

# Chalkyitsik, Alaska

---

## Community Information & Existing Infrastructure

The village of Chalkyitsik is a Gwichin Athabascan community of 77 people located along the Black River. There are 51 residential units, 16 commercial/public facilities and one school for a total of 68 services. The existing water and sewer services provided in Chalkyitsik consist of self-haul water system and honey buckets/outhouses for waste disposal. The water treatment plant (WTP) distributes water from the water storage tank (WST) to the washeteria, community water point, village council building, clinic, and the school's wood-stave WST. The washeteria, WTP, council building, and the clinic discharge wastewater to a lift station under the WTP that is piped to the sewage lagoon. The existing water and sewer infrastructure consists of the following:

- Black River – 15 gpm transfer pump
- Treated Water Storage – 95,000 gallons
- Water Treatment Plant/Washeteria – 2,314 SF, upgraded in 2008
- Water Treatment – Treated with coagulant, filtered, passed through a granulated carbon filter, and chlorinated
- Sewage Lagoon – Two Cell, 1.0 acres

Subsurface conditions in Chalkyitsik typically consist of several feet of organic soils overlying ice-rich silts to depths of 16.5 to 27.5 feet.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The system will consist of approximately 17,100 feet of circulating water mains, and 9,300 feet of pressure sewer mains. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house, glycol heat trace for freeze protection, and one lift station. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. The existing 95,000 gallon water storage tank is sufficient to meet the CT-required volume and provide a reserve for fire flows and/or emergencies.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	7	15	-
Water Storage (gallons)	67,600	95,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.6	1.0	0.6
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon Stabilized Gravel Pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,100	-	17,100
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,300	-	9,300
Individual Grinder Pump Stations (GPS) (ea)	68	-	68
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,100	-	5,100
Pressure Sewer Service Lines (lf)	5,100	-	5,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Chalkyitsik. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30):

Estimated Capital Costs				Village Chalkyitsik	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	68	\$28,096.69	\$1,910,575
3	Sewage collection mains or services (gravity or force), above ground	LF	14,400	\$310.58	\$4,472,295
4	Sewage lift station	EA	1	\$1,397,322.77	\$1,397,323
10	Sewage lagoon, barrow, local material	Acre	0.6	\$1,675,613.17	\$1,005,368
12	Water distribution, mains or services, above ground	LF	22,200	\$425.83	\$9,453,451
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
Total Estimated Cost in 2010 dollars (rounded):					<b>\$22,139,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$26,435,100</b>
27	Individual Grinder Pump Stations	EA	68	\$30,000	\$2,040,000
28	Electrical Service Upgrades	EA	68	\$5,500	\$374,000
<b>Subtotal</b>					<b>\$28,849,100</b>
29	Construction Contingency (15%)	LS	1	\$4,327,400	\$4,327,400
30	Design & Construction Administration Services (20%)	LS	1	\$5,769,800	\$5,769,800
<b>Total</b>					<b>\$38,946,300</b>



The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.


<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$30,000
Fuel	\$95,500
Electricity	\$37,100
Other (R&R, Training, etc.)	\$19,000
<b>Total</b>	<b>\$188,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Chalkyitsik are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 188	51	85%	<b>\$ 97,661</b>
Public/Commercial Service	\$ 207	16	100%	<b>\$ 39,650</b>
School Service	\$ 5,632	1	100%	<b>\$ 50,689</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 188,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Chalkyitsik.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

2/29/2016  
Chalkyitsik

**Existing Community & System Data**

2015 Population	77
2015 Number of Services	68
HITS Database (E1 & H1-H7)	51
DCED Mapping Commercial/Public Facilities/School	17
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	95000
Water Treatment Capacity	15
Existing Sewage Lagoon Size	1

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	9300	17100
Gravity Sewer Main			
Pressure Sewer Main	x	9300	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      Chalkyitsik

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	7	
Req Water Storage (gallons) (less existing)	-	- sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	0.6	

Quantity      Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200
Water Distribution System	Circulating Water Main with Pitorifices (lf)	17,100
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	9,300
	Individual Grinder Pump Stations (GPS) (ea)	68
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	5,100
	Pressure Sewer Service Lines (lf)	5,100

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	7	15	-
Water Storage (gallons)	67,600	95,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.6	1.0	0.6
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,100	-	17,100
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,300	-	9,300
Residential Grinder Pump Stations (GPS) (ea)	68	-	68
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,100	-	5,100
Pressure Sewer Service Lines (lf)	5,100	-	5,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		2/29/2016 Chalkyitsik	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	77 people	2015 ADOL	
2015 Number of Services	68 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	94 people	Px(1+i)^n	
<b>Water Demand Estimates</b>			
Existing Capacity	15 gpm		
Average Day (ADD)	4,698 gpd	50 gallons per Capita	
Max Day (MDD)	9,395 gpd	2 x ADD	
Peak Hour	20 gpm	3 x MDD	
Treatment Capacity	7 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	SW		
Required Capacity	7 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	95,000 gallons		
Demand Based Volume (if source is GW)	Check Min CT Requirements		
Daily Operation (DO) (gallons)	9,395 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	28,186 gallons	3 days x DO	
Water Storage Tank Volume	67,582 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	LI x (5.057) x (e^(0.0693T))x(e^(0.361PH))x(e^(0.113RC))	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	33,283 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	67,600 gallons		
Required Additional Storage	- gallons	0	
Estimate of Min Platform Size (3' clearance around)	- sf	D = 0.103xVg^(1/2) H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Thermosyphon stabilized gravel pad (sf)	Pile Foundation
Firm soils, or continuous permafrost	x		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Circulating Water Main with Pitorifices (lf)	Static Water Mains
Above ground system or buried with permafrost	x		Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Sewer Main with Glycol Heat Trace (lf)	Bare sewer main, no heat trace
Above ground or buried with permafrost	x		Insulated sewer main with glycol heat trace
Gravity Sewer Main	0	Individual Grinder Pump Stations (GPS) (ea)	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x		Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Circulating Water Service Lines (lf)	Static Water Service Line
Circulating Water Main	x		Circulating Water Service Lines
Gravity Sewer Main	0	Pressure Sewer Service Lines (lf)	Gravity Service Line
Pressure Sewer Main	x		Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	1 acres		
Organic Loading Based Size check	0.8 acres 151.4	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	1.6 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	1.6 acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Chalkyitsik**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	68	\$28,096.69	\$1,910,575
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	14,400	\$310.58	\$4,472,295
4	Sewage lift station	EA	1	\$1,397,322.77	\$1,397,323
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.6	\$1,675,613.17	\$1,005,368
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	22,200	\$425.83	\$9,453,451
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$769.95	\$923,935
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$22,138,605**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Chalkyitsik

## General Community Data

Current population	77 persons
Average number of people per house	1.5
Service Connections	
Number of houses	51
Number of public/commerical buildings	16
Number of schools	1
Total number of service connections	68
Burdened labor rate	\$18 hr
Electricity cost (Public facility)	\$0.55 kWh
Electricity cost (Residential service)	\$0.40 kWh
Cost per gallon for heating oil	\$8.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	460 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	3514 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	95,000 gallons
Length of water line to/ from tank	40 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	17100 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	10
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	8700 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	600 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$29,952
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,436 /month	\$11,485.89
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$375 /month	\$4,494.34
Water storage tank	\$116 /month	\$924.16
Water storage tank line	\$12 /month	\$93.39
Water mains	\$2,994 /month	\$35,931
Service lines	\$893 /month	\$10,716
<u>Wastewater system</u>		
Sewer mains	\$1,523 /month	\$18,281
Service lines	\$893 /month	\$10,716
Lift/pump station buildings	\$204 /month	\$1,634.30
Force main to lagoon	\$105 /month	\$1,261
	Subtotal	\$95,500
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$564 /month	\$6,768
HVAC/hydronic system	\$564 /month	\$6,768
Water treatment	\$32 /month	\$386
Pumps		
Intake or well	\$32 /month	\$386.23
WST circulation	\$74 /month	\$594
Pressure/booster	\$48 /month	\$579.35
Main line circulation	\$1,181 /month	\$14,177
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$80 /month	\$963
HVAC/hydronic system	\$80 /month	\$642
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$8 /month	\$90.88
Sewer/force main glycol circulation	\$442 /month	\$5,306
Lagoon discharge pump	\$464 /year	\$464
	Subtotal	\$37,100
<b>Other Costs</b>		
Equipment R&R	\$8,128 /year	\$8,128
Miscellaneous materials & supplies	\$4,877 /year	\$4,877
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$19,000

## Summary

Administration	\$6,000
Labor	\$30,000
Fuel	\$95,500
Electricity	\$37,100
Other	\$19,000
<b>Total</b>	<b>\$188,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 188	51	85%	\$ 97,661
Public/Commerc	\$ 207	16	100%	\$ 39,650
School Service	\$ 5,632	1	100%	\$ 50,689
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 188,000</b>



# Chefornak, Alaska

---

## Community Information & Existing Infrastructure

Chefornak is a Yup'ik Eskimo community of 420 people located on the south bank of the Kinia River, at its junction with the Keguk River, in the Yukon Kuskokwim Delta. There are 83 residential units, 24 commercial/public facilities, and one K-12 school for a total of 108 services. The existing water and sewer services provided in Chefornak consist of a self-haul system from watering points for water and honey buckets for waste disposal. The school has a treatment system, but purchases raw water from the City. There is a piped distribution loop with about 10 watering points throughout the community that provide service to the washeteria, clinic, and school. The existing water and sewer infrastructure consists of the following:

- Well Water – 6 gpm transfer pump
- Treated Water Storage – 4,000 gallons (very poor condition)
- Water Treatment Plant – 768 SF, built in 1984 (very poor condition)
- Water Treatment – Chlorination (water quality is very poor, high in salinity and not consumed by the community, only used for washing/bathing)
- Sewage Lagoon – Two cell, 4.2 acres

The soil section underlying the community generally consists of a matrix of large pumice boulders with organics and/or silt. There is peat 1-2 feet below ground surface, and organic silt up to 3-5 feet below ground surface; typically frozen. Groundwater encountered around 10 feet at one test pit.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 11,900 feet of pipe, and the pressure sewer approximately 8,500 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house in addition to one sewer main lift station, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 2,500 sf facility is included to house the equipment needed for water treatment and distribution equipment. A new well is also proposed.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	36	6	30
Water Storage (gallons)	235,000	-	235,000
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,500	-	2,500
Sewage Lagoon Size (acre)	8.9	4.2	4.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	5,630	-	5,630
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	11,900	-	11,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,000	-	9,000
Individual Grinder Pump Stations (GPS) (ea)	108	-	108
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,100	-	8,100
Pressure Sewer Service Lines (lf)	8,100	-	8,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Chefornak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Chefornak
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	108	\$26,342.77	\$2,845,020
3	Sewage collection mains or services (gravity or force), above ground	LF	17,100	\$196.77	\$3,364,753
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
10	Sewage lagoon, barrow, local material	Acre	4.7	\$702,902.35	\$3,303,641
12	Water distribution, mains or services, above ground	LF	20,000	\$328.15	\$6,563,015
14	Water storage tank, no foundation	Gal	235,000	\$2.45	\$576,884
15	Water treatment plant, no foundation	SF	2,500	\$1,582.62	\$3,956,543
18	Foundation - freeze back piles	SF	5,360	\$299.71	\$1,606,470
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$23,032,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$27,501,400</b>
27	Individual Grinder Pump Stations	EA	108	\$30,000	\$3,240,000
28	Electrical Service Upgrades	EA	108	\$5,500	\$594,000
<b>Subtotal</b>					<b>\$31,335,400</b>
29	Construction Contingency (15%)	LS	1	\$4,700,300	\$4,700,300
30	Design & Construction Administration Services (20%)	LS	1	\$6,267,100	\$6,267,100
<b>Total</b>					<b>\$42,302,800</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.


<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$25,000
Fuel	\$90,900
Electricity	\$30,100
Other (R&R, Training, etc.)	\$17,700
<b>Total</b>	<b>\$170,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Chefornak are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 116	83	85%	<b>\$ 98,307</b>
Public/Commercial Service	\$ 122	24	100%	<b>\$ 35,115</b>
School Service	\$ 4,064	1	100%	<b>\$ 36,578</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 170,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Chefornak.dwg



**LEGEND:**

PROPOSED WATER MAIN	
PROPOSED SEWER/FORCE MAIN	
PROPOSED LIFT STATION	
EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP	
EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP	
HOME ADDITION FROM HITS MAP	

**CRW**  
ENGINEERING GROUP, LLC

PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF UNSERVED COMMUNITIES <b>CHEFORNAK</b>	DATE SEP 2016
	SCALE GRAPHIC
	FIGURE 8



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 9/7/2016  
 Community Chefnak  
 Input

**Existing Community & System Data**

2015 Population	420	
2015 Number of Services	108	
HITS Database (E1 & H1-H7)	83	
DCED Mapping Commerical/Public Facilities/School	25	
Type (surface water or groundwater)	GW	
Water quality (Poor or Good)	Poor	High in salinity
Water Storage Tank	0	Existing tank in poor condition
Water Treatment Capacity	6	
Existing Sewage Lagoon Size	4.2	
<b>Soil Conditions (check only one)</b>		
Soft poorly drained soils or discontinuous permafrost	x	
Firm soils, or continuous permafrost		
Stiff soils, no permafrost		

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	9000	11900
Gravity Sewer Main			
Pressure Sewer Main	x	9000	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Chefnak

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	36	
Req Water Storage (gallons) (less existing)	235,000	3,130 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,500	2,500 sf
Req Sewage Lagoon Size (acre) (less existing)	4.7	

	Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf) 5,630	
Water Distribution System	Circulating Water Main with Pitorifices (lf) 11,900	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf) 9,000 Individual Grinder Pump Stations (GPS) (ea) 108	
Water & Sewer Service Lines	Circulating Water Service Lines (lf) 8,100 Pressure Sewer Service Lines (lf) 8,100	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	36	6	30
Water Storage (gallons)	235,000	-	235,000
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,500	-	2,500
Sewage Lagoon Size (acre)	8.9	4.2	4.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	5,630	-	5,630
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	11,900	-	11,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,000	-	9,000
Individual Grinder Pump Stations (GPS) (ea)	108	-	108
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,100	-	8,100
Pressure Sewer Service Lines (lf)	8,100	-	8,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date 9/7/2016		
Community Chebournak		
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	420 people	2015 ADOL
2015 Number of Services	108 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	512 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	6 gpm	
Average Day (ADD)	25,624 gpd	50 gallons per Capita
Max Day (MDD)	51,248 gpd	2 x ADD
Peak Hour	107 gpm	3 x MDD
Treatment Capacity	36 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	36 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	- gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	51,248 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	153,744 gallons	3 days x DO
Water Storage Tank Volume	234,992 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	181,545 gallons	CT/RCxPeak Hour/BF
Required Water Storage	235,000 gallons	
Required Additional Storage	235,000 gallons	
Estimate of Min Platform Size (3' clearance around)	3,130 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	2,500 sf	Good Water Quality (no treatment other than CL) = 800 sf Existing WTP<800 sf and in poor condition
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Lines
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	4.2 acres	
Organic Loading Based Size	4.4 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	353.6	
Hydraulic Loading Based Size	8.9 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	8.9 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Chefornak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	108	\$26,342.77	\$2,845,020
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	17,100	\$196.77	\$3,364,753
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	4.7	\$702,902.35	\$3,303,641
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	20,000	\$328.15	\$6,563,015
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	235,000	\$2.45	\$576,884
15	Water treatment plant, no foundation	SF	2,500	\$1,582.62	\$3,956,543
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	5,360	\$299.71	\$1,606,470
19	Foundation - thermosyphen stabilized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$23,032,054**



# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Chefornak

### General Community Data

Current population	420 persons
Average number of people per house	5.1
Service Connections	
Number of houses	83
Number of public/commerical buildings	24
Number of schools	1
Total number of service connections	108
Burdened labor rate	\$12 hr
Electricity cost (Public facility)	\$0.47 kWh
Electricity cost (Residential service)	\$0.19 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	2560 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	2500 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	235,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	11900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	108
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	8000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	1000 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$766 /month	\$6,128.64
Raw water line	\$560 /month	\$4,482.66
Raw water heat addition	\$1,532 /month	\$12,257.28
Water storage tank	\$214 /month	\$1,714.56
Water storage tank line	\$11 /month	\$87.55
Water mains	\$2,605 /month	\$20,837
Service lines	\$1,773 /month	\$14,183
<u>Wastewater system</u>		
Sewer mains	\$1,751 /month	\$14,008
Service lines	\$1,773 /month	\$14,183
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to lagoon	\$219 /month	\$1,751
	Subtotal	\$90,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$343 /month	\$4,115
HVAC/hydronic system	\$343 /month	\$2,743
Water treatment	\$150 /month	\$1,800
Pumps		
Intake or well	\$150 /month	\$1,800.29
WST circulation	\$63 /month	\$508
Pressure/booster	\$225 /month	\$2,700.43
Main line circulation	\$1,010 /month	\$8,076
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$69 /month	\$823
HVAC/hydronic system	\$69 /month	\$549
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$234 /month	\$2,811.05
Sewer/force main glycol circulation	\$252 /month	\$2,015
Lagoon discharge pump	\$2,162 /year	\$2,162
	Subtotal	\$30,100
<b>Other Costs</b>		
Equipment R&R	\$7,298 /year	\$7,298
Miscellaneous materials & supplies	\$4,379 /year	\$4,379
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$17,700

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$90,900
Electricity	\$30,100
Other	\$17,700
<b>Total</b>	<b>\$170,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 116	83	85%	\$ 98,307
Public/Commerc	\$ 122	24	100%	\$ 35,115
School Service	\$ 4,064	1	100%	\$ 36,578
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 170,000</b>

# Circle, Alaska

## Community Information & Existing Infrastructure

The village of Circle is an Athabascan community of 119 people located at the terminus of the Steese Highway on the west bank of the Yukon River. There are 38 residential units, 14 commercial/public facilities and one school for a total of 53 services. The existing water services provided in Circle consist of self-haul water system from the washeteria building watering point. The existing sewer service consists of individual septic and leach fields for a few commercial facilities such as the the post office, and clinic. The school and the washeteria discharge into the lagoon through a piped sewer line. Residents without wastewater facilities use outhouses/honey buckets. The existing water and sewer infrastructure consists of the following:

- Well Water – 10 gpm transfer pump
- Treated Water Storage – 3,500 gallons
- Water Treatment Plant/Washeteria – 1,400 SF, built in 1994
- Water Treatment – Addition of chlorine
- School Sewage Lagoon – Single Cell, 0.5 acres

The general soil profile in the area consists of 1-4 feet of organic layer overlaying 6-7 feet of silts and clay, which is underlain by gravel beds. There is discontinuous permafrost in the area.

## Piped System Description

The piped water and sewer system will be a buried system consisting of approximately 34,200 feet of circulating water mains and approximately 18,800 feet of gravity sewer mains. The water system will consist of two circulating loops. The sewer system will require glycol heat trace for freeze protection, and 10 lift stations throughout the system. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 800 sf facility is included to house the equipment needed for additional treatment and water distribution.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	10	10	-
<b>Water Storage (gallons)</b>	88,100	3,500	84,600
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	800	-	800
<b>Sewage Lagoon Size (acre)</b>	2.5	-	2.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon Stabilized Gravel Pad (sf)	2,090	-	2,090
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	34,200	-	34,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	18,800	-	18,800
Lift Stations for Gravity Sewer Mains (ea)	10	-	10
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,000	-	4,000
Gravity Sewer Service Lines (lf)	4,000	-	4,000



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Circle. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30):

Estimated Capital Costs					
Village					
Circle					
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	53	\$26,191.57	\$1,388,153
2	Sewage collection mains or services (gravity or force), buried	LF	22,800	\$352.90	\$8,046,061
4	Sewage lift station	EA	10	\$430,053.92	\$4,300,539
10	Sewage lagoon, barrow, local material	Acre	2.5	\$672,606.85	\$1,681,517
12	Water distribution, mains or services, above ground	LF	38,200	\$316.71	\$12,098,262
14	Water storage tank, no foundation	Gal	84,600	\$2.38	\$201,540
15	Water treatment plant, no foundation	SF	800	\$1,515.91	\$1,212,732
19	Foundation - thermosyphen stabilized gravel pad	SF	2,090	\$207.24	\$433,136
Total Estimated Cost in 2010 dollars (rounded):					<b>\$29,362,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$35,059,800</b>
28	Electrical Service Upgrades	EA	53	\$5,500	\$291,500
<b>Subtotal</b>					<b>\$35,351,300</b>
29	Construction Contingency (15%)	LS	1	\$5,302,700	\$5,302,700
30	Design & Construction Administration Services (20%)	LS	1	\$7,070,300	\$7,070,300
<b>Total</b>					<b>\$47,724,300</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.



Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$99,700
Electricity	\$50,800
Other (R&R, Training, etc.)	\$20,000
<b>Total</b>	<b>\$202,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Circle are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 272	38	85%	<b>\$ 105,235</b>
Public/Commercial Service	\$ 285	14	100%	<b>\$ 47,894</b>
School Service	\$ 5,430	1	100%	<b>\$ 48,871</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 202,000</b>





File: J:\jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Circle.dwg





File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Circle.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
CIRCLE (2 OF 2)

**LEGEND:**

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



PROPOSED LIFT STATION



EXISTING PUBLIC STRUCTURE SHOWN ON  
DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN  
ON DCRA MAP



HOME ADDITION FROM HITS MAP



DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
10



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/4/2016  
 Community Circle  
 Input

**Existing Community & System Data**

2015 Population	119
2015 Number of Services	53
HITS Database (E1 & H1-H7)	38
DCED Mapping Commerical/Public Facilities/School	15
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Good
Water Storage Tank	3500
Water Treatment Capacity	10
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	18800	34200
Gravity Sewer Main	x	18400	
Pressure Sewer Main		400	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Circle

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	10	
Req Water Storage (gallons) (less existing)	84,600	1,290 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	800 sf
Req Sewage Lagoon Size (acre) (less existing)	2.5	

Quantity Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	2,090
Water Distribution System	Circulating Water Main with Pitorifices (lf)	34,200
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	18,800
	Lift Stations for Gravity Sewer Mains (ea)	10
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	4,000
	Gravity Sewer Service Lines (lf)	4,000

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	10	10	0
Water Storage (gallons)	88,100	3,500	84,600
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	-	800
Sewage Lagoon Size (acre)	2.5	-	2.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,090	-	2,090
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	34,200	-	34,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	18,800	-	18,800
Lift Stations for Gravity Sewer Mains (ea)	10	-	10
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,000	-	4,000
Gravity Sewer Service Lines (lf)	4,000	-	4,000

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date 3/4/2016		
Community Circle		
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	119 people	2015 ADOL
2015 Number of Services	53 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	145 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	10 gpm	
Average Day (ADD)	7,260 gpd	50 gallons per Capita
Max Day (MDD)	14,520 gpd	2 x ADD
Peak Hour	30 gpm	3 x MDD
Treatment Capacity	10 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	10 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	3,500 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	14,520 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	43,561 gallons	3 days x DO
Water Storage Tank Volume	88,081 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	51,438 gallons	CT/RCxPeak Hour/BF
Required Water Storage	88,100 gallons	
Required Additional Storage	84,600 gallons	0
Estimate of Min Platform Size (3' clearance around)	1,290 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Good	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	800 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains (ea)
Pressure Sewer Main	0	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)
Pressure Sewer Main	0	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size check	1.2 acres 188.2	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	2.5 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	2.5 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Circle**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	53	\$26,191.57	\$1,388,153
2	Sewage collection mains or services (gravity or force), buried	LF	22,800	\$352.90	\$8,046,061
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	10	\$430,053.92	\$4,300,539
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	2.5	\$672,606.85	\$1,681,517
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	38,200	\$316.71	\$12,098,262
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	84,600	\$2.38	\$201,540
15	Water treatment plant, no foundation	SF	800	\$1,515.91	\$1,212,732
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	2,090	\$207.24	\$433,136
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$29,361,940**

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

**Community:** Circle

### General Community Data

Current population	119	persons
Average number of people per house	3.1	
Service Connections		
Number of houses	38	
Number of public/commerical buildings	14	
Number of schools	1	
Total number of service connections	53	
Burdened labor rate	\$15	hr
Electricity cost (Public facility)	\$0.55	kWh
Electricity cost (Residential service)	\$0.26	kWh
Cost per gallon for heating oil	\$5.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	870 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

#### Water Treatment

Size of water treatment plant building	2200 sf
Raw water quality (Good or Poor)	Good

#### Water Storage

Size of tank(s)	88,100 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	34200 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	10
Number of facilities served by lift/pump station #1	21
Number of facilities served by lift/pump station #2	32
Number of facilities served by lift/pump station #3	38
Number of facilities served by lift/pump station #4	38
Number of facilities served by lift/pump station #5	38
Number of facilities served by lift/pump station #6	38
Number of facilities served by lift/pump station #7	11
Number of facilities served by lift/pump station #8	14
Number of facilities served by lift/pump station #9	14
Number of facilities served by lift/pump station #10	53
Size of lift stations	500 sf
Total length of sewer mains	18400 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	400 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$562 /month	\$4,494.34
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$362 /month	\$4,341.12
Water storage tank	\$67 /month	\$535.65
Water storage tank line	\$9 /month	\$72.96
Water mains	\$3,743 /month	\$44,914
Service lines	\$435 /month	\$5,220
<u>Wastewater system</u>		
Sewer mains	\$2,014 /month	\$24,164
Service lines	\$435 /month	\$5,220
Lift/pump station buildings	\$1,277 /month	\$10,214.40
Force main to lagoon	\$44 /month	\$525
	Subtotal	\$99,700
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$353 /month	\$4,238
HVAC/hydronic system	\$353 /month	\$4,238
Water treatment	\$10 /month	\$119
Pumps		
Intake or well	\$50 /month	\$596.90
WST circulation	\$74 /month	\$594
Pressure/booster	\$75 /month	\$895.36
Main line circulation	\$1,181 /month	\$14,177
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$803 /month	\$9,631
HVAC/hydronic system	\$803 /month	\$6,420
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$467 /month	\$5,598.33
Sewer/force main glycol circulation	\$295 /month	\$3,538
Lagoon discharge pump	\$717 /year	\$717
	Subtotal	\$50,800
<b>Other Costs</b>		
Equipment R&R	\$8,773 /year	\$8,773
Miscellaneous materials & supplies	\$5,264 /year	\$5,264
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$20,000

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$99,700
Electricity	\$50,800
Other	\$20,000
<b>Total</b>	<b>\$202,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 272	38	85%	\$ 105,235
Public/Commerc	\$ 285	14	100%	\$ 47,894
School Service	\$ 5,430	1	100%	\$ 48,871
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 202,000</b>

# Crooked Creek, Alaska

## Community Information & Existing Infrastructure

The village of Crooked Creek is a mixed Yup'ik Eskimo and Athabascan community of 105 people located on the Kuskokwim River at its junction with Crooked Creek in the Kilbuk-Kuskokwim Mountains. The community is spread out over a distance of approximately 2 miles. There are 43 residential units, 10 commercial/public facilities and one school for a total of 54 services. The existing water and sewer service consists primarily of a haul system from the river, and honeybuckets. There is piped water and sewer to the washeteria, school, and clinic. The existing water and sewer infrastructure consists of the following:

- Well Water – 10 gpm transfer pump
- Treated Water Storage – 3,800 gallons
- Water Treatment Plant/Washeteria – 1,200 SF, built in 1998
- Water Treatment – Potassium permanganate, polymer, greensand filter, chlorine, and fluoride
- Sewage Lagoon – Two Cell, 0.5 acres

The general subsurface condition in the area consists of discontinuous permafrost and wetlands.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 20,200 feet of pipe, and the pressure sewer approximately 14,800 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house, glycol heat trace for freeze protection, and 1 lift station throughout the system. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new well and two new 1,200 sf facilities are included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	9	10	-
<b>Water Storage (gallons)</b>	81,200	3,800	77,400
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,400	-	2,400
<b>Sewage Lagoon Size (acre)</b>	2.2	0.5	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	3,600	-	3,600
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	20,200	-	20,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,800	-	14,800
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Crooked Creek. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30):

Estimated Capital Costs				Village Crooked Creek	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$26,403.25	\$1,425,776
2	Sewage collection mains or services (gravity or force), buried	LF	18,900	\$260.13	\$4,916,364
4	Sewage lift station	EA	1	\$762,792.59	\$762,793
10	Sewage lagoon, barrow, local material	Acre	1.7	\$847,406.81	\$1,440,592
13	Water distribution, mains or services, buried	LF	24,300	\$283.67	\$6,893,232
14	Water storage tank, no foundation	Gal	77,400	\$4.66	\$360,897
15	Water treatment plant, no foundation	SF	2,400	\$1,623.65	\$3,896,751
19	Foundation - thermosyphen stabilized gravel pad	SF	3,600	\$276.71	\$996,146
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$20,846,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$24,891,200</b>
27	Individual Grinder Pump Stations	EA	54	\$30,000	\$1,620,000
28	Electrical Service Upgrades	EA	54	\$5,500	\$297,000
<b>Subtotal</b>					<b>\$26,808,200</b>
29	Construction Contingency (15%)	LS	1	\$4,021,200	\$4,021,200
30	Design & Construction Administration Services (20%)	LS	1	\$5,361,600	\$5,361,600
<b>Total</b>					<b>\$36,191,000</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$20,000
Fuel	\$81,800
Electricity	\$57,300
Other (R&R, Training, etc.)	\$18,700
<b>Total</b>	<b>\$184,000</b>

VSW - Unserved Communities Project  
Crooked Creek Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Crooked Creek are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 247	43	85%	<b>\$ 108,384</b>
Public/Commercial Service	\$ 259	10	100%	<b>\$ 31,136</b>
School Service	\$ 4,942	1	100%	<b>\$ 44,480</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 184,000</b>



File: J:\jobdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Crooked Creek.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
CROOKED CREEK

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
11



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/4/2016  
 Community Crooked Creek  
 Input

**Existing Community & System Data**

2015 Population	105
2015 Number of Services	54
HITS Database (E1 & H1-H7)	43
DCED Mapping Commerical/Public Facilities/School	11
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	3800
Water Treatment Capacity	10
Existing Sewage Lagoon Size	0.5

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	14800	20200
Gravity Sewer Main		0	
Pressure Sewer Main	x	14800	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Crooked Creek

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	9	
Req Water Storage (gallons) (less existing)	77,400	1,200 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	2,400 sf
Req Sewage Lagoon Size (acre) (less existing)	1.7	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	3,600	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	20,200	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	14,800	
	Individual Grinder Pump Stations (GPS) (ea)	54	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	4,100	
	Pressure Sewer Service Lines (lf)	4,100	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	10	-
Water Storage (gallons)	81,200	3,800	77,400
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	-	2,400
Sewage Lagoon Size (acre)	2.2	0.5	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	3,600	-	3,600
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	20,200	-	20,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,800	-	14,800
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/4/2016	
Community	Crooked Creek	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	105 people	2015 ADOL
2015 Number of Services	54 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	128 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	10 gpm	
Average Day (ADD)	6,406 gpd	50 gallons per Capita
Max Day (MDD)	12,812 gpd	2 x ADD
Peak Hour	27 gpm	3 x MDD
Treatment Capacity	9 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	9 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	3,800 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	12,812 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	38,436 gallons	3 days x DO
Water Storage Tank Volume	81,248 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	45,386 gallons	CT/RCxPeak Hour/BF
Required Water Storage	81,200 gallons	
Required Additional Storage	77,400 gallons	0
Estimate of Min Platform Size (3' clearance around)	1,200 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	2,400 sf	Good Water Quality (no treatment other than CL) = 800 sf Need two facilities to accommodate both sides of community
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.5 acres	
Organic Loading Based Size	1.1 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	176.8	
Hydraulic Loading Based Size	2.2 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	2.2 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Crooked Creek**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$26,403.25	\$1,425,776
2	Sewage collection mains or services (gravity or force), buried	LF	18,900	\$260.13	\$4,916,364
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	1	\$762,792.59	\$762,793
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.7	\$847,406.81	\$1,440,592
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	24,300	\$283.67	\$6,893,232
14	Water storage tank, no foundation	Gal	77,400	\$4.66	\$360,897
15	Water treatment plant, no foundation	SF	2,400	\$1,623.65	\$3,896,751
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	3,600	\$276.71	\$996,146
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$20,846,148**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Crooked Creek

## General Community Data

Current population	105 persons
Average number of people per house	2.4
Service Connections	
Number of houses	43
Number of public/commerical buildings	10
Number of schools	1
Total number of service connections	54
Burdened labor rate	\$12 hr
Electricity cost (Public facility)	\$0.85 kWh
Electricity cost (Residential service)	\$0.35 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	200 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	3600 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	81,200 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	20200 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	54
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Size of lift stations	500 sf
Total length of sewer mains	14600 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	200 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$19,968
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,103 /month	\$8,825.24
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$383 /month	\$3,064.32
Water storage tank	\$74 /month	\$592.44
Water storage tank line	\$13 /month	\$157.59
Water mains	\$2,653 /month	\$31,834
Service lines	\$532 /month	\$6,383
<u>Wastewater system</u>		
Sewer mains	\$1,917 /month	\$23,009
Service lines	\$532 /month	\$6,383
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to lagoon	\$26 /month	\$315
	Subtotal	\$81,800
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$893 /month	\$10,716
HVAC/hydronic system	\$893 /month	\$10,716
Water treatment	\$68 /month	\$814
Pumps		
Intake or well	\$68 /month	\$813.96
WST circulation	\$115 /month	\$918
Pressure/booster	\$102 /month	\$1,220.94
Main line circulation	\$1,826 /month	\$21,910
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$124 /month	\$1,488
HVAC/hydronic system	\$124 /month	\$992
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$102 /month	\$1,226.62
Sewer/force main glycol circulation	\$456 /month	\$5,467
Lagoon discharge pump	\$977 /year	\$977
	Subtotal	\$57,300
<b>Other Costs</b>		
Equipment R&R	\$7,953 /year	\$7,953
Miscellaneous materials & supplies	\$4,772 /year	\$4,772
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,700

## Summary

Administration	\$6,000
Labor	\$20,000
Fuel	\$81,800
Electricity	\$57,300
Other	\$18,700
<b>Total</b>	<b>\$184,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 247	43	85%	\$ 108,384
Public/Commerc	\$ 259	10	100%	\$ 31,136
School Service	\$ 4,942	1	100%	\$ 44,480
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 184,000</b>

# Deering, Alaska

---

## Community Information & Existing Infrastructure

The City of Deering is an Inupiaq community of 152 people located on Kotzebue Sound at the mouth of the Inmachuk River. There are 68 residential units and 9 commercial/public facilities and one K-12 school for a total of 78 services. The existing water service provided in Deering consists of self-haul system from the central watering point located at the washeteria. The community operates a vacuum sewer collection system hooked up to the existing homes. Only the washeteria, health clinic, and school are served with piped water service. The existing water and sewer infrastructure consists of the following:

- Inmachuk River – 30 gpm (Seasonal)
- Treated Water Storage – 21,000 gallons
- Raw Water Storage – 425,000 & 440,000 gallons
- Community-wide buried vacuum sewer collection system
- Water Treatment Plant – 1,500 SF, built in 1993, Renovated between 1993-2002
- Water Treatment – Pressure sand filtration & chlorination
- Sewage Lagoon – Single Cell, 1.7 acres

Deering is built on a flat sand and gravel spit approximately 300 feet wide and a half-mile long. The terrain upstream of the community consists of treeless tundra.

## Piped System Description

The piped water system will consist of approximately 9,500 feet of buried pipe in two circulating loops. The existing vacuum sewer system is old but reportedly in good condition. Service lines have had minimal issues with failed heat tapes and will not be replaced. As the mains are glycol traced, it is recommended that new vacuum sewer system service lines with glycol heat trace lines are installed. Based on average per capita water consumption of 50 gallons per person per day, the existing water storage capacity would need to be increased to provide sufficient water year round. Approximately 2.8 million gallons of raw water in addition to the treated water would need to be stored during the operation of the seasonal water source to provide water for the piped system when the source is non-producing. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	13	30	-
Raw Water Storage (gallons)	2,800,000	865,000	1,935,000
Treated Water Storage (gallons)	104,200	21,000	83,200
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	3.2	1.7	1.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon Stabilized Gravel Pad	24,400	-	24,400
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,500	-	9,500

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Deering. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs					
Village					
Deering					
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	78	\$22,235.73	\$1,734,387
10	Sewage lagoon, barrow, local material	Acre	1.5	\$787,792.89	\$1,181,689
13	Water distribution, mains or services, buried	LF	9,500	\$269.86	\$2,563,693
14	Water storage tank, no foundation	Gal	2,018,200	\$1.80	\$3,625,138
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
19	Foundation - thermosyphen stabilized gravel pad	SF	24,400	\$159.13	\$3,882,806
Total Estimated Cost in 2010 dollars (rounded):					<b>\$14,747,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$17,608,700</b>
28	Electrical Service Upgrades	EA	78	\$5,500	\$429,000
<b>Subtotal</b>					<b>\$18,037,700</b>
29	Construction Contingency (15%)	LS	1	\$2,705,700	\$2,705,700
30	Design & Construction Administration Services (20%)	LS	1	\$3,607,500	\$3,607,500
<b>Total</b>					<b>\$24,350,900</b>



The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment. The O&M cost for the existing vacuum sewer system was provided by the City of Deering.

<b>Estimated O&amp;M Costs</b>			
<b>Description</b>	<b>Cost</b>	<b>Existing Vacuum Sewer O&amp;M</b>	<b>Water + Vacuum Sewer O&amp;M</b>
Administration	\$6,000	\$10,000	\$16,000
Labor	\$33,300	\$0	\$33,300
Fuel	\$57,800	\$10,000	\$67,800
Electricity	\$36,600	\$12,000	\$48,600
Other (R&R, Training, etc.)	\$16,200	\$3,200	\$19,400
<b>Total</b>			<b>\$185,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Deering are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 158	68	85%	\$ 109,616
Public/Commercial Service	\$ 237	9	100%	\$ 25,602
School Service	\$ 5,531	1	100%	\$ 49,782
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 185,000</b>

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 9/6/2016  
 Community Deering  
 Input

**Existing Community & System Data**

2015 Population	152
2015 Number of Services	78
HITS Database (E1 & H1-H7)	68
DCED Mapping Commerical/Public Facilities/School	10
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	886000
Water Treatment Capacity	30
Existing Sewage Lagoon Size	1.7

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x		9467
Gravity Sewer Main			
Pressure Sewer Main			
Typical Service Line Length (ea)		0	0

**Piped System Requirements**

Community Deering

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	13	
Req Water Storage (gallons) (less existing)	2,018,200	23,200 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	1.5	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	9,500	
Wastewater Collection System			
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	-	
	Vaccum Sewer Service Lines (lf)	-	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	13	30	-
Raw Water Storage (gallons)	2,800,000	865,000	1,935,000
Treated Water Storage (gallons)	104,200	21,000	83,200
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	3.2	1.7	1.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	24,400	-	24,400
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,500	-	9,500

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	9/6/2016	
Community	Deering	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	152 people	2015 ADOL
2015 Number of Services	78 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	185 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	30 gpm	
Average Day (ADD)	9,273 gpd	50 gallons per Capita
Max Day (MDD)	18,547 gpd	2 x ADD
Peak Hour	39 gpm	3 x MDD
Treatment Capacity	13 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	13 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	886,000 gallons	
<u>Demand Based Volume (if source is SW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	18,547 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	55,641 gallons	3 days x DO
Water Storage Tank Volume	104,188 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	65,702 gallons	CT/RCxPeak Hour/BF
Required Water Storage	104,200 gallons	
Required Additional Storage	2,018,200 gallons	0
Estimate of Min Platform Size (3' clearance around)	23,200 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon
Stiff soils, no permafrost	0	Thermosyphon stabilized gravel pad Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (If)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (If)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (If)
Gravity Sewer Main	0	Gravity Service Line
Vacuum Sewer Main	x	Vacuum Sewer Service Lines (If)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	1.7 acres	
Organic Loading Based Size check	1.6 acres 212.7	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	3.2 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	3.2 acres	Either organic loading based or hydraulic, whichever is greater



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Deering**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	78	\$22,235.73	\$1,734,387
2	Sewage collection mains or services (gravity or vacuum), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.5	\$787,792.89	\$1,181,689
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	9,500	\$269.86	\$2,563,693
14	Water storage tank, no foundation	Gal	2,018,200	\$1.80	\$3,625,138
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	24,400	\$159.13	\$3,882,806
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$14,746,580**

# O&M Cost Estimate Piped Water & Sewer System

9/6/2016

**Community:** Deering

## General Community Data

Current population	152 persons
Average number of people per house	2.2
Service Connections	
Number of houses	68
Number of public/commerical buildings	9
Number of schools	1
Total number of service connections	78
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.70 kWh
Electricity cost (Residential service)	\$0.45 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	11275 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	2700 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	2,904,200 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	9500 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Used O&M cost for existing vacuum sewer.
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	
Total length of sewer mains	
Sewer mains heated for freeze protection (Yes or No)	
Number of circulating glycol loops	
Location of the mains (Above ground (AG) or Buried)	
Average service line length	

### Wastewater Treatment / Disposal

Length of force main	750 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Septic system discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/6/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/6/2016

## Estimated O&M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$827 /month	\$6,618.93
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$554 /month	\$4,435.97
Water storage tank	\$2,649 /month	\$21,189.04
Water storage tank line	\$13 /month	\$157.59
Water mains	\$1,248 /month	\$14,971
Service lines	\$768 /month	\$9,219
<u>Wastewater system</u>		
Sewer mains	\$0 /month	\$0
Service lines	\$0 /month	\$0
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$98 /month	\$1,182
	Subtotal	\$57,800
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$552 /month	\$6,619
HVAC/hydronic system	\$552 /month	\$6,619
Water treatment	\$81 /month	\$970
Pumps		
Intake or well	\$81 /month	\$970.37
WST circulation	\$95 /month	\$756
Pressure/booster	\$121 /month	\$1,455.55
Main line circulation	\$1,504 /month	\$18,043
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$0 /month	\$0
Lagoon discharge pump	\$1,165 /year	\$1,165
	Subtotal	\$36,600
<b>Other Costs</b>		
Equipment R&R	\$6,384 /year	\$6,384
Miscellaneous materials & supplies	\$3,830 /year	\$3,830
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$16,200

<b>Summary</b>		<b>Existing Vacuum Sewer</b>	<b>Total W+S</b>
Administration	\$6,000	\$10,000	\$16,000
Labor	\$33,300	\$0	\$33,300
Fuel	\$57,800	\$10,000	\$67,800
Electricity	\$36,600	\$12,000	\$48,600
Other	\$16,200	\$3,200	\$19,400
		Total	\$185,000

<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 158	68	85%	\$ 109,616
Public/Commercial	\$ 237.06	9	100%	\$ 25,602
School Service <sup>(3)</sup>	\$ 5,531.35	1	100%	\$ 49,782
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 185,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Deering.dwg





# Diomedé, Alaska

## Community Information & Existing Infrastructure

The community of Diomedé is an Ingalikmiut Eskimo community of 111 people located on the west coast of Little Diomedé Island in the Bering Straits, 135 miles northwest of Nome. There are 41 residential units, 9 commercial/public facilities, one elementary school, and one high school for a total of 52 services. The existing water service provided in Diomedé consists of a self-haul system from the water storage tank. Gray water is disposed of onto the ground, and black water is disposed of onto the sea ice or thrown into the ocean. There is a piped utilidor system that provides water services to the washeteria/clinic and the school. The existing water and sewer infrastructure consists of the following:

- Seasonal Runoff Stream – 5 gpm
- Treated Water Storage – 424,000 gallons
- Water Treatment Plant Building –600 SF, built in 1992
- Water Treatment – Carbon filter, pH neutralization filter, bag filters, and chlorine (Not potable)
- Sewage Lagoon – None

Little Diomedé Island is a mass of boulders, covered in light gray granite. There is black, sandy gravel with coarser gravel above bedrock near the shore up to 13-feet thick.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 2,400 feet of pipe, and the sewer system approximately 1,000 feet of gravity and pressure pipe. The water system will consist of a single circulating loop. The sewer system including the force main will require one sewer main lift station and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet water pipe and 100 feet of gravity sewer pipe would be required for each service. Upgrades to the existing seasonal water source will be needed to provide adequate flow for a piped system. A 2012 study indicated that improvements could be made to achieve 50 gpm on a seasonal basis (~60 days per year). Approximately 2 million gallons of raw water would need to be stored during the operation of the seasonal water source to provide water for the piped system when the source is non-producing. The existing 424,000 gallon water storage tank is sufficient for storing treated water and meeting the systems CT requirements. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The sewage treatment system would consist of construction of septic tanks, and a primary outfall. As evaluated in a 2012 Master Plan by CRW Engineering Group, the system would be installed in place of the existing septic tanks that serve the washeteria and clinic. The 2012 study assumed a community water demand of 18 gpcd and sized the facility accordingly. For this assessment, the system has been increased to accommodate a community water use of 50 gpcd.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	5	4
New Water Source (gpm)	50	-	50
Raw Water Storage (gallons)	2,000,000	-	2,000,000
Treated Water Storage (gallons)	84,200	424,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Septic Tank System (gallons)	30,000	-	30,000
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,200	-	1,200
Conventional, Local Gravel Material	23,000	-	23,000
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	2,400	-	2,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	1,000	-	1,000
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,900	-	3,900
Gravity Sewer Service Lines (lf)	5,200	-	5,200

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Diomedes. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 23.1 & 28-30).

VSW - Unserved Communities Project  
Diomedes Piped Water & Sewer Assessment

Estimated Capital Costs				Village	
				Little Diomedes	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	52	\$22,235.73	\$1,156,258
3	Sewage collection mains or services (gravity or force), above ground	LF	6,200	\$202.72	\$1,256,855
4	Sewage lift station	EA	1	\$ 722,316.38	\$ 722,316
7	Septic tank, community	EA	2	\$311,494.26	\$622,989
12	Water distribution, mains or services, above ground	LF	6,300	\$302.61	\$1,906,414
14	Water storage tank, no foundation	Gal	2,000,000	\$1.80	\$3,594,426
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
17	Foundation - conventional, local gravel material	SF	23,000	\$183.21	\$4,213,790
18	Foundation - freeze back piles	SF	1,200	\$442.34	\$530,809
Total Estimated Cost in 2010 dollars (rounded):					<b>\$15,763,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$18,821,800</b>
23.1	Upgrade Seasonal Stream Intake*	EA	1	\$336,000	\$336,000
28	Electrical Service Upgrades	EA	52	\$5,500	\$286,000
<b>Subtotal</b>					<b>\$19,443,800</b>
29	Construction Contingency (15%)	LS	1	\$2,916,600	\$2,916,600
30	Design & Construction Administration Services (20%)	LS	1	\$3,888,800	\$3,888,800
<b>Total</b>					<b>\$26,249,200</b>

\* From 2012 water and sewer master plan by CRW. Adjusted for inflation.

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$33,300
Fuel	\$59,300
Electricity	\$18,400
Other (R&R, Training, etc.)	\$14,900
<b>Total</b>	<b>\$132,000</b>



The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Diomedes are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 181	41	85%	<b>\$ 75,661</b>
Public/Commercial Service	\$ 190	9	100%	<b>\$ 20,516</b>
School Service	\$ 1,990	2	100%	<b>\$ 35,822</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 132,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Diomedes.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/29/2016  
 Community Diomedes  
 Input

**Existing Community & System Data**

2015 Population	111
2015 Number of Services	52
HITS Database (E1 & H1-H7)	41
DCED Mapping Commercial/Public Facilities/School	11
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	424000
Water Treatment Capacity	5
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	1000	2374
Gravity Sewer Main			
Pressure Sewer Main	x	1000	
Typical Service Line Length (ea)		100	75

**Piped System Requirements**

Community Diomedes

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	9		
Req Water Storage (gallons) (less existing)	2,000,000	23,000	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	SEPTIC TANKS		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	2,400	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	1,000	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	3,900	
	Gravity Sewer Service Lines (lf)	5,200	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	5	4
New Water Source (gpm)	50	-	50
Raw Water Storage (gallons)	2,000,000	-	2,000,000
Treated Water Storage (gallons)	84,200	424,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Septic Tank System (gallons)	30,000	-	30,000
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,200	-	1,200
Conventional, Local Gravel Material	23,000	-	23,000
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	2,400	-	2,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	1,000	-	1,000
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,900	-	3,900
Gravity Sewer Service Lines (lf)	5,200	-	5,200

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		3/29/2016 Diomedes	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	111 people	2015 ADOL	
2015 Number of Services	52 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	135 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	5 gpm		
Average Day (ADD)	6,772 gpd	50 gallons per Capita	
Max Day (MDD)	13,544 gpd	2 x ADD	
Peak Hour	28 gpm	3 x MDD	
Treatment Capacity	9 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	SW		
Required Capacity	9 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	424,000 gallons		
Demand Based Volume (if source is GW)	Check Min CT Requirements		
Daily Operation (DO) (gallons)	13,544 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	40,632 gallons	3 days x DO	
Water Storage Tank Volume	84,176 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-(0.0693T)}) \times (e^{(0.361PH)}) \times (e^{(0.113RC)})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	47,980 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	84,200 gallons		
Required Additional Storage	2,000,000 gallons	0	
Estimate of Min Platform Size (3' clearance around)	23,000 sf	$D = 0.103 \times Vg^{(1/2)}$ H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)	Pile Foundation
Firm soils, or continuous permafrost	0		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0		Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitoriffices (lf)	Circulating Water Main with Pitoriffices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0		Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	0		Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0		Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	0		Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>	NOT SUITABLE FOR DIOMEDE. SEPTIC TANKS ARE PROPOSED.		
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	0.0 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
	0.0		
Hydraulic Loading Based Size	0.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	- acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Little Diomed**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	52	\$22,235.73	\$1,156,258
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	6,200	\$202.72	\$1,256,855
4	Sewage lift station	EA	1	\$722,316.38	\$722,316
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	2	\$311,494.26	\$622,989
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	6,300	\$302.61	\$1,906,414
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	2,000,000	\$1.80	\$3,594,426
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	23,000	\$183.21	\$4,213,790
18	Foundation - freeze back piles	SF	1,200	\$442.34	\$530,809
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$15,762,724**

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

**Community:** Diomede

### General Community Data

Current population	111 persons
Average number of people per house	2.7
Service Connections	
Number of houses	41
Number of public/commerical buildings	9
Number of schools	2
Total number of service connections	52
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.46 kWh
Electricity cost (Residential service)	\$0.14 kWh
Cost per gallon for heating oil	\$7.32 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	1237 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	1800 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	2,424,000 gallons
Length of water line to/ from tank	800 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	1600 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	47
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	1000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	100 ft

#### Wastewater Treatment / Disposal

Length of force main	100 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Septic Tanks discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$673 /month	\$5,383.40
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$494 /month	\$3,952.10
Water storage tank	\$2,697 /month	\$21,576.31
Water storage tank line	\$214 /month	\$1,709.02
Water mains	\$427 /month	\$3,418
Service lines	\$1,041 /month	\$8,331
<u>Wastewater system</u>		
Sewer mains	\$267 /month	\$2,136
Service lines	\$1,389 /month	\$11,109
Lift/pump station buildings	\$187 /month	\$1,495.39
Force main to lagoon	\$27 /month	\$214
	Subtotal	\$59,300
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$242 /month	\$2,900
HVAC/hydronic system	\$242 /month	\$1,933
Water treatment	\$39 /month	\$466
Pumps		
Intake or well	\$39 /month	\$465.67
WST circulation	\$62 /month	\$497
Pressure/booster	\$58 /month	\$698.50
Main line circulation	\$988 /month	\$7,905
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$67 /month	\$805
HVAC/hydronic system	\$67 /month	\$537
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$53 /month	\$640.58
Sewer/force main glycol circulation	\$123 /month	\$986
Lagoon discharge pump	\$559 /year	\$559
	Subtotal	\$18,400
<b>Other Costs</b>		
Equipment R&R	\$5,549 /year	\$5,549
Miscellaneous materials & supplies	\$3,329 /year	\$3,329
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$14,900

## Summary

Administration	\$6,000
Labor	\$33,300
Fuel	\$59,300
Electricity	\$18,400
Other	\$14,900
<b>Total</b>	<b>\$132,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 181	41	85%	\$ 75,661
Public/Commerc	\$ 189.97	9	100%	\$ 20,516
School Service	\$ 1,990.13	2	100%	\$ 35,822
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 132,000</b>



# Eagle City, Alaska

## Community Information & Existing Infrastructure

Eagle City is a traditional Han Kutchin Indian community of 81 people located on the left bank of the Yukon River at the mouth of Mission Creek, on the Taylor Highway. There are 41 residential units, 12 commercial/public facilities, and one school for a total of 54 services. The existing water service provided in Eagle City consists of a self-haul system and septic systems/outhouses for wastewater disposal. The existing water and sewer infrastructure consists of the following:

- Well – 12 gpm
- Treated Water Storage – 87 gallons
- Well house – 196 SF, built in 1905
- Water Treatment – Filters, UV disinfection
- Sewage Lagoon – None

Soil in the area consists of 1-3 inches of organic mat with 2-3 feet of a silt layer underneath. No permafrost encountered but lenses are known to exist in the area.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 16,400 feet of pipe, and the pressure sewer system approximately 14,900 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system will require individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	6	12	-
<b>Water Storage (gallons)</b>	69,500	87	69,413
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	1.7	-	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,300	-	2,300
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	16,400	-	16,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,900	-	14,900
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Eagle City. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village
					Eagle
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$26,191.57	\$1,414,345
3	Sewage collection mains or services (gravity or force), above ground	LF	19,000	\$183.70	\$3,490,342
10	Sewage lagoon, barrow, local material	Acre	1.7	\$688,671.60	\$1,170,742
12	Water distribution, mains or services, above ground	LF	20,500	\$317.45	\$6,507,780
14	Water storage tank, no foundation	Gal	69,413	\$2.54	\$176,378
15	Water treatment plant, no foundation	SF	1,200	\$1,507.42	\$1,808,905
19	Foundation - thermosyphen stablized gravel pad	SF	2,300	\$202.08	\$464,773
Total Estimated Cost in 2010 dollars (rounded):					<b>\$15,033,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$17,950,200</b>
27	Individual Grinder Pump Stations	EA	54	\$30,000	\$1,620,000
28	Electrical Service Upgrades	EA	54	\$5,500	\$297,000
Subtotal					<b>\$19,867,200</b>
29	Construction Contingency (15%)	LS	1	\$2,980,100	\$2,980,100
30	Design & Construction Administration Services (20%)	LS	1	\$3,973,400	\$3,973,400
Total					<b>\$26,820,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$63,400
Electricity	\$16,100
Other (R&R, Training, etc.)	\$14,400
<b>Total</b>	<b>\$125,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Eagle City are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 152	41	85%	\$ 63,502
Public/Commercial Service	\$ 190	12	100%	\$ 27,332
School Service	\$ 3,796	1	100%	\$ 34,165
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 125,000</b>

File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Eagle.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/21/2016  
Community Eagle City  
Input

**Existing Community & System Data**

2015 Population	81
2015 Number of Services	54
DCCED Community Housing Info	41
DCED Mapping Commerical/Public Facilities/School	13
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	87
Water Treatment Capacity	12
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	14900	16400
Gravity Sewer Main			
Pressure Sewer Main	x	14900	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Eagle City

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	7	
Req Water Storage (gallons) (less existing)	69,413	1,100 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	1.7	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	16,400	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	14,900	
	Individual Grinder Pump Stations (GPS) (ea)	54	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	4,100	
	Pressure Sewer Service Lines (lf)	4,100	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	7	12	-
Water Storage (gallons)	69,500	87	69,413
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.7	-	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,300	-	2,300
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	16,400	-	16,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,900	-	14,900
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/21/2016	
Community	Eagle City	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	81 people	2015 ADOL
2015 Number of Services	54 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	99 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	12 gpm	
Average Day (ADD)	4,942 gpd	50 gallons per Capita
Max Day (MDD)	9,884 gpd	2 x ADD
Peak Hour	21 gpm	3 x MDD
Treatment Capacity	7 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	7 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	87 gallons	
<u>Demand Based Volume (if source is GW)</u>	Applicable	
Daily Operation (DO) (gallons)	9,884 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	29,651 gallons	3 days x DO
Water Storage Tank Volume	69,534 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	35,012 gallons	CT/RCxPeak Hour/BF
Required Water Storage	69,500 gallons	
Required Additional Storage	69,413 gallons	0
Estimate of Min Platform Size (3' clearance around)	1,100 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon
Stiff soils, no permafrost	0	Thermosyphon stabilized gravel pad Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size	0.8 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	155.3	
Hydraulic Loading Based Size	1.7 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	1.7 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Eagle Village**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$26,191.57	\$1,414,345
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	19,000	\$183.70	\$3,490,342
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.7	\$688,671.60	\$1,170,742
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	20,500	\$317.45	\$6,507,780
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	69,413	\$2.54	\$176,378
15	Water treatment plant, no foundation	SF	1,200	\$1,507.42	\$1,808,905
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	2,300	\$202.08	\$464,773
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$15,033,265**

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

**Community:** Eagle City

## General Community Data

Current population	81 persons
Average number of people per house	2.0
Service Connections	
Number of houses	41
Number of public/commerical buildings	12
Number of schools	1
Total number of service connections	54
Burdened labor rate	\$15 hr
Electricity cost (Public facility)	\$0.48 kWh
Electricity cost (Residential service)	\$0.24 kWh
Cost per gallon for heating oil	\$5.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	1396 sf
Raw water quality (Good or Poor)	Good

### Water Storage

Size of tank(s)	69,500 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	16400 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	14900 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	444 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$356 /month	\$2,851.86
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$246 /month	\$1,969.92
Water storage tank	\$53 /month	\$422.56
Water storage tank line	\$0 /month	\$0.00
Water mains	\$2,991 /month	\$23,931
Service lines	\$739 /month	\$5,910
<u>Wastewater system</u>		
Sewer mains	\$2,718 /month	\$21,742
Service lines	\$739 /month	\$5,910
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$81 /month	\$648
	Subtotal	\$63,400
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$196 /month	\$2,347
HVAC/hydronic system	\$196 /month	\$1,564
Water treatment	\$6 /month	\$71
Pumps		
Intake or well	\$30 /month	\$354.59
WST circulation	\$65 /month	\$518
Pressure/booster	\$44 /month	\$531.88
Main line circulation	\$1,031 /month	\$8,248
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$257 /month	\$2,058
Lagoon discharge pump	\$426 /year	\$426
	Subtotal	\$16,100
<b>Other Costs</b>		
Equipment R&R	\$5,223 /year	\$5,223
Miscellaneous materials & supplies	\$3,134 /year	\$3,134
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$14,400

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$63,400
Electricity	\$16,100
Other	\$14,400
<b>Total</b>	<b>\$125,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 152	41	85%	\$ 63,502
Public/Commerc	\$ 189.81	12	100%	\$ 27,332
School Service	\$ 3,796.16	1	100%	\$ 34,165
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 125,000</b>

## Kipnuk, Alaska

### Community Information & Existing Infrastructure

The Community of Kipnuk is a Yupik community of 643 people located on the west bank of Kugkaklik River in the Yukon-Kuskokwim Delta. There are 157 residential units, 31 commercial/public facilities and one school for a total of 189 services. The existing water and sewer services provided in Kipnuk consist of self-haul from the central watering point attached to the water treatment plant and honey buckets. Raw water is pumped from the reservoir to the WTP through a 4-inch arctic pipe. The raw water reservoir is replenished by a combination of surface water runoff, rain, and snow. The fish plant, clinic, and triplex housing have cowater haul systems installed. The school and the water treatment plant have piped water and sewer. The existing water and sewer infrastructure consists of the following:

- Raw Water Reservoir – 17.5 million gallons
- WTP Treatment Capacity – 40 gpm
- Two Water Storage Tanks – 212,000 gallons & 100,000 gallons
- Water Treatment Plant/Washeteria – 8,000 SF, built in 2012
- Water Treatment – Calcium chlorite, potassium permanganate, soda ash
- Sewage Lagoon – Four Cell, 7.14 acres

Soils around Kipnuk were observed to be marginally frozen soil and unfrozen soil; inorganic silt observed to be medium stiff and silty fine sand/fine sand observed to be medium dense.

### Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 20,900 feet of pipe, and the pressure sewer system approximately 16,300 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require one sewer main lift station, individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. The existing water storage tank is sufficient to meet CT requirements (278,000 gallons) and provide a small reserve for fire flows.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

### Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	54	40	14
<b>Water Storage (gallons)</b>	343,800	312,000	31,800
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	13.7	7.1	6.6
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,760	-	1,760
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	20,900	-	20,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	16,300	-	16,300
Individual Grinder Pump Stations (GPS) (ea)	189	-	189
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	14,200	-	14,200
Pressure Sewer Service Lines (lf)	14,200	-	14,200

### Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Kipnuk. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village	
				Kipnuk	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	189	\$26,342.77	\$4,978,784
3	Sewage collection mains or services (gravity or force), above ground	LF	30,500	\$194.04	\$5,918,082
4	Sewage lift station	EA	1	\$ 662,130.80	\$ 662,131
10	Sewage lagoon, barrow, local material	Acre	7	\$689,113.57	\$4,548,150
12	Water distribution, mains or services, above ground	LF	35,100	\$326.34	\$11,454,672
14	Water storage tank, no foundation	Gal	43,800	\$5.41	\$236,919
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
18	Foundation - freeze back piles	SF	1,760	\$374.51	\$659,140
22	Water source - surface water intake	EA	1	\$444,987.75	\$444,988
Total Estimated Cost in 2010 dollars (rounded):					<b>\$30,833,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$36,816,200</b>
27	Individual Grinder Pump Stations	EA	189	\$30,000	\$5,670,000
28	Electrical Service Upgrades	EA	189	\$5,500	\$1,039,500
<b>Subtotal</b>					<b>\$43,525,700</b>
29	Construction Contingency (15%)	LS	1	\$6,528,900	\$6,528,900
30	Design & Construction Administration Services (20%)	LS	1	\$8,705,100	\$8,705,100
<b>Total</b>					<b>\$58,759,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$27,000
Fuel	\$143,900
Electricity	\$45,000
Other (R&R, Training, etc.)	\$23,300
<b>Total</b>	<b>\$245,000</b>



The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Kipnuk are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Custom ers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 94	157	85%	<b>\$ 150,358</b>
Public/Commercial Service	\$ 141	31	100%	<b>\$ 52,391</b>
School Service	\$ 4,695	1	100%	<b>\$ 42,251</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 245,000</b>

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/21/2016  
Community Kipnuk  
Input

**Existing Community & System Data**

2015 Population	643
2015 Number of Services	189
HITS Database (E1 & H1-H7)	157
DCED Mapping Commercial/Public Facilities/School	32
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	312000
Water Treatment Capacity	40
Existing Sewage Lagoon Size	7.14

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	16300	20900
Gravity Sewer Main			
Pressure Sewer Main	x	16300	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Kipnuk

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	54		
Req Water Storage (gallons) (less existing)	31,800	590	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	6.6		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
Water Distribution System			
	Circulating Water Main with Pitorifices (lf)	20,900	
Wastewater Collection System			
	Sewer Main with Glycol Heat Trace (lf)	16,300	
	Individual Grinder Pump Stations (GPS) (ea)	189	
Water & Sewer Service Lines			
	Circulating Water Service Lines (lf)	14,200	
	Pressure Sewer Service Lines (lf)	14,200	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	54	40	14
Water Storage (gallons)	343,800	312,000	31,800
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	13.7	7.1	6.6
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,790	-	1,790
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	20,900	-	20,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	16,300	-	16,300
Individual Grinder Pump Stations (GPS) (ea)	189	-	189
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	14,200	-	14,200
Pressure Sewer Service Lines (lf)	14,200	-	14,200

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/21/2016	
Community	Kipnuk	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	643 people	2015 ADOL
2015 Number of Services	189 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	785 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	40 gpm	
Average Day (ADD)	39,229 gpd	50 gallons per Capita
Max Day (MDD)	78,458 gpd	2 x ADD
Peak Hour	163 gpm	3 x MDD
Treatment Capacity	54 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	54 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	312,000 gallons	
<u>Demand Based Volume (if source is SW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	78,458 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	235,375 gallons	3 days x DO
Water Storage Tank Volume	343,833 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	277,937 gallons	CT/RCxPeak Hour/BF
Required Water Storage	343,800 gallons	
Required Additional Storage	31,800 gallons	0
Estimate of Min Platform Size (3' clearance around)	590 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	7.14 acres	
Organic Loading Based Size check	6.7 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	437.5	
Hydraulic Loading Based Size	13.7 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	13.7 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Kipnuk**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	189	\$26,342.77	\$4,978,784
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	30,500	\$194.04	\$5,918,082
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	6.6	\$689,113.57	\$4,548,150
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	35,100	\$326.34	\$11,454,672
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	43,800	\$5.41	\$236,919
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,760	\$374.51	\$659,140
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	1	\$444,987.75	\$444,988
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$30,832,641**



# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

**Community:** Kipnuk

## General Community Data

Current population	643 persons
Average number of people per house	4.1
Service Connections	
Number of houses	157
Number of public/commerical buildings	31
Number of schools	1
Total number of service connections	189
Burdened labor rate	\$13 hr
Electricity cost (Public facility)	\$0.40 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$5.40 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	2400 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	9200 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	344,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	20900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	130
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	13100 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	3200 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$27,040
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$2,537 /month	\$20,298.06
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$2,111 /month	\$16,888.78
Water storage tank	\$282 /month	\$2,258.84
Water storage tank line	\$0 /month	\$0.00
Water mains	\$4,117 /month	\$32,937
Service lines	\$2,792 /month	\$22,339
<u>Wastewater system</u>		
Sewer mains	\$2,581 /month	\$20,645
Service lines	\$2,792 /month	\$22,339
Lift/pump station buildings	\$138 /month	\$1,103.16
Force main to lagoon	\$630 /month	\$5,043
	Subtotal	\$143,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$1,074 /month	\$12,888
HVAC/hydronic system	\$1,074 /month	\$8,592
Water treatment	\$195 /month	\$2,346
Pumps		
Intake or well	\$195 /month	\$2,345.66
WST circulation	\$54 /month	\$432
Pressure/booster	\$293 /month	\$3,518.50
Main line circulation	\$859 /month	\$6,874
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$58 /month	\$700
HVAC/hydronic system	\$58 /month	\$467
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$194 /month	\$2,330.72
Sewer/force main glycol circulation	\$214 /month	\$1,715
Lagoon discharge pump	\$2,816 /year	\$2,816
	Subtotal	\$45,000
<b>Other Costs</b>		
Equipment R&R	\$10,797 /year	\$10,797
Miscellaneous materials & supplies	\$6,478 /year	\$6,478
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$23,300

## Summary

Administration	\$6,000
Labor	\$27,000
Fuel	\$143,900
Electricity	\$45,000
Other	\$23,300
<b>Total</b>	<b>\$245,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 94	157	85%	\$ 150,358
Public/Commerc	\$ 140.84	31	100%	\$ 52,391
School Service	\$ 4,694.57	1	100%	\$ 42,251
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 245,000</b>



File: J:\jobdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 KipnuK.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
KIPNUK

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
15



# Kongiganak, Alaska

---

## Community Information & Existing Infrastructure

The Community of Kongiganak is a Yupik community of 501 people located on the west shore of Kuskokwim Bay, west of the mouth of the Kuskokwim River. There are 89 residential units, 31 commercial/public facilities and one school for a total of 121 services. The existing water and sewer services provided in Kongiganak consist of self-haul system from the central watering point attached to the water treatment plant and honey buckets. The washeteria and water treatment plant have piped water and sewer services, but the school only has a piped sewer service. The existing water and sewer infrastructure consists of the following:

- Contractor's Lake – 50 gpm transfer pump (Seasonal)
- Treated Water Storage – 10,000 gallons
- Raw Water Storage – 1.2 MG & 500,000 gallons
- Water Treatment Plant/Multi-Purpose Building – 2,400 SF, built in 2002 (20 gpm)
- Water Treatment – Bag filters, flocculation tanks, chlorine, and soda ash
- Sewage Lagoon – Single Cell, 5.3 acres

The community is underlain by deep permafrost that has started to degrade at the surface.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 17,900 feet of pipe, and the pressure sewer system approximately 11,000 feet of pipe. The water system will consist of four circulating loops. The pressure sewer system would require one sewer main lift station, individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. Upgrades to the existing seasonal water source will be needed to provide adequate flow for a piped system. Approximately 7 million gallons of raw water would need to be stored during the operation of the seasonal water source to provide water for the piped system when the source is non-producing. In order to fill and store 7 million gallons of raw water, the existing transfer pump would need to be increased to transfer a minimum of 60 gpm. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	42	20	22
<b>Raw Water Storage (gallons)</b>	7,000,000	1,700,000	5,300,000
<b>Water Storage (gallons)</b>	274,500	10,000	264,500
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	10.7	5.3	5.4
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	1,200	-	1,200
Thermosyphon stabilized gravel pad (sf)	61,990	-	61,990
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,900	-	17,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	11,000	-	11,000
Individual Grinder Pump Stations (GPS) (ea)	121	-	121
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,100	-	9,100
Pressure Sewer Service Lines (lf)	9,100	-	9,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Kongiganak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

VSW - Unserved Communities Project  
Kongiganak Piped Water & Sewer Assessment

Estimated Capital Costs				Village Kongiganak	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	121	\$26,342.77	\$3,187,476
3	Sewage collection mains or services (gravity or force), above ground	LF	20,100	\$195.84	\$3,936,394
4	Sewage lift station	EA	1	\$ 662,130.80	\$ 662,131
10	Sewage lagoon, barrow, local material	Acre	5	\$696,693.37	\$3,762,144
12	Water distribution, mains or services, above ground	LF	27,000	\$327.06	\$8,830,671
14	Water storage tank, no foundation	Gal	5,565,000	\$1.81	\$10,053,951
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
18	Foundation - freeze back piles	SF	1,200	\$426.48	\$511,777
19	Foundation - thermosyphen stablized gravel pad	SF	61,990	\$160.34	\$9,939,782
22	Water source - surface water intake	EA	1	\$444,987.75	\$444,988
Total Estimated Cost in 2010 dollars (rounded):					<b>\$43,259,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$51,653,500</b>
27	Individual Grinder Pump Stations	EA	121	\$30,000	\$3,630,000
28	Electrical Service Upgrades	EA	121	\$5,500	\$665,500
<b>Subtotal</b>					<b>\$55,949,000</b>
29	Construction Contingency (15%)	LS	1	\$8,392,400	\$8,392,400
30	Design & Construction Administration Services (20%)	LS	1	\$11,189,800	\$11,189,800
<b>Total</b>					<b>\$75,531,200</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$22,900
Fuel	\$145,600
Electricity	\$28,800
Other (R&R, Training, etc.)	\$21,800
<b>Total</b>	<b>\$225,000</b>

VSW - Unserved Communities Project  
Kongiganak Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Kongiganak are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 134	89	85%	<b>\$ 121,798</b>
Public/Commercial Service	\$ 148	31	100%	<b>\$ 54,902</b>
School Service	\$ 5,367	1	100%	<b>\$ 48,301</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 225,000</b>



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/21/2016  
 Community Kongiganak  
 Input

**Existing Community & System Data**

2015 Population	501
2015 Number of Services	121
HITS Database (E1 & H1-H7)	89
DCED Mapping Commerical/Public Facilities/School	32
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	10000
Water Treatment Capacity	20
Existing Sewage Lagoon Size	5.3

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	11000	17900
Gravity Sewer Main			
Pressure Sewer Main	x	11000	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Kongiganak

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	42		
Req Water Storage (gallons) (less existing)	5,565,000	61,990	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	5.4		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
	Thermosyphon stabilized gravel pad (sf)	61,990	
Water Distribution System			
	Circulating Water Main with Pitorifices (lf)	17,900	
Wastewater Collection System			
	Sewer Main with Glycol Heat Trace (lf)	11,000	
	Individual Grinder Pump Stations (GPS) (ea)	121	
Water & Sewer Service Lines			
	Circulating Water Service Lines (lf)	9,100	
	Pressure Sewer Service Lines (lf)	9,100	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	42	20	22
Raw Water Storage (gallons)	7,000,000	1,700,000	5,300,000
Water Storage (gallons)	274,500	10,000	264,500
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	10.7	5.3	5.4
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,200	-	1,200
Thermosyphon stabilized gravel pad (sf)	61,990	-	61,990
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,900	-	17,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	11,000	-	11,000
Individual Grinder Pump Stations (GPS) (ea)	121	-	121
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,100	-	9,100
Pressure Sewer Service Lines (lf)	9,100	-	9,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/21/2016	
Community	Kongiganak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	501 people	2015 ADOL
2015 Number of Services	121 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	611 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	30,566 gpd	50 gallons per Capita
Max Day (MDD)	61,132 gpd	2 x ADD
Peak Hour	127 gpm	3 x MDD
Treatment Capacity	42 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	42 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	10,000 gallons	
<u>Demand Based Volume (if source is SW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	61,132 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	183,395 gallons	3 days x DO
Water Storage Tank Volume	274,526 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	216,558 gallons	CT/RCxPeak Hour/BF
Required Water Storage	274,500 gallons	
Required Additional Storage	5,565,000 gallons	0
Estimate of Min Platform Size (3' clearance around)	61,990 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf) Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf) Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf) Sewer main with glycol heat trace
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf) Circulating Water Service Lines
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf) Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	5.3 acres	
Organic Loading Based Size	5.2 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	386.2	
Hydraulic Loading Based Size	10.7 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	10.7 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Kongiganak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	121	\$26,342.77	\$3,187,476
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	20,100	\$195.84	\$3,936,394
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	5.4	\$696,693.37	\$3,762,144
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	27,000	\$327.06	\$8,830,671
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	5,565,000	\$1.81	\$10,053,951
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,200	\$426.48	\$511,777
19	Foundation - thermosyphen stablized gravel pad	SF	61,990	\$160.34	\$9,939,782
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	1	\$444,987.75	\$444,988
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$43,259,089**

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Kongiganak

### General Community Data

Current population	501 persons
Average number of people per house	5.6
Service Connections	
Number of houses	89
Number of public/commerical buildings	31
Number of schools	1
Total number of service connections	121
Burdened labor rate	\$11 hr
Electricity cost (Public facility)	\$0.30 kWh
Electricity cost (Residential service)	\$0.35 kWh
Cost per gallon for heating oil	\$5.43 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	9800 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	3600 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	7,275,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	4
Total length of Water Main	17900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	104
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	11000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	4
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	435 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$22,880
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$998 /month	\$7,986.84
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,654 /month	\$13,232.17
Water storage tank	\$6,004 /month	\$48,035.95
Water storage tank line	\$0 /month	\$0.00
Water mains	\$3,546 /month	\$28,366
Service lines	\$1,798 /month	\$14,381
<u>Wastewater system</u>		
Sewer mains	\$2,179 /month	\$17,432
Service lines	\$1,798 /month	\$14,381
Lift/pump station buildings	\$139 /month	\$1,109.28
Force main to lagoon	\$86 /month	\$689
	Subtotal	\$145,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$315 /month	\$3,782
HVAC/hydronic system	\$315 /month	\$2,521
Water treatment	\$114 /month	\$1,371
Pumps		
Intake or well	\$114 /month	\$1,370.74
WST circulation	\$41 /month	\$324
Pressure/booster	\$171 /month	\$2,056.10
Main line circulation	\$1,289 /month	\$10,310
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$44 /month	\$525
HVAC/hydronic system	\$44 /month	\$350
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$160 /month	\$1,922.11
Sewer/force main glycol circulation	\$322 /month	\$2,573
Lagoon discharge pump	\$1,646 /year	\$1,646
	Subtotal	\$28,800
<b>Other Costs</b>		
Equipment R&R	\$9,864 /year	\$9,864
Miscellaneous materials & supplies	\$5,918 /year	\$5,918
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$21,800

## Summary

Administration	\$6,000
Labor	\$22,900
Fuel	\$145,600
Electricity	\$28,800
Other	\$21,800
<b>Total</b>	<b>\$225,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 134	89	85%	\$ 121,798
Public/Commerc	\$ 147.58	31	100%	\$ 54,902
School Service	\$ 5,366.73	1	100%	\$ 48,301
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 225,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CAD\01 Working Set\01 Civil\31303.00 Kongiganak.dwg



**LEGEND:**

PROPOSED WATER MAIN	
PROPOSED SEWER/FORCE MAIN	
PROPOSED LIFT STATION	
EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP	
EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP	
HOME ADDITION FROM HITS MAP	

**CRW**  
ENGINEERING GROUP, LLC

PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF UNSERVED COMMUNITIES KONGIGANAK	DATE SEP 2016
	SCALE GRAPHIC
	FIGURE 16



# Koyukuk, Alaska

## Community Information & Existing Infrastructure

The Community of Koyukuk is an Athabascan community of 92 people located on the Yukon River near the mouth of the Koyukuk River. There are 50 residential units, 10 commercial/public facilities and one school for a total of 61 services. The existing water and sewer services provided in Koyukuk consist of self-haul system from the washeteria and honey buckets/pit privies. The existing water and sewer infrastructure consists of the following:

- Well Water – 14 gpm transfer pump
- Treated Water Storage – 5,000 gallons
- Water Treatment Plant/Washeteria – 1,200 SF, built in 1975, renovated in 1987
- Water Treatment – Greensand filters, oxidation chamber, carbon filter, chlorine
- Sewage Lagoon – Single Cell, 0.28 acres

Soils around Koyukuk consist of dark brown peaty silt approximately 1.5-3 feet, and sand mixed with silt below 3 feet. The community is in a continuous permafrost zone with varying depths between 6-15 feet.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 15,500 feet of pipe, and the pressure sewer system approximately 12,000 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	8	14	-
<b>Water Storage (gallons)</b>	74,900	5,000	69,900
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	2.0	0.3	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,300	-	2,300
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	15,500	-	15,500
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,000	-	12,000
Individual Grinder Pump Stations (GPS) (ea)	61	-	61
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,600	-	4,600
Pressure Sewer Service Lines (lf)	4,600	-	4,600



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Koyukuk. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village
					Koyukuk
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	61	\$26,403.25	\$1,610,598
3	Sewage collection mains or services (gravity or force), above ground	LF	16,600	\$202.45	\$3,360,590
10	Sewage lagoon, barrow, local material	Acre	2	\$847,406.81	\$1,440,592
12	Water distribution, mains or services, above ground	LF	20,100	\$332.88	\$6,690,809
14	Water storage tank, no foundation	Gal	69,900	\$4.97	\$347,198
15	Water treatment plant, no foundation	SF	1,200	\$1,660.79	\$1,992,952
19	Foundation - thermosyphen stablized gravel pad	SF	2,300	\$344.23	\$791,733
Total Estimated Cost in 2010 dollars (rounded):					<b>\$16,234,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$19,384,200</b>
27	Individual Grinder Pump Stations	EA	61	\$30,000	\$1,830,000
28	Electrical Service Upgrades	EA	61	\$5,500	\$335,500
Subtotal					<b>\$21,549,700</b>
29	Construction Contingency (15%)	LS	1	\$3,232,500	\$3,232,500
30	Design & Construction Administration Services (20%)	LS	1	\$4,309,900	\$4,309,900
Total					<b>\$29,092,100</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$80,100
Electricity	\$19,800
Other (R&R, Training, etc.)	\$16,000
<b>Total</b>	<b>\$147,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Koyukuk are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 170	50	85%	<b>\$ 86,471</b>
Public/Commercial Service	\$ 187	10	100%	<b>\$ 22,381</b>
School Service	\$ 4,239	1	100%	<b>\$ 38,149</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 147,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Koyukuk.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/22/2016  
 Community Koyukuk  
 Input

**Existing Community & System Data**

2015 Population	92
2015 Number of Services	61
HITS Database (E1 & H1-H7)	50
DCED Mapping Commerical/Public Facilities/School	11
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	5000
Water Treatment Capacity	14
Existing Sewage Lagoon Size	0.28

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	12000	15500
Gravity Sewer Main			
Pressure Sewer Main	x	12000	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Koyukuk

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	8		
Req Water Storage (gallons) (less existing)	69,900	1,100	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	1.7		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	15,500	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	12,000	
	Individual Grinder Pump Stations (GPS) (ea)	61	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	4,600	
	Pressure Sewer Service Lines (lf)	4,600	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	8	14	-
Water Storage (gallons)	74,900	5,000	69,900
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	2.0	0.3	1.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,300	-	2,300
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	15,500	-	15,500
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,000	-	12,000
Individual Grinder Pump Stations (GPS) (ea)	61	-	61
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,600	-	4,600
Pressure Sewer Service Lines (lf)	4,600	-	4,600



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/22/2016	
Community	Koyukuk	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	92 people	2015 ADOL
2015 Number of Services	61 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	112 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	14 gpm	
Average Day (ADD)	5,613 gpd	50 gallons per Capita
Max Day (MDD)	11,226 gpd	2 x ADD
Peak Hour	23 gpm	3 x MDD
Treatment Capacity	8 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	8 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	5,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	11,226 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	33,677 gallons	3 days x DO
Water Storage Tank Volume	74,903 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	39,767 gallons	CT/RCxPeak Hour/BF
Required Water Storage	74,900 gallons	
Required Additional Storage	69,900 gallons	0
Estimate of Min Platform Size (3' clearance around)	1,100 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon
Stiff soils, no permafrost	0	Thermosyphon stabilized gravel pad Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (If)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (If)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (If)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (If)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.28 acres	
Organic Loading Based Size	1.0 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	165.5	
Hydraulic Loading Based Size	2.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	2.0 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Koyukuk**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	61	\$26,403.25	\$1,610,598
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	16,600	\$202.45	\$3,360,590
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.7	\$847,406.81	\$1,440,592
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	20,100	\$332.88	\$6,690,809
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	69,900	\$4.97	\$347,198
15	Water treatment plant, no foundation	SF	1,200	\$1,660.79	\$1,992,952
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	2,300	\$344.23	\$791,733
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$16,234,472**

# O&M Cost Estimate Piped Water & Sewer System

4/21/2016

**Community:** Koyukuk

## General Community Data

Current population	92 persons
Average number of people per house	1.8
Service Connections	
Number of houses	50
Number of public/commerical buildings	10
Number of schools	1
Total number of service connections	61
Burdened labor rate	\$15 hr
Electricity cost (Public facility)	\$0.49 kWh
Electricity cost (Residential service)	\$0.46 kWh
Cost per gallon for heating oil	\$6.50 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	30 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	2400 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	74,900 gallons
Length of water line to/ from tank	25 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	15500 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	12000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	360 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

4/21/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

4/21/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$797 /month	\$6,373.79
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$364 /month	\$2,908.67
Water storage tank	\$74 /month	\$592.01
Water storage tank line	\$0 /month	\$0.00
Water mains	\$2,205 /month	\$26,463
Service lines	\$651 /month	\$7,811
<u>Wastewater system</u>		
Sewer mains	\$1,707 /month	\$20,487
Service lines	\$651 /month	\$7,811
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$51 /month	\$615
	Subtotal	\$73,100
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$343 /month	\$4,118
HVAC/hydronic system	\$343 /month	\$4,118
Water treatment	\$34 /month	\$411
Pumps		
Intake or well	\$34 /month	\$411.13
WST circulation	\$66 /month	\$529
Pressure/booster	\$51 /month	\$616.69
Main line circulation	\$1,053 /month	\$12,630
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$263 /month	\$3,152
Lagoon discharge pump	\$494 /year	\$494
	Subtotal	\$26,500
<b>Other Costs</b>		
Equipment R&R	\$6,228 /year	\$6,228
Miscellaneous materials & supplies	\$3,737 /year	\$3,737
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$16,000

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$73,100
Electricity	\$26,500
Other	\$16,000
<b>Total</b>	<b>\$147,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 170	50	85%	\$ 86,471
Public/Commerc	\$ 186.51	10	100%	\$ 22,381
School Service	\$ 4,238.75	1	100%	\$ 38,149
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 147,000</b>

# Kwigillingok, Alaska

## Community Information & Existing Infrastructure

The Community of Kwigillingok is a Yupik community of 364 people located on the western shore of Kuskokwim Bay near the mouth of the Kuskokwim River. There are 95 residential units, 29 commercial/public facilities and one K-12 school for a total of 125 services. The existing water and sewer services provided in Kwigillingok consist of a self-haul system. Raw water is stored in a reservoir that supplies water year round. The raw water reservoir is replenished by a combination of surface water runoff, rain, and snow. The existing water and sewer infrastructure consists of the following:

- Reservoir – 40 gpm (Year round supply)
- Treated Water Storage – 215,000 gallons
- Water Treatment Plant – 2,760 SF, built in 2008
- Water Treatment – Soda ash, potassium permanganate, cationic polymer, greensand filtration, and chlorine
- Sewage Lagoon – Single Cell, 0.57 acres

Soils around Kwigillingok consist of a thin organic mat with peat and ice up to approximately 4 inches thick. There is ice-rich organic silt 25-30 feet deep, overlaying sandy silt. Permafrost is present sporadically.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 37,700 feet of pipe, and the pressure sewer system approximately 27,000 feet of pipe. The water system will consist of four circulating loops. The pressure sewer system would require three sewer main lift stations, individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, two new 1,200 sf facilities are included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. The existing water storage tank is sufficient to meet CT requirements (157,400 gallons) and provide reserve for fire flows.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	31	40	-
<b>Water Storage (gallons)</b>	207,700	215,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,400	-	2,400
<b>Sewage Lagoon Size (acre)</b>	7.8	0.6	7.2
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,400	-	2,400
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	37,700	-	37,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	27,000	-	27,000
Individual Grinder Pump Stations (GPS) (ea)	125	-	125
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,400	-	9,400
Pressure Sewer Service Lines (lf)	9,400	-	9,400

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Kwigillingok. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Kwigillingok
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	125	\$26,342.77	\$3,292,847
3	Sewage collection mains or services (gravity or force), above ground	LF	36,400	\$193.47	\$7,042,309
4	Sewage lift station	EA	2	\$ 563,234.80	\$ 1,126,470
10	Sewage lagoon, barrow, local material	Acre	7	\$686,271.14	\$4,941,152
12	Water distribution, mains or services, above ground	LF	47,100	\$325.73	\$15,342,081
15	Water treatment plant, no foundation	SF	2,400	\$1,583.60	\$3,800,638
18	Foundation - freeze back piles	SF	2,400	\$344.81	\$827,554
Total Estimated Cost in 2010 dollars (rounded):					<b>\$36,373,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$43,431,300</b>
27	Individual Grinder Pump Stations	EA	125	\$30,000	\$3,750,000
28	Electrical Service Upgrades	EA	125	\$5,500	\$687,500
Subtotal					<b>\$47,868,800</b>
29	Construction Contingency (15%)	LS	1	\$7,180,300	\$7,180,300
30	Design & Construction Administration Services (20%)	LS	1	\$9,573,800	\$9,573,800
Total					<b>\$64,622,900</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$33,300
Fuel	\$138,800
Electricity	\$41,900
Other (R&R, Training, etc.)	\$23,100
<b>Total</b>	<b>\$243,000</b>

VSW - Unserved Communities Project  
Kwigillingok Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Kwigillingok are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 146	95	85%	<b>\$ 141,269</b>
Public/Commercial Service	\$ 160	29	100%	<b>\$ 55,808</b>
School Service	\$ 5,103	1	100%	<b>\$ 45,923</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 243,000</b>



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

3/22/2016  
Kwigillingok

**Existing Community & System Data**

2015 Population	364
2015 Number of Services	125
HITS Database (E1 & H1-H7)	95
DCED Mapping Commerical/Public Facilities/School	30
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	215000
Water Treatment Capacity	40
Existing Sewage Lagoon Size	0.57

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<b>x</b>
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<b>x</b>	27000	37700
Gravity Sewer Main			
Pressure Sewer Main	<b>x</b>	27000	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      Kwigillingok

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	31		
Req Water Storage (gallons) (less existing)	(7,300)	-	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	2,400	sf
Req Sewage Lagoon Size (acre) (less existing)	7.2		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	2,400	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	37,700	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	27,000	
	Individual Grinder Pump Stations (GPS) (ea)	125	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	9,400	
	Pressure Sewer Service Lines (lf)	9,400	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	31	40	-
Water Storage (gallons)	207,700	215,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	-	2,400
Sewage Lagoon Size (acre)	7.8	0.6	7.2
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,400	-	2,400
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	37,700	-	37,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	27,000	-	27,000
Individual Grinder Pump Stations (GPS) (ea)	125	-	125
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,400	-	9,400
Pressure Sewer Service Lines (lf)	9,400	-	9,400

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/22/2016	
Community	Kwigillingok	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	364 people	2015 ADOL
2015 Number of Services	125 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	444 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	40 gpm	
Average Day (ADD)	22,207 gpd	50 gallons per Capita
Max Day (MDD)	44,415 gpd	2 x ADD
Peak Hour	93 gpm	3 x MDD
Treatment Capacity	31 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	31 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	215,000 gallons	
<u>Demand Based Volume (if source is SW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	44,415 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	133,245 gallons	3 days x DO
Water Storage Tank Volume	207,660 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	157,339 gallons	CT/RCxPeak Hour/BF
Required Water Storage	207,700 gallons	
Required Additional Storage	(7,300) gallons	0
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.57 acres	
Organic Loading Based Size check	3.8 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	329.2	
Hydraulic Loading Based Size	7.8 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	7.8 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Kwigillingok**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	125	\$26,342.77	\$3,292,847
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	36,400	\$193.47	\$7,042,309
4	Sewage lift station	EA	2	\$563,234.80	\$1,126,470
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	7.2	\$686,271.14	\$4,941,152
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	47,100	\$325.73	\$15,342,081
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	2,400	\$1,583.60	\$3,800,638
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	2,400	\$344.81	\$827,554
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$36,373,051**

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Kwigillingok

### General Community Data

Current population	364 persons
Average number of people per house	3.8
Service Connections	
Number of houses	95
Number of public/commerical buildings	29
Number of schools	1
Total number of service connections	125
Burdened labor rate	\$16 hr
Electricity cost (Public facility)	\$0.42 kWh
Electricity cost (Residential service)	\$0.19 kWh
Cost per gallon for heating oil	\$4.65 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	3100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	4560 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	212,000 gallons
Length of water line to/ from tank	25 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	4
Total length of Water Main	37700 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	60
Number of facilities served by lift/pump station #2	122
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	27000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	4
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	4070 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,083 /month	\$8,663.45
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,029 /month	\$8,232.81
Water storage tank	\$150 /month	\$1,198.73
Water storage tank line	\$0 /month	\$0.00
Water mains	\$6,395 /month	\$51,161
Service lines	\$1,590 /month	\$12,722
<u>Wastewater system</u>		
Sewer mains	\$4,580 /month	\$36,641
Service lines	\$1,590 /month	\$12,722
Lift/pump station buildings	\$237 /month	\$1,899.88
Force main to lagoon	\$690 /month	\$5,523
	Subtotal	\$138,800
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$559 /month	\$6,707
HVAC/hydronic system	\$559 /month	\$4,471
Water treatment	\$116 /month	\$1,394
Pumps		
Intake or well	\$116 /month	\$1,394.27
WST circulation	\$57 /month	\$454
Pressure/booster	\$174 /month	\$2,091.40
Main line circulation	\$1,804 /month	\$14,435
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$123 /month	\$1,471
HVAC/hydronic system	\$123 /month	\$981
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$267 /month	\$3,205.34
Sewer/force main glycol circulation	\$450 /month	\$3,602
Lagoon discharge pump	\$1,674 /year	\$1,674
	Subtotal	\$41,900
<b>Other Costs</b>		
Equipment R&R	\$10,699 /year	\$10,699
Miscellaneous materials & supplies	\$6,419 /year	\$6,419
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$23,100


## Summary

Administration	\$6,000
Labor	\$33,300
Fuel	\$138,800
Electricity	\$41,900
Other	\$23,100
<b>Total</b>	<b>\$243,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 146	95	85%	\$ 141,269
Public/Commerc	\$ 160.37	29	100%	\$ 55,808
School Service	\$ 5,102.59	1	100%	\$ 45,923
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 243,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Kwigillingok.dwg



**LEGEND:**

PROPOSED WATER MAIN	
PROPOSED SEWER/FORCE MAIN	
PROPOSED LIFT STATION	
EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP	
EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP	
HOME ADDITION FROM HITS MAP	

**CRW**  
ENGINEERING GROUP, LLC

PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF UNSERVED COMMUNITIES <b>KWIGILLINGOK</b>	DATE MAR 2015
	SCALE GRAPHIC
	FIGURE 18



# Lime Village, Alaska

## Community Information & Existing Infrastructure

Lime Village is a Denaina Athabascan Indian community of 29 people located on the south bank of the Stony River, 50 miles southeast of its junction with the Kuskokwim River. There are 11 residential units and 8 commercial/public facilities for a total of 19 services. The existing water and sewer services provided in Lime Village consist of self-haul system from the watering point attached to the washeteria and pit privies. The existing water and sewer infrastructure consists of the following:

- Well Water – 20 gpm Well Capacity
- Treated Water Storage – 1050 gallons
- Water Treatment Plant – 1590 SF, built in 2006
- Water Treatment – No treatment
- Sewage Lagoon – N/A

Soils around Lime Village consist of 6 inch of vegetative mat overlying dense sandy silts Coarse sand, gravel and cobbles underneath. Moisture contents indicate seasonally frozen material is wet and soft when unfrozen.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 7,200 feet of pipe, and the pressure sewer system approximately 4,900 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require one sewer main lift station, individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 800 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	2	15	-
<b>Water Storage (gallons)</b>	44,200	95	44,105
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	800	-	800
<b>Sewage Lagoon Size (acre)</b>	0.6	-	0.6
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,560	-	1,560
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	7,200	-	7,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	4,900	-	4,900
Individual Grinder Pump Stations (GPS) (ea)	19	-	19
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	1,400	-	1,400
Pressure Sewer Service Lines (lf)	1,400	-	1,400



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Lime Village. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Lime Village	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	19	\$28,096.69	\$533,837
2	Sewage collection mains or services (gravity or force), buried	LF	6,300	\$417.48	\$ 2,630,154
4	Sewage lift station	EA	1	\$ 1,397,322.77	\$ 1,397,323
10	Sewage lagoon, barrow, local material	Acre	1	\$1,675,613.17	\$1,005,368
13	Water distribution, mains or services, buried	LF	8,600	\$417.57	\$3,591,126
14	Water storage tank, no foundation	Gal	44,105	\$10.90	\$480,951
15	Water treatment plant, no foundation	SF	800	\$2,542.06	\$2,033,649
18	Foundation - freeze back piles	SF	1,560	\$720.07	\$1,123,307
Total Estimated Cost in 2010 dollars (rounded):					<b>\$12,796,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$15,279,100</b>
27	Individual Grinder Pump Stations	EA	19	\$30,000	\$570,000
28	Electrical Service Upgrades	EA	19	\$5,500	\$104,500
<b>Subtotal</b>					<b>\$15,953,600</b>
29	Construction Contingency (15%)	LS	1	\$2,393,000	\$2,393,000
30	Design & Construction Administration Services (20%)	LS	1	\$3,190,700	\$3,190,700
<b>Total</b>					<b>\$21,537,300</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$31,700
Electricity	\$28,800
Other (R&R, Training, etc.)	\$12,800
<b>Total</b>	<b>\$104,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Lime Village are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 478	11	85%	<b>\$ 53,576</b>
Public/Commercial Service	\$ 525	8	100%	<b>\$ 50,424</b>
School Service	\$ -	0	100%	<b>\$ -</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 104,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Lime Village.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

3/23/2016  
Lime Village

**Existing Community & System Data**

2015 Population	29
2015 Number of Services	19
HITS Database (E1 & H1-H7)	11
DCED Mapping Commerical/Public Facilities/School	8
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Good
Water Storage Tank	95
Water Treatment Capacity	15
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<input checked="" type="checkbox"/>	4900	7200
Gravity Sewer Main			
Pressure Sewer Main	<input checked="" type="checkbox"/>	4900	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
Lime Village

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>
Water Treatment Capacity (gpm)	2	
Req Water Storage (gallons) (less existing)	44,105	760 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	800 sf
Req Sewage Lagoon Size (acre) (less existing)	0.6	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	800	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	7,200	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	4,900	
	Individual Grinder Pump Stations (GPS) (ea)	19	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	1,400	
	Pressure Sewer Service Lines (lf)	1,400	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	2	15	-
Water Storage (gallons)	44,200	95	44,105
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	800	-	800
Sewage Lagoon Size (acre)	0.6	-	0.6
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,560	-	1,560
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	7,200	-	7,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	4,900	-	4,900
Individual Grinder Pump Stations (GPS) (ea)	19	-	19
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	1,400	-	1,400
Pressure Sewer Service Lines (lf)	1,400	-	1,400



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/23/2016	
Community	Lime Village	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	29 people	2015 ADOL
2015 Number of Services	19 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	35 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	15 gpm	
Average Day (ADD)	1,769 gpd	50 gallons per Capita
Max Day (MDD)	3,539 gpd	2 x ADD
Peak Hour	7 gpm	3 x MDD
Treatment Capacity	2 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	2 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	95 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	3,539 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	10,616 gallons	3 days x DO
Water Storage Tank Volume	44,154 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	12,535 gallons	CT/RCxPeak Hour/BF
Required Water Storage	44,200 gallons	
Required Additional Storage	44,105 gallons	0
Estimate of Min Platform Size (3' clearance around)	760 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Good	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	800 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size	0.3 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	92.9	
Hydraulic Loading Based Size	0.6 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	0.6 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Lime Village**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	19	\$28,096.69	\$533,837
2	Sewage collection mains or services (gravity or force), buried	LF	6,300	\$417.48	\$2,630,154
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	1	\$1,397,322.77	\$1,397,323
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.6	\$1,675,613.17	\$1,005,368
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	8,600	\$417.57	\$3,591,126
14	Water storage tank, no foundation	Gal	44,105	\$10.90	\$480,951
15	Water treatment plant, no foundation	SF	800	\$2,542.06	\$2,033,649
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,560	\$720.07	\$1,123,307
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$12,795,715**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Lime Village

## General Community Data

Current population	29 persons
Average number of people per house	2.6
Service Connections	
Number of houses	11
Number of public/commerical buildings	8
Number of schools	0
Total number of service connections	19
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.82 kWh
Electricity cost (Residential service)	\$0.96 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	750 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	1472 sf
Raw water quality (Good or Poor)	Good

### Water Storage

Size of tank(s)	44,200 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	7200 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	18
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	4900 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	1340 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$451 /month	\$3,608.54
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$106 /month	\$846.34
Water storage tank	\$40 /month	\$322.48
Water storage tank line	\$0 /month	\$0.00
Water mains	\$946 /month	\$11,347
Service lines	\$187 /month	\$2,246
<u>Wastewater system</u>		
Sewer mains	\$644 /month	\$7,722
Service lines	\$187 /month	\$2,246
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to lagoon	\$176 /month	\$2,112
	Subtotal	\$31,700
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$352 /month	\$4,227
HVAC/hydronic system	\$352 /month	\$4,227
Water treatment	\$4 /month	\$43
Pumps		
Intake or well	\$18 /month	\$216.87
WST circulation	\$111 /month	\$886
Pressure/booster	\$27 /month	\$325.31
Main line circulation	\$881 /month	\$10,568
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$120 /month	\$1,436
HVAC/hydronic system	\$120 /month	\$957
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$35 /month	\$425.86
Sewer/force main glycol circulation	\$440 /month	\$5,274
Lagoon discharge pump	\$260 /year	\$260
	Subtotal	\$28,800
<b>Other Costs</b>		
Equipment R&R	\$4,273 /year	\$4,273
Miscellaneous materials & supplies	\$2,564 /year	\$2,564
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$12,800

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$31,700
Electricity	\$28,800
Other	\$12,800
<b>Total</b>	<b>\$104,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 478	11	85%	\$ 53,576
Public/Commerc	\$ 525.25	8	100%	\$ 50,424
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 104,000</b>

# Mekoryuk, Alaska

## Community Information & Existing Infrastructure

The City of Mekoryuk is a Yupik community of 210 people on Nunivak Island. There are 97 residential units, 19 commercial/public facilities and one school for a total of 117 services. The existing water and sewer services provided in Mekoryuk consist of a Cowater flush, tank and haul system at each building. The existing water and sewer infrastructure consists of the following:

- River Infiltration Gallery - 100 gpm transfer pump
- Raw Water Reservoir - 7.5 million gallons
- Direct Filtration Treatment - 25 gpm
- Water Treatment Plant/Washeteria - 1540 sf, built in 1990
- Treated water storage - 125,000 gallons
- Sewage Lagoon - 4.3 acres

Soil conditions in the community generally consist of a mix of thaw stable sand and wet or ice-rich silts. Discontinuous permafrost, shallow groundwater and occasional basalt flows exist. Any new foundations should consist of driven piles or thermosyphen stabilized gravel pads.

## Piped System Description

The piped water system will be an above grade system roughly 14,900 feet in length. The pressure sewer will consist of roughly 6,500 feet of pipe above grade and 3,000 below grade. Only areas east of the school can be buried due to soil conditions. The pressure sewer system would require individual grinder pump stations at each house, and glycol heat trace for freeze protection. Approximately 8,800 feet of water and sewer service piping would be required; and a third of this could be buried (2,900). For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. The existing water storage tank is sufficient to meet CT requirements (91,000 gallons) and provide a small reserve for fire flows.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	18	25	-
<b>Water Storage (gallons)</b>	91,000	125,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	2.9	4	-
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphen stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	14,900	-	14,900
<b>Wastewater Collection System</b>			
Insulated Sewer Main with Glycol Heat Trace (lf)	9,500	-	9,500
Residential Grinder Pump Stations (GPS) (ea)	117	-	117
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,800	-	8,800
Pressure Sewer Service w GPS (lf)	8,800	-	8,800

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Mekoryuk. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Mekoryuk	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	117	\$ 26,342.77	\$ 3,082,104
2	Sewage collection mains or services (gravity or force), buried	LF	5,900	\$293.55	\$ 1,731,936
3	Sewage collection mains or services (gravity or force), above ground	LF	12,400	\$201.57	\$ 2,499,422
4	Sewage lift station	EA	1	\$ 746,130.80	\$ 746,131
12	Water distribution, mains or services, above ground	LF	23,700	\$328.77	\$7,791,873
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$513.76	\$616,510
Total Estimated Cost (rounded):					<b>\$18,428,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$22,004,000</b>
27	Residential Grinder Pump Stations	EA	117	\$30,000	\$3,510,000
28	Electrical Service Upgrades	EA	117	\$5,500	\$643,500
<b>Subtotal</b>					<b>\$26,157,500</b>
29	Construction Contingency (15%)	LS	1	\$2,615,800	\$2,615,800
30	Design & Construction Administration Services (20%)	LS	1	\$5,231,500	\$5,231,500
<b>Total</b>					<b>\$34,004,800</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.


Estimated O&M Costs	
Description	Annual Cost
Administration	\$6,000
Labor	\$45,800
Fuel (Heating)	\$94,800
Electricity	\$18,600
Other (R&R, Training, etc.)	\$18,700
<b>Total</b>	<b>\$184,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Mekoryuk are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 104	97	85%	\$ 102,783
Public/Commercial Service	\$ 192	19	100%	\$ 43,818
School Service	\$ 4,155	1	100%	\$ 37,398
Local Capital Contribution				\$ -
<b>Total Revenue</b>				\$ 184,000



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Mekoryuk.dwg





VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model																																																															
Date	2/9/2016																																																														
Community	Mekoryuk																																																														
Input																																																															
<b>Existing Community &amp; System Data</b>																																																															
2015 Population	210																																																														
2015 Number of Services	117																																																														
HITS Database (E1 & H1-H7)	97																																																														
DCED Mapping Commerical/Public Facilities/School	20																																																														
Type (surface water or groundwater)	SW																																																														
Water quality (Poor or Good)	poor																																																														
Water Storage Tank	125000																																																														
Water Treatment Capacity	25																																																														
Existing Sewage Lagoon Size	4.3																																																														
<b>Soil Conditions (check only one)</b>																																																															
Soft poorly drained soils or discontinuous permafrost																																																															
Firm soils, or continuous permafrost	x																																																														
Stiff soils, no permafrost																																																															
<b>Piping Configurations (check all that apply)</b>																																																															
		Sewer Main Length (ft)	Water Main Length (ft)																																																												
Buried system with no permafrost																																																															
Above ground system or buried with permafrost	x	9500	14900																																																												
Gravity Sewer Main		0																																																													
Pressure Sewer Main	x	9500																																																													
Typical Service Line Length (ea)		75	75																																																												
<b>Piped System Requirements</b>																																																															
Community	Mekoryuk																																																														
Output for Cost Model (calculated)																																																															
		Foundation Size																																																													
Water Treatment Capacity (gpm)	18																																																														
Req Water Storage (gallons)	91,000	1,370	sf																																																												
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf																																																												
Req Sewage Lagoon Size (acre)	2.9																																																														
		Quantity	Notes																																																												
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	2,570	Only need foundation for bldg, not tank.																																																												
Water Distribution System	Circulating Water Main with Pitorifices (lf)	14,900																																																													
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	9,500																																																													
	Residential Grinder Pump Stations (GPS) (ea)	20																																																													
	Water & Sewer Service Lines	Circulating Water Service Lines (lf)	8,800																																																												
	Pressure Sewer Service w/GPS (lf)	8,800																																																													
<table border="1"> <thead> <tr> <th>System Description</th> <th>Piped System Need</th> <th>Existing Facility</th> <th>Net Need</th> </tr> </thead> <tbody> <tr> <td>Water Treatment Capacity (gpm)</td> <td>18</td> <td>25</td> <td>-</td> </tr> <tr> <td>Water Storage (gallons)</td> <td>91,000</td> <td>125,000</td> <td>-</td> </tr> <tr> <td>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</td> <td>1,200</td> <td>-</td> <td>1,200</td> </tr> <tr> <td>Sewage Lagoon Size (acre)</td> <td>2.9</td> <td>4.3</td> <td>-</td> </tr> <tr> <td colspan="4"><b>Required Foundation System for WTP and/or WST</b></td> </tr> <tr> <td>Thermosyphon stabilized gravel pad (sf)</td> <td>1,200</td> <td>-</td> <td>1,200</td> </tr> <tr> <td colspan="4"><b>Water Distribution System</b></td> </tr> <tr> <td>Circulating Water Main with Pitorifices (lf)</td> <td>14,900</td> <td>-</td> <td>14,900</td> </tr> <tr> <td colspan="4"><b>Wastewater Collection System</b></td> </tr> <tr> <td>Insulated Sewer Main with Glycol Heat Trace (lf)</td> <td>9,500</td> <td>-</td> <td>9,500</td> </tr> <tr> <td>Residential Grinder Pump Stations (GPS) (ea)</td> <td>20</td> <td>-</td> <td>20</td> </tr> <tr> <td colspan="4"><b>Water &amp; Sewer Service Lines</b></td> </tr> <tr> <td>Circulating Water Service Lines (lf)</td> <td>8,800</td> <td>-</td> <td>8,800</td> </tr> <tr> <td>Pressure Sewer Service w GPS (lf)</td> <td>8,800</td> <td>-</td> <td>8,800</td> </tr> </tbody> </table>				System Description	Piped System Need	Existing Facility	Net Need	Water Treatment Capacity (gpm)	18	25	-	Water Storage (gallons)	91,000	125,000	-	W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200	Sewage Lagoon Size (acre)	2.9	4.3	-	<b>Required Foundation System for WTP and/or WST</b>				Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200	<b>Water Distribution System</b>				Circulating Water Main with Pitorifices (lf)	14,900	-	14,900	<b>Wastewater Collection System</b>				Insulated Sewer Main with Glycol Heat Trace (lf)	9,500	-	9,500	Residential Grinder Pump Stations (GPS) (ea)	20	-	20	<b>Water &amp; Sewer Service Lines</b>				Circulating Water Service Lines (lf)	8,800	-	8,800	Pressure Sewer Service w GPS (lf)	8,800	-	8,800
System Description	Piped System Need	Existing Facility	Net Need																																																												
Water Treatment Capacity (gpm)	18	25	-																																																												
Water Storage (gallons)	91,000	125,000	-																																																												
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200																																																												
Sewage Lagoon Size (acre)	2.9	4.3	-																																																												
<b>Required Foundation System for WTP and/or WST</b>																																																															
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200																																																												
<b>Water Distribution System</b>																																																															
Circulating Water Main with Pitorifices (lf)	14,900	-	14,900																																																												
<b>Wastewater Collection System</b>																																																															
Insulated Sewer Main with Glycol Heat Trace (lf)	9,500	-	9,500																																																												
Residential Grinder Pump Stations (GPS) (ea)	20	-	20																																																												
<b>Water &amp; Sewer Service Lines</b>																																																															
Circulating Water Service Lines (lf)	8,800	-	8,800																																																												
Pressure Sewer Service w GPS (lf)	8,800	-	8,800																																																												

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	Community	
2/9/2016	Mekoryuk	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	210 people	2015 ADOL
2015 Number of Services	117 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	256 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	25 gpm	
Average Day (ADD)	12,812 gpd	50 gallons per Capita
Max Day (MDD)	25,624 gpd	2 x ADD
Peak Hour	53 gpm	3 x MDD
Treatment Capacity	18 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	SW or GW
Required Capacity	18 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	125000 gallons	
<u>Demand Based Volume (if source is GW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	25,624 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	76,872 gallons	3 days x DO
Water Storage Tank Volume	132,496 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	90,773 gallons	CT/RCxPeak Hour/BF
Required Water Storage (CT or demand)	91,000 gallons	Vg = volume in gallons
Estimate of Min Platform Size (3' clearance around)	1,374 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
<b>Water Treatment Plant Requirements*</b>		
Water Quality	poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Residential Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Water Service Type	0	Static Water Service Line
	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service w/GPS (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	4.3 acres	
Organic Loading Based Size check	2.2 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	250.0	
Hydraulic Loading Based Size	2.9 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1
Two cell lagoon, combined acreage	2.9 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Mekoryuk**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	117	\$26,342.77	\$3,082,104
2	Sewage collection mains or services (gravity or force), buried	LF	5,900	\$293.55	\$1,731,936
3	Sewage collection mains or services (gravity or force), above ground	LF	12,400	\$201.57	\$2,499,422
4	Sewage lift station	EA	1	\$746,130.80	\$746,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	23,700	\$328.77	\$7,791,873
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	1,200	\$513.76	\$616,510
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$18,427,991**



# O&M Cost Estimate Piped Water & Sewer System

2/19/2016

**Community:** Mekoryuk

## General Community Data

Current population	210 persons
Average number of people per house	2.2
Service Connections	
Number of houses	97
Number of public/commerical buildings	19
Number of schools	1
Total number of service connections	117
Burdened labor rate	\$22 hr
Electricity cost (Public facility)	\$0.42 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	22100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	1200 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	125,000 gallons
Length of water line to/ from tank	30 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	14850 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Number of service line circ pumps	
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	9500 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	5100 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

2/19/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Service line circulation	34	kWh/month/service
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

2/19/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$45,760
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$368 /month	\$2,941.75
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$766 /month	\$6,128.64
Water storage tank	\$114 /month	\$912.00
Water storage tank line	\$7 /month	\$52.53
Water mains	\$3,250 /month	\$26,003
Service lines	\$1,921 /month	\$15,365
<u>Wastewater system</u>		
Sewer mains	\$2,079 /month	\$16,635
Service lines	\$1,921 /month	\$15,365
Lift/pump station buildings	\$306 /month	\$2,451.46
Force main to lagoon	\$1,116 /month	\$8,930
	Subtotal	\$94,800
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$147 /month	\$1,765
HVAC/hydronic system	\$147 /month	\$1,177
Water treatment	\$67 /month	\$804
Pumps		
Intake or well	\$67 /month	\$804.38
WST circulation	\$57 /month	\$454
Pressure/booster	\$101 /month	\$1,206.58
Main line circulation	\$902 /month	\$7,217
Service line circulation	\$0 /month	\$0.00
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$123 /month	\$1,471
HVAC/hydronic system	\$123 /month	\$981
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$225 /month	\$1,801
Lagoon discharge pump	\$966 /year	\$966
	Subtotal	\$18,600
<b>Other Costs</b>		
Equipment R&R	\$7,958 /year	\$7,958
Miscellaneous materials & supplies	\$4,775 /year	\$4,775
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,700

## Summary

Administration	\$6,000
Labor	\$45,800
Fuel	\$94,800
Electricity	\$18,600
Other	\$18,700
<b>Total</b>	<b>\$184,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 104	97	85%	\$ 102,783
Public/Commerc	\$ 192	19	100%	\$ 43,818
School Service	\$ 4,155	1	100%	\$ 37,398
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 184,000</b>

# Mertarvik, Alaska

## Community Information & Existing Infrastructure

Mertarvik is the new site for the village of Newtok. Newtok is a traditional Yupik Eskimo village of 380 people. Mertarvik is located on the Nelson Island off the coast of Baird Inlet. There will be approx. 92 residential units, 7 commercial/public facilities and one school for a total of 100 services.

Mertarvik is situated on a side of a hill where the elevation difference between the highest point and lowest point of the community is greater than 200 feet. The only existing infrastructure in Mertarvik is the Mertarvik Evacuation Center (MEC) and a mat stabilized road from the boat landing to the MEC building.

The soil in Mertarvik generally consists of approx. 18 inches of peat layer on the surface, and a layer of silt with organics under the layer of peat. Bedrock was encountered from as little as 4 feet to more than 31.5 feet below ground surface.

## Piped System Description

The piped water and gravity sewer system will be a buried system. The water system will consist of approximately 16,700 feet of pipe, and the gravity sewer system approximately 19,200 feet of pipe. The water system will consist of two circulating loops. It is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	32	15	17
<b>Water Storage (gallons)</b>	215,500	-	215,500
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	8.1	-	8.1
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	1,200	-	1,200
Thermosyphon Stabilized Gravel Pad (sf)	2,900	-	2,900
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	16,700	-	16,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	19,200	-	19,200
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	7,500	-	7,500
Gravity Sewer Service Lines (lf)	7,500	-	7,500



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Mertarvik. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs					Village
					Newtok
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	100	\$26,342.77	\$2,634,277
2	Sewage collection mains or services (gravity or vacuum), buried	LF	26,700	\$248.45	\$6,633,553
4	Sewage lift station	EA	1	\$ 662,130.80	\$ 662,131
10	Sewage lagoon, barrow, local material	Acre	8.1	\$682,797.07	\$5,530,656
13	Water distribution, mains or services, buried	LF	24,200	\$276.80	\$6,698,458
14	Water storage tank, no foundation	Gal	215,500	\$2.52	\$542,212
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
18	Foundation - freeze back piles	SF	1,200	\$426.48	\$511,777
19	Foundation - thermosyphen stabilized gravel pad	SF	2,900	\$261.95	\$759,659
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$26,056,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$31,112,200</b>
28	Electrical Service Upgrades	EA	100	\$5,500	\$550,000
<b>Subtotal</b>					<b>\$31,662,200</b>
29	Construction Contingency (15%)	LS	1	\$4,749,300	\$4,749,300
30	Design & Construction Administration Services (20%)	LS	1	\$6,332,400	\$6,332,400
<b>Total</b>					<b>\$42,743,900</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$33,300
Fuel	\$103,000
Electricity	\$28,900
Other (R&R, Training, etc.)	\$19,200
<b>Total</b>	<b>\$190,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Mertarvik are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 116	92	85%	<b>\$ 108,691</b>
Public/Commercial Service	\$ 347	7	100%	<b>\$ 29,188</b>
School Service	\$ 5,791	1	100%	<b>\$ 52,121</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 190,000</b>

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

9/9/2016  
Mertarvik

**Existing Community & System Data**

2015 Population	380
2015 Number of Services	100
HITS Database (E1 & H1-H7)	92
DCED Mapping Commerical/Public Facilities/School	8
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Good
Water Storage Tank	0
Water Treatment Capacity	15
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input checked="" type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<input checked="" type="checkbox"/>	19200	16700
Gravity Sewer Main	<input checked="" type="checkbox"/>	19200	
Pressure Sewer Main			
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community

Mertarvik

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	32	
Req Water Storage (gallons) (less existing)	215,500	2,900 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	8.1	

Quantity Notes

Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200
	Thermosyphon stabilized gravel pad (sf)	2,900
Water Distribution System		
	Circulating Water Main with Pitorifices (lf)	16,700
Wastewater Collection System		
	Sewer Main with Glycol Heat Trace (lf)	19,200
	Lift Stations for Gravity Sewer	1
Water & Sewer Service Lines		
	Circulating Water Service Lines (lf)	7,500
	Gravity Sewer Service Lines (lf)	7,500

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	32	15	17
Water Storage (gallons)	215,500	-	215,500
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	8.1	-	8.1
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	1,200	-	1,200
Thermosyphon stabilized gravel pad (sf)	2,900	-	2,900
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	16,700	-	16,700
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	19,200	-	19,200
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	7,500	-	7,500
Gravity Sewer Service Lines (lf)	7,500	-	7,500

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		9/9/2016 Mertarvik	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	380 people	2015 ADOL	
2015 Number of Services	100 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	464 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	15 gpm		
Average Day (ADD)	23,184 gpd	50 gallons per Capita	
Max Day (MDD)	46,367 gpd	2 x ADD	
Peak Hour	97 gpm	3 x MDD	
Treatment Capacity	32 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	32 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	- gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	46,367 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	139,102 gallons	3 days x DO	
Water Storage Tank Volume	215,469 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$L \times (5.057) \times (e^{-(0.0693T)}) \times (e^{(0.361PH)}) \times (e^{(0.113RC)})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	164,255 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	215,500 gallons		
Required Additional Storage	215,500 gallons	0	
Estimate of Min Platform Size (3' clearance around)	2,900 sf	$D = 0.103 \times Vg^{(1/2)}$ H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Good	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	800 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0		Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0		Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0		Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0		Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)	Gravity Service Line
Pressure Sewer Main	0		Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	3.9 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
	336.3		
Hydraulic Loading Based Size	8.1 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	8.1 acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Newtok**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	100	\$26,342.77	\$2,634,277
2	Sewage collection mains or services (gravity or vacuum), buried	LF	26,700	\$248.45	\$6,633,553
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	8.1	\$682,797.07	\$5,530,656
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	24,200	\$276.80	\$6,698,458
14	Water storage tank, no foundation	Gal	215,500	\$2.52	\$542,212
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,200	\$426.48	\$511,777
19	Foundation - thermosyphen stablized gravel pad	SF	2,900	\$261.95	\$759,659
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$26,056,095**

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

**Community:** Mertarvik

## General Community Data

Current population	380 persons
Average number of people per house	4.1
Service Connections	
Number of houses	92
Number of public/commerical buildings	7
Number of schools	1
Total number of service connections	100
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.40 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	155 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	1200 sf
Raw water quality (Good or Poor)	Good

### Water Storage

Size of tank(s)	215,500 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	16700 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	0
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	100
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	19200 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	5
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	3200 ft
Force main heated for freeze protection (Yes or No)	No
Location of force main (Above ground (AG) or Buried)	Buried
Septic system discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Septic system discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$368 /month	\$2,941.75
Raw water line	\$20 /month	\$244.27
Raw water heat addition	\$1,386 /month	\$16,634.88
Water storage tank	\$197 /month	\$1,572.29
Water storage tank line	\$13 /month	\$157.59
Water mains	\$2,193 /month	\$26,318
Service lines	\$985 /month	\$11,820
<u>Wastewater system</u>		
Sewer mains	\$2,521 /month	\$30,258
Service lines	\$985 /month	\$11,820
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to septic system	\$0 /month	\$0
	Subtotal	\$103,000
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$140 /month	\$1,681
HVAC/hydronic system	\$140 /month	\$1,681
Water treatment	\$23 /month	\$277
Pumps		
Intake or well	\$116 /month	\$1,386.24
WST circulation	\$54 /month	\$432
Pressure/booster	\$173 /month	\$2,079.36
Main line circulation	\$859 /month	\$10,310
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$58 /month	\$700
HVAC/hydronic system	\$58 /month	\$467
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$151 /month	\$1,808.14
Sewer/force main glycol circulation	\$536 /month	\$6,432
Septic system discharge pump	\$1,664 /year	\$1,664
	Subtotal	\$28,900
<b>Other Costs</b>		
Equipment R&R	\$8,259 /year	\$8,259
Miscellaneous materials & supplies	\$4,955 /year	\$4,955
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$19,200


## Summary

Administration	\$6,000
Labor	\$33,300
Fuel	\$103,000
Electricity	\$28,900
Other	\$19,200
<b>Total</b>	<b>\$190,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 116	92	85%	\$ 108,691
Public/Commerc	\$ 347.48	7	100%	\$ 29,188
School Service	\$ 5,791.27	1	100%	\$ 52,121
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 190,000</b>



File: J:\Jobsdata\31303.00 View - Assessment of Unserved Communities\00\_CADD\01 Working Set\01 Civil\31303.00 Mertarvik.dwg



# Napakiak, Alaska

## Community Information & Existing Infrastructure

Napakiak is a Yupik Eskimo community of 387 people located on the north bank of the Kuskokwim River, 15 miles southwest of Bethel. There are 98 residential units, 15 commercial/public facilities and one school for a total of 114 services. The existing water and sewer services provided in Napakiak consist of a self-haul system and honey buckets. The school and washeteria have piped sewer that discharges into the school sewage lagoon. The existing water and sewer infrastructure consists of the following:

- Well Water – 20 gpm transfer pump
- Treated Water Storage – 5,000 gallons
- Water Treatment Plant – 480 SF, built in 1986
- Water Treatment – Potassium permanganate, greensand filter, chlorination, and fluoridation
- Sewage Lagoon – Single Cell, 0.9 acres

Soils around Napakiak consist of poorly drained silt and muck on top of fine silt and black mud. There is shallow groundwater in the area.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The west water system will consist of approximately 9,300 feet of pipe, and the east water system will consist of approximately 8,000 feet of pipe. The pressure sewer system will consist of approximately 14,400 feet of pipe. The west water system will consist of two circulating loops, and the east side will consist of a single loop. The pressure sewer system would require two sewer main lift stations, individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, two new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	33	20	13
<b>Water Storage (gallons)</b>	218,900	5,000	213,900
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,400	-	2,400
<b>Sewage Lagoon Size (acre)</b>	8.2	0.9	7.3
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	5,280	-	5,280
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,300	-	17,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,400	-	14,400
Individual Grinder Pump Stations (GPS) (ea)	114	-	114
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,600	-	8,600
Pressure Sewer Service Lines (lf)	8,600	-	8,600

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Napakiak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village
					Napakiak
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	114	\$26,403.25	\$3,009,971
3	Sewage collection mains or services (gravity or force), above ground	LF	23,000	\$198.84	\$4,573,319
4	Sewage lift station	EA	2	\$ 579,896.59	\$ 1,159,793
10	Sewage lagoon, barrow, local material	Acre	7	\$692,456.93	\$5,054,936
12	Water distribution, mains or services, above ground	LF	25,900	\$330.44	\$8,558,286
14	Water storage tank, no foundation	Gal	215,100	\$2.57	\$551,936
15	Water treatment plant, no foundation	SF	2,400	\$1,611.05	\$3,866,511
18	Foundation - freeze back piles	SF	5,280	\$309.69	\$1,635,146
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$28,563,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$34,105,700</b>
27	Individual Grinder Pump Stations	EA	114	\$30,000	\$3,420,000
28	Electrical Service Upgrades	EA	114	\$5,500	\$627,000
<b>Subtotal</b>					<b>\$38,152,700</b>
29	Construction Contingency (15%)	LS	1	\$5,722,900	\$5,722,900
30	Design & Construction Administration Services (20%)	LS	1	\$7,630,500	\$7,630,500
<b>Total</b>					<b>\$51,506,100</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$20,800
Fuel	\$91,000
Electricity	\$46,600
Other (R&R, Training, etc.)	\$18,700
<b>Total</b>	<b>\$183,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Napakiak are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 116	98	85%	<b>\$ 116,100</b>
Public/Commercial Service	\$ 139	15	100%	<b>\$ 25,088</b>
School Service	\$ 4,646	1	100%	<b>\$ 41,813</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 183,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Napakiak.dwg



LEGEND:

- PROPOSED WATER MAIN
- PROPOSED SEWER/FORCE MAIN
- PROPOSED LIFT STATION
- EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP
- EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP
- HOME ADDITION FROM HITS MAP



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
NAPAKIAK

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
21



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/23/2016  
 Community Napakiak  
 Input

**Existing Community & System Data**

2015 Population	387
2015 Number of Services	114
HITS Database (E1 & H1-H7)	98
DCED Mapping Commerical/Public Facilities/School	16
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	5000
Water Treatment Capacity	20
Existing Sewage Lagoon Size	0.9

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	14400	17300
Gravity Sewer Main			
Pressure Sewer Main	x	14400	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Napakiak

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	33	
Req Water Storage (gallons) (less existing)	213,900	2,880 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	2,400 sf
Req Sewage Lagoon Size (acre) (less existing)	7.3	

	Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf) 2,400	
Water Distribution System	Circulating Water Main with Pitorifices (lf) 17,300	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf) 14,400 Individual Grinder Pump Stations (GPS) (ea) 114	
Water & Sewer Service Lines	Circulating Water Service Lines (lf) 8,600 Pressure Sewer Service Lines (lf) 8,600	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	33	20	13
Water Storage (gallons)	218,900	5,000	213,900
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	-	2,400
Sewage Lagoon Size (acre)	8.2	0.9	7.3
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	5,280	-	5,280
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,300	-	17,300
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,400	-	14,400
Individual Grinder Pump Stations (GPS) (ea)	114	-	114
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,600	-	8,600
Pressure Sewer Service Lines (lf)	8,600	-	8,600

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/23/2016	
Community	Napakiak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	387 people	2015 ADOL
2015 Number of Services	114 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	472 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	23,611 gpd	50 gallons per Capita
Max Day (MDD)	47,221 gpd	2 x ADD
Peak Hour	98 gpm	3 x MDD
Treatment Capacity	33 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	33 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	5,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	47,221 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	141,664 gallons	3 days x DO
Water Storage Tank Volume	218,885 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	167,281 gallons	CT/RCxPeak Hour/BF
Required Water Storage	218,900 gallons	
Required Additional Storage	213,900 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,880 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.9 acres	
Organic Loading Based Size	4.0 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	339.4	
Hydraulic Loading Based Size	8.2 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	8.2 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Napakiak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	114	\$26,403.25	\$3,009,971
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	23,000	\$198.84	\$4,573,319
4	Sewage lift station	EA	2	\$579,896.59	\$1,159,793
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	7.3	\$692,456.93	\$5,054,936
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	25,900	\$330.44	\$8,558,286
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	215,100	\$2.57	\$551,936
15	Water treatment plant, no foundation	SF	2,400	\$1,611.05	\$3,866,511
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	5,280	\$309.69	\$1,635,146
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$28,563,495**



# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Napakiak

## General Community Data

Current population	387	persons
Average number of people per house	3.9	
Service Connections		
Number of houses	98	
Number of public/commerical buildings	15	
Number of schools	1	
Total number of service connections	114	
Burdened labor rate	\$10	hr
Electricity cost (Public facility)	\$0.61	kWh
Electricity cost (Residential service)	\$0.29	kWh
Cost per gallon for heating oil	\$5.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	860 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	2880 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	218,900 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	3
Total length of Water Main	17300 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	24
Number of facilities served by lift/pump station #2	114
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	14400 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	750 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$20,800
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$735 /month	\$5,883.49
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,176 /month	\$9,411.84
Water storage tank	\$166 /month	\$1,330.91
Water storage tank line	\$0 /month	\$0.00
Water mains	\$3,156 /month	\$25,244
Service lines	\$1,560 /month	\$12,476
<u>Wastewater system</u>		
Sewer mains	\$2,627 /month	\$21,012
Service lines	\$1,560 /month	\$12,476
Lift/pump station buildings	\$255 /month	\$2,042.88
Force main to lagoon	\$137 /month	\$1,094
	Subtotal	\$91,000
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$513 /month	\$6,152
HVAC/hydronic system	\$513 /month	\$4,102
Water treatment	\$179 /month	\$2,153
Pumps		
Intake or well	\$179 /month	\$2,152.96
WST circulation	\$82 /month	\$659
Pressure/booster	\$269 /month	\$3,229.44
Main line circulation	\$1,965 /month	\$15,723
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$178 /month	\$2,136
HVAC/hydronic system	\$178 /month	\$1,424
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$303 /month	\$3,638.06
Sewer/force main glycol circulation	\$327 /month	\$2,616
Lagoon discharge pump	\$2,585 /year	\$2,585
	Subtotal	\$46,600
<b>Other Costs</b>		
Equipment R&R	\$7,920 /year	\$7,920
Miscellaneous materials & supplies	\$4,752 /year	\$4,752
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,700

## Summary

Administration	\$6,000
Labor	\$20,800
Fuel	\$91,000
Electricity	\$46,600
Other	\$18,700
<b>Total</b>	<b>\$183,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 116	98	85%	\$ 116,100
Public/Commerc	\$ 139.38	15	100%	\$ 25,088
School Service	\$ 4,645.85	1	100%	\$ 41,813
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 183,000</b>

# Napaskiak, Alaska

## Community Information & Existing Infrastructure

Napaskiak is a Yupik Eskimo community of 451 people located on the east bank of the Kuskokwim River, along the Napaskiak Slough, 7 miles southeast of Bethel. There are 105 residential units, 22 commercial/public facilities and one school for a total of 128 services. Existing water service provided in Napaskiak consists of a self-haul system from either the primary or secondary water plant dispensing points. The existing sewer service consists of honey buckets that are disposed of in honey bucket dump stations located throughout the village. The existing water and sewer infrastructure consists of the following:

- Well Water – 40 gpm
- Primary Water Storage – 22,000 gallons,  
Secondary Water Storage – 22,000 gallons
- Primary Water Treatment Plant – 1120 SF,  
built in 1978, Upgraded in 2004
- Secondary Water Treatment Plant – 640  
SF, built in 1994, Upgraded in 2010
- Water Treatment – Potassium  
permanganate, filtration, chlorination
- Sewage Lagoon – Two Cell, 2.8 acres

Soils around Napaskiak consist of organic mat underlain by silt and sandy silt. There is a permafrost layer approximately 2-6 feet below ground. Groundwater is present 4.5 feet below surface.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The west water system will consist of approximately 9,700 feet of pipe with two circulating loops. The east water system will consist of approximately 8,500 feet of pipe with a single circulating loop. The pressure sewer system will consist of approximately 12,800 feet of pipe. The pressure sewer system would require one additional sewer main lift station, individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility (West side) and a new 800 sf facility (East side) is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	38	40	-
<b>Water Storage (gallons)</b>	250,100	44,000	206,100
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,000	-	2,000
<b>Sewage Lagoon Size (acre)</b>	9.6	2.8	6.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	4,780	-	4,780
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	18,200	-	18,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,800	-	12,800
Individual Grinder Pump Stations (GPS) (ea)	128	-	128
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,600	-	9,600
Pressure Sewer Service Lines (lf)	9,600	-	9,600



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Napaskiak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Napaskiak	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	128	\$26,403.25	\$3,379,616
3	Sewage collection mains or services (gravity or force), above ground	LF	22,400	\$198.96	\$4,456,791
4	Sewage lift station	EA	1	\$ 678,792.59	\$ 678,793
10	Sewage lagoon, barrow, local material	Acre	7	\$694,724.45	\$4,724,126
12	Water distribution, mains or services, above ground	LF	27,800	\$330.21	\$9,179,951
14	Water storage tank, no foundation	Gal	206,100	\$2.60	\$535,497
15	Water treatment plant, no foundation	SF	2,000	\$1,615.96	\$3,231,912
18	Foundation - freeze back piles	SF	4,780	\$313.57	\$1,498,864
Total Estimated Cost in 2010 dollars (rounded):					<b>\$27,686,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$33,058,500</b>
27	Individual Grinder Pump Stations	EA	128	\$30,000	\$3,840,000
28	Electrical Service Upgrades	EA	128	\$5,500	\$704,000
<b>Subtotal</b>					<b>\$37,602,500</b>
29	Construction Contingency (15%)	LS	1	\$5,640,400	\$5,640,400
30	Design & Construction Administration Services (20%)	LS	1	\$7,520,500	\$7,520,500
<b>Total</b>					<b>\$50,763,400</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$31,200
Fuel	\$149,900
Electricity	\$32,200
Other (R&R, Training, etc.)	\$23,100
<b>Total</b>	<b>\$242,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Napaskiak are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 137	105	85%	<b>\$ 147,179</b>
Public/Commercial Service	\$ 172	22	100%	<b>\$ 45,349</b>
School Service	\$ 5,497	1	100%	<b>\$ 49,472</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 242,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Napaskiak.dwg



**LEGEND:**

PROPOSED WATER MAIN	
PROPOSED SEWER/FORCE MAIN	
PROPOSED LIFT STATION	
EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP	
EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP	
HOME ADDITION FROM HITS MAP	

**CRW**  
ENGINEERING GROUP, LLC

PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF UNSERVED COMMUNITIES <b>NAPASKIAK</b>	DATE MAR 2015
	SCALE GRAPHIC
	FIGURE 22



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 3/25/2016  
Community Napaskiak  
Input

**Existing Community & System Data**

2015 Population	451
2015 Number of Services	128
HITS Database (E1 & H1-H7)	105
DCED Mapping Commercial/Public Facilities/School	23
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	44000
Water Treatment Capacity	40
Existing Sewage Lagoon Size	2.8

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	12800	18200
Gravity Sewer Main			
Pressure Sewer Main	x	12800	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Napaskiak

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	38		
Req Water Storage (gallons) (less existing)	206,100	2,780	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,000	2,000	sf
Req Sewage Lagoon Size (acre) (less existing)	6.8		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	2,000	
Water Distribution System			
	Circulating Water Main with Pitorifices (lf)	18,200	
Wastewater Collection System			
	Sewer Main with Glycol Heat Trace (lf)	12,800	
	Individual Grinder Pump Stations (GPS) (ea)	128	
Water & Sewer Service Lines			
	Circulating Water Service Lines (lf)	9,600	
	Pressure Sewer Service Lines (lf)	9,600	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	38	40	-
Water Storage (gallons)	250,100	44,000	206,100
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,000	-	2,000
Sewage Lagoon Size (acre)	9.6	2.8	6.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	4,780	-	4,780
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	18,200	-	18,200
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,800	-	12,800
Individual Grinder Pump Stations (GPS) (ea)	128	-	128
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,600	-	9,600
Pressure Sewer Service Lines (lf)	9,600	-	9,600



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/25/2016	
Community	Napaskiak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	451 people	2015 ADOL
2015 Number of Services	128 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	550 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	40 gpm	
Average Day (ADD)	27,515 gpd	50 gallons per Capita
Max Day (MDD)	55,031 gpd	2 x ADD
Peak Hour	115 gpm	3 x MDD
Treatment Capacity	38 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	38 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	44,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	55,031 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	165,092 gallons	3 days x DO
Water Storage Tank Volume	250,122 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	194,945 gallons	CT/RCxPeak Hour/BF
Required Water Storage	250,100 gallons	
Required Additional Storage	206,100 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,780 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	2.8 acres	
Organic Loading Based Size check	4.7 acres 366.4	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	9.6 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	9.6 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village  
Napaskiak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	128	\$26,403.25	\$3,379,616
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	22,400	\$198.96	\$4,456,791
4	Sewage lift station	EA	1	\$678,792.59	\$678,793
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	6.8	\$694,724.45	\$4,724,126
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	27,800	\$330.21	\$9,179,951
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	206,100	\$2.60	\$535,497
15	Water treatment plant, no foundation	SF	2,000	\$1,615.96	\$3,231,912
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	4,780	\$313.57	\$1,498,864
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$27,685,550**

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

**Community:** Napaskiak

### General Community Data

Current population	451	persons
Average number of people per house	4.3	
Service Connections		
Number of houses	105	
Number of public/commerical buildings	22	
Number of schools	1	
Total number of service connections	128	
Burdened labor rate	\$15	hr
Electricity cost (Public facility)	\$0.36	kWh
Electricity cost (Residential service)	\$0.34	kWh
Cost per gallon for heating oil	\$7.65	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	200 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	3760 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	250,100 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	3
Total length of Water Main	18200 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	67
Number of facilities served by existing lift/pump station	128
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	12800 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	1700 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/13/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$31,200
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,469 /month	\$11,752.28
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$2,098 /month	\$16,781.53
Water storage tank	\$291 /month	\$2,326.53
Water storage tank line	\$0 /month	\$0.00
Water mains	\$5,079 /month	\$40,633
Service lines	\$2,679 /month	\$21,433
<u>Wastewater system</u>		
Sewer mains	\$3,572 /month	\$28,577
Service lines	\$2,679 /month	\$21,433
Lift/pump station buildings	\$391 /month	\$3,125.61
Force main to lagoon	\$474 /month	\$3,795
	Subtotal	\$149,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$395 /month	\$4,740
HVAC/hydronic system	\$395 /month	\$3,160
Water treatment	\$123 /month	\$1,481
Pumps		
Intake or well	\$123 /month	\$1,480.72
WST circulation	\$49 /month	\$389
Pressure/booster	\$185 /month	\$2,221.08
Main line circulation	\$1,160 /month	\$9,279
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$105 /month	\$1,261
HVAC/hydronic system	\$105 /month	\$840
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$275 /month	\$3,299.90
Sewer/force main glycol circulation	\$289 /month	\$2,316
Lagoon discharge pump	\$1,778 /year	\$1,778
	Subtotal	\$32,200
<b>Other Costs</b>		
Equipment R&R	\$10,665 /year	\$10,665
Miscellaneous materials & supplies	\$6,399 /year	\$6,399
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$23,100

## Summary

Administration	\$6,000
Labor	\$31,200
Fuel	\$149,900
Electricity	\$32,200
Other	\$23,100
<b>Total</b>	<b>\$242,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 137	105	85%	\$ 147,179
Public/Commerc	\$ 171.78	22	100%	\$ 45,349
School Service	\$ 5,496.88	1	100%	\$ 49,472
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 242,000</b>

# Nightmute, Alaska

---

## Community Information & Existing Infrastructure

Nightmute is a Yupik Eskimo community of 274 people located on the Nelson Island, in western Alaska. There are 47 residential units, 28 commercial/public facilities and one school for a total of 76 services. The existing water service provided in Nightmute consists of self-haul system from the central watering point attached to the water treatment plant, and a flush tank and haul system for sewer. The school operates a separate water and sewer system which includes a water supply well, water and wastewater piping and fixtures, three lift stations, wastewater discharging piping, and a sewage lagoon. The existing water and sewer infrastructure consists of the following:

- Summer Seasonal Spring – 25 gpm peak flow
- Treated Water Storage – 880 gallons
- Water Treatment Plant – 480 SF, built in 1986
- Water Treatment – Filtration and chlorination

The community currently utilizes a tundra pond approximately 5.6 acres to dispose of the community's waste. While not uncommon in the region, tundra ponds can be extremely difficult to quantify, properly maintain, and permit. For the purposes of this assessment, the tundra pond is not included as an existing "usable" facility.

Soils around Nightmute consist of thin layer of soft, saturated silt occasionally overlain by organic silt 1 foot thick. Permafrost is present approximately 3.5 – 14 feet deep. There is groundwater perched on underlying permafrost near ground surface.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 8,000 feet of pipe, and the pressure sewer system approximately 6,900 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require four sewer main lift stations, individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. The existing water storage tank is not sufficient to meet CT requirements (118,500 gallons).

The existing water source currently produces enough water to meet the demand of a piped system; however, the water source is seasonal and only provides water during the summer. For the purposes of this assessment, a new well is included to provide year round water to the community. Since the system would rely on both surface water and groundwater sources, water storage would still be subject to meeting CT.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	23	25	-
Water Storage (gallons)	163,700	880	162,820
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	5.8	-	5.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	3,460	-	3,460
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	8,000	-	8,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,900	-	6,900
Individual Grinder Pump Stations (GPS) (ea)	76	-	76
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,700	-	5,700
Pressure Sewer Service Lines (lf)	5,700	-	5,700

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Nightmute. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village
					Nightmute
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	76	\$26,342.77	\$2,002,051
3	Sewage collection mains or services (gravity or force), above ground	LF	12,600	\$201.39	\$2,537,532
10	Sewage lagoon, barrow, local material	Acre	6	\$709,459.65	\$4,114,866
12	Water distribution, mains or services, above ground	LF	13,700	\$332.29	\$4,552,365
14	Water storage tank, no foundation	Gal	162,820	\$3.13	\$509,024
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
18	Foundation - freeze back piles	SF	3,460	\$328.53	\$1,136,730
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$16,966,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$20,258,300</b>
27	Individual Grinder Pump Stations	EA	76	\$30,000	\$2,280,000
28	Electrical Service Upgrades	EA	76	\$5,500	\$418,000
Subtotal					<b>\$22,956,300</b>
29	Construction Contingency (15%)	LS	1	\$3,443,400	\$3,443,400
30	Design & Construction Administration Services (20%)	LS	1	\$4,591,300	\$4,591,300
Total					<b>\$30,991,000</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$41,600
Fuel	\$86,400
Electricity	\$12,100
Other (R&R, Training, etc.)	\$17,200
<b>Total</b>	<b>\$163,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Nightmute are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 140	47	85%	<b>\$ 67,132</b>
Public/Commercial Service	\$ 154	28	100%	<b>\$ 51,757</b>
School Service	\$ 4,901	1	100%	<b>\$ 44,111</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 163,000</b>



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

3/25/2016  
Nightmute

**Existing Community & System Data**

2015 Population	274
2015 Number of Services	76
HITS Database (E1 & H1-H7)	47
DCED Mapping Commerical/Public Facilities/School	29
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	880
Water Treatment Capacity	25
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	6900	8000
Gravity Sewer Main			
Pressure Sewer Main	x	6900	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
Nightmute

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	23	
Req Water Storage (gallons) (less existing)	162,820	2,260 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	5.8	

	Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf) 1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf) 8,000	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf) 6,900 Individual Grinder Pump Stations (GPS) (ea) 76	
Water & Sewer Service Lines	Circulating Water Service Lines (lf) 5,700 Pressure Sewer Service Lines (lf) 5,700	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	23	25	-
Water Storage (gallons)	163,700	880	162,820
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	5.8	-	5.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	3,460	-	3,460
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	8,000	-	8,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,900	-	6,900
Individual Grinder Pump Stations (GPS) (ea)	76	-	76
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,700	-	5,700
Pressure Sewer Service Lines (lf)	5,700	-	5,700

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	3/25/2016	
Community	Nightmute	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	274 people	2015 ADOL
2015 Number of Services	76 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	334 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	25 gpm	
Average Day (ADD)	16,717 gpd	50 gallons per Capita
Max Day (MDD)	33,433 gpd	2 x ADD
Peak Hour	70 gpm	3 x MDD
Treatment Capacity	23 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	SW	
Required Capacity	23 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	880 gallons	
<u>Demand Based Volume (if source is SW)</u>	Check Min CT Requirements	
Daily Operation (DO) (gallons)	33,433 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	100,300 gallons	3 days x DO
Water Storage Tank Volume	163,733 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	118,437 gallons	CT/RCxPeak Hour/BF
Required Water Storage	163,700 gallons	
Required Additional Storage	162,820 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,260 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size	2.8 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	285.6	
Hydraulic Loading Based Size	5.8 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	5.8 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Nightmute**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	76	\$26,342.77	\$2,002,051
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	12,600	\$201.39	\$2,537,532
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	5.8	\$709,459.65	\$4,114,866
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	13,700	\$332.29	\$4,552,365
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	162,820	\$3.13	\$509,024
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	3,460	\$328.53	\$1,136,730
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$16,966,180**

# O&M Cost Estimate

## Piped Water & Sewer System

4/26/2016

**Community:** Nightmute

### General Community Data

Current population	274	persons
Average number of people per house	5.8	
Service Connections		
Number of houses	47	
Number of public/commerical buildings	28	
Number of schools	1	
Total number of service connections	76	
Burdened labor rate	\$25	hr
Electricity cost (Public facility)	\$0.34	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$8.50	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	1150 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	1680 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	163,700 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	8000 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	6900 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	915 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate Piped Water & Sewer System

4/26/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

4/26/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$41,600
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$729 /month	\$5,834.47
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,416 /month	\$11,328.26
Water storage tank	\$212 /month	\$1,692.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$2,481 /month	\$19,845
Service lines	\$1,767 /month	\$14,140
<u>Wastewater system</u>		
Sewer mains	\$2,140 /month	\$17,116
Service lines	\$1,767 /month	\$14,140
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$284 /month	\$2,270
	Subtotal	\$86,400
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$167 /month	\$2,000
HVAC/hydronic system	\$167 /month	\$1,334
Water treatment	\$71 /month	\$850
Pumps		
Intake or well	\$71 /month	\$849.62
WST circulation	\$46 /month	\$367
Pressure/booster	\$106 /month	\$1,274.43
Main line circulation	\$365 /month	\$2,921
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$182 /month	\$1,458
Lagoon discharge pump	\$1,020 /year	\$1,020
	Subtotal	\$12,100
<b>Other Costs</b>		
Equipment R&R	\$7,005 /year	\$7,005
Miscellaneous materials & supplies	\$4,203 /year	\$4,203
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$17,200


## Summary

Administration	\$6,000
Labor	\$41,600
Fuel	\$86,400
Electricity	\$12,100
Other	\$17,200
<b>Total</b>	<b>\$163,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 140	47	85%	\$ 67,132
Public/Commerc	\$ 154.04	28	100%	\$ 51,757
School Service	\$ 4,901.20	1	100%	\$ 44,111
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 163,000</b>



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Nightmute.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
NIGHTMUTE

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
23



# Northway Village, Alaska

## Community Information & Existing Infrastructure

Northway Village is an Athabascan community of 112 people located between Nabesna River and Skate Lake, on a 9-mile spur road off of the Alaska Highway. There are 34 residential units and 3 commercial/public facilities for a total of 37 services. The existing water and sewer services provided in Northway Village consist of self-haul system and honey buckets. The washeteria/clinic/water treatment plant and the water/sewer truck haul garage have piped water and sewer services. The existing water and sewer infrastructure consists of the following:

- Well – 30 gpm capacity
- Treated Water Storage – 3,800 gallons
- Water Treatment Plant/Washeteria – 2,270 SF, built in 1997
- Water Treatment – Potassium permanganate, polymer, and greensand filter
- Northway Village Sewage Lagoon – Two Cell, 1.84 acres

The soil conditions around Northway Village consist of an organic mat 1.5-3 feet deep with groundwater around 4 feet. Permafrost present in some areas as shallow as 2 feet deep.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 8,950 feet of pipe, and the pressure sewer system approximately 5,600 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	9	30	-
<b>Water Storage (gallons)</b>	84,700	3,800	80,900
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	2.4	1.8	0.5
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,450	-	2,450
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,000	-	9,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,600	-	5,600
Individual Grinder Pump Stations (GPS) (ea)	37	-	37
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,800	-	2,800
Pressure Sewer Service Lines (lf)	2,800	-	2,800



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Northway Village. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Northway	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	37	\$26,191.57	\$969,088
3	Sewage collection mains or services (gravity or force), above ground	LF	8,400	\$182.10	\$1,529,638
10	Sewage lagoon, barrow, local material	Acre	0.5	\$674,757.25	\$337,379
12	Water distribution, mains or services, above ground	LF	11,800	\$316.36	\$3,733,036
14	Water storage tank, no foundation	Gal	80,900	\$1.81	\$146,129
15	Water treatment plant, no foundation	SF	1,200	\$1,495.47	\$1,794,569
18	Foundation - freeze back piles	SF	2,450	\$246.64	\$604,273
Total Estimated Cost in 2010 dollars (rounded):					<b>\$9,114,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$10,882,600</b>
27	Individual Grinder Pump Stations	EA	37	\$30,000	\$1,110,000
28	Electrical Service Upgrades	EA	37	\$5,500	\$203,500
Subtotal					<b>\$12,196,100</b>
29	Construction Contingency (15%)	LS	1	\$1,829,400	\$1,829,400
30	Design & Construction Administration Services (20%)	LS	1	\$2,439,200	\$2,439,200
Total					<b>\$16,464,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$22,500
Fuel	\$32,600
Electricity	\$16,200
Other (R&R, Training, etc.)	\$11,700
<b>Total</b>	<b>\$89,000</b>

VSW - Unserved Communities Project  
Northway Village Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Northway Village are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 204	34	85%	\$ 70,662
Public/Commercial Service	\$ 509	3	100%	\$ 18,338
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 89,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Northway Village.dwg



**LEGEND:**

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



EXISTING PUBLIC STRUCTURE SHOWN ON  
DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN  
ON DCRA MAP



HOME ADDITION FROM HITS MAP



PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
NORTHWAY VILLAGE

DATE  
MAR 2015

SCALE  
GRAPHIC

FIGURE  
24



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/18/2016  
Northway Village

**Existing Community & System Data**

2015 Population	112
2015 Number of Services	37
HITS Database (E1 & H1-H7)	34
DCED Mapping Commerical/Public Facilities/School	3
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	3800
Water Treatment Capacity	30
Existing Sewage Lagoon Size	1.84

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	5600	8950
Gravity Sewer Main			
Pressure Sewer Main	x	5600	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Northway Village

**Output for Cost Model (calculated)**

		Foundation Size	
Water Treatment Capacity (gpm)	9		
Req Water Storage (gallons) (less existing)	80,900	1,250	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	0.5		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	9,000	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	5,600	
	Individual Grinder Pump Stations (GPS) (ea)	37	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	2,800	
	Pressure Sewer Service Lines (lf)	2,800	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	9	30.0	-
Water Storage (gallons)	84,700	3,800	80,900
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	2.4	1.8	0.5
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,450	-	2,450
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,000	-	9,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,600	-	5,600
Individual Grinder Pump Stations (GPS) (ea)	37	-	37
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,800	-	2,800
Pressure Sewer Service Lines (lf)	2,800	-	2,800



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	4/18/2016	
Community	Northway Village	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	112 people	2015 ADOL
2015 Number of Services	37 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	137 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	30 gpm	
Average Day (ADD)	6,833 gpd	50 gallons per Capita
Max Day (MDD)	13,666 gpd	2 x ADD
Peak Hour	28 gpm	3 x MDD
Treatment Capacity	9 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	9 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	3,800 gallons	
<u>Demand Based Volume (if source is GW)</u>	Applicable	
Daily Operation (DO) (gallons)	13,666 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	40,998 gallons	3 days x DO
Water Storage Tank Volume	84,665 gallons	DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	48,412 gallons	CT/RCxPeak Hour/BF
Required Water Storage	84,700 gallons	
Required Additional Storage	80,900 gallons	0
Estimate of Min Platform Size (3' clearance around)	1,250 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	1.84 acres	
Organic Loading Based Size	1.2 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	182.6	
Hydraulic Loading Based Size	2.4 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	2.4 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Northway**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	37	\$26,191.57	\$969,088
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	8,400	\$182.10	\$1,529,638
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.5	\$674,757.25	\$337,379
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	11,800	\$316.36	\$3,733,036
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	80,900	\$1.81	\$146,129
15	Water treatment plant, no foundation	SF	1,200	\$1,495.47	\$1,794,569
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	2,450	\$246.64	\$604,273
19	Foundation - thermosyphen stabilized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$9,114,112**

# O&M Cost Estimate

## Piped Water & Sewer System

4/27/2016

**Community:** Northway Village

### General Community Data

Current population	112 persons
Average number of people per house	3.3
Service Connections	
Number of houses	34
Number of public/commerical buildings	3
Number of schools	0
Total number of service connections	37
Burdened labor rate	\$18 hr
Electricity cost (Public facility)	\$0.44 kWh
Electricity cost (Residential service)	\$0.23 kWh
Cost per gallon for heating oil	\$4.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	3470 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	84,700 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	9000 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by existing lift/pump station	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	5600 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	670 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$22,464
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$709 /month	\$5,671.03
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$272 /month	\$2,179.07
Water storage tank	\$51 /month	\$411.98
Water storage tank line	\$0 /month	\$0.00
Water mains	\$1,313 /month	\$10,506
Service lines	\$405 /month	\$3,239
<u>Wastewater system</u>		
Sewer mains	\$817 /month	\$6,537
Service lines	\$405 /month	\$3,239
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$98 /month	\$782
	Subtotal	\$32,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$446 /month	\$5,347
HVAC/hydronic system	\$446 /month	\$3,565
Water treatment	\$37 /month	\$449
Pumps		
Intake or well	\$37 /month	\$449.43
WST circulation	\$59 /month	\$475
Pressure/booster	\$56 /month	\$674.15
Main line circulation	\$473 /month	\$3,780
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$118 /month	\$943
Lagoon discharge pump	\$540 /year	\$540
	Subtotal	\$16,200
<b>Other Costs</b>		
Equipment R&R	\$3,563 /year	\$3,563
Miscellaneous materials & supplies	\$2,138 /year	\$2,138
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$11,700

## Summary

Administration	\$6,000
Labor	\$22,500
Fuel	\$32,600
Electricity	\$16,200
Other	\$11,700
<b>Total</b>	<b>\$89,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 204	34	85%	\$ 70,662
Public/Commerc	\$ 509.39	3	100%	\$ 18,338
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 89,000</b>

# Nunapitchuk, Alaska

## Community Information & Existing Infrastructure

The City of Nunapitchuk is a Yup'ik community of 563 people located along the west and east side of Johnson River. There are 138 residential units, 21 commercial/public facilities and one school for a total of 160 services. Most of the existing water and sewer services provided in Nunapitchuk consist of a Cowater flush, tank and haul system at each building. The existing water and sewer infrastructure consists of the following:

- Groundwater well -20 gpm
- Raw water - High in Fe & Mn
- Direct Filtration Treatment - 20 gpm
- Water Treatment Plant/Washeteria – 2,050 sf, built in 1978
- Treated water storage - 84,500 gallons
- Sewage Lagoon - 3 acres (LKSD lagoon)

Soil conditions in the community consist of ice-rich silts, discontinuous permafrost and a shallow active layer. Any new foundations should consist of driven piles.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 22,500 feet of pipe, and the pressure sewer system approximately 13,700 feet of pipe. Both the west and east side of Nunapitchuk will consist of two circulating water mains, and pressure sewer systems. The pressure sewer system would require individual grinder pump stations at each service, and glycol heat trace for freeze protection. For the purposes of this assessment, a new 1200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment; a new groundwater well will be installed and an additional 220,300 gallons of water storage will be needed (304,800-84,500).

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	48	20	28
<b>Water Storage (gallons)</b>	304,800	84,500	220,300
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	7.7	3.0	4.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	4,150	-	4,150
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	22,500	-	22,500
<b>Wastewater Collection System</b>			
Insulated Sewer Main with Glycol Heat Trace (lf)	13,700	-	13,700
Residential Grinder Pump Stations (GPS) (ea)	160	-	160
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	12,000	-	12,000
Pressure Sewer Service w GPS (lf)	12,000	-	12,000

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Nunapitchuk. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Nunapitchuk	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	160	\$26,403	\$4,224,521
3	Sewage collection mains or services (gravity or force), above ground	LF	25,700	\$198	\$5,097,696
10	Sewage lagoon, barrow, local material	Acre	4.7	\$709,516	\$3,334,727
12	Water distribution, mains or services, above ground	LF	34,500	\$330	\$11,372,141
14	Water storage tank, no foundation	Gal	220,300	\$3	\$561,434
15	Water treatment plant, no foundation	SF	1,200	\$1,636	\$1,962,712
18	Foundation - freeze back piles	SF	4,150	\$320	\$1,327,147
23	Water source - ground water well	EA	1	\$153,597	\$153,597
Total Estimated Cost:					<b>\$28,033,975</b>
Total with Inflation (3% per year for 6 years)					<b>\$33,474,000</b>
27	Residential Grinder Pump Stations	EA	160	\$30,000	\$4,800,000
28	Electrical Service Upgrades	EA	160	\$5,500	\$880,000
<b>Subtotal</b>					<b>\$39,154,000</b>
29	Construction Contingency (15%)	LS	1	\$3,915,400	\$3,915,400
30	Design & Construction Administration Services (20%)	LS	1	\$7,830,800	\$7,830,800
<b>Total</b>					<b>\$50,900,200</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Annual Cost
Administration	\$6,000
Labor	\$31,200
Fuel (Heating)	\$142,000
Electricity	\$30,500
Other (R&R, Training, etc.)	\$22,300
<b>Total</b>	<b>\$232,000</b>


VSW - Unserved Communities Project  
Nunapitchuk Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Nunapitchuk are listed below:

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 102	138	85%	\$ 143,305
Public/Commercial Service	\$ 188	21	100%	\$ 47,463
School Service	\$ 4,581	1	100%	\$ 41,232
Local Capital Contribution				\$ -
<b>Total Revenue</b>				\$ 232,000



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Nunapitchuk.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

2/9/2016  
Nunapitchuk

**Existing Community & System Data**

2015 Population	563
2015 Number of Services	160
HITS Database (E1 & H1-H7)	138
DCED Mapping Commercial/Public Facilities/School	22
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	poor
Water Storage Tank	84500
Water Treatment Capacity	20
Existing Sewage Lagoon Size	3

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	13660	22480
Gravity Sewer Main		0	
Pressure Sewer Main	x	13660	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
**Nunapitchuk**

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	48	
Req Water Storage (gallons) (less existing)	220,300	2,950 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	4.7	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	4,150	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	22,500	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	13,700	
	Residential Grinder Pump Stations (GPS) (ea)	160	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	12,000	
	Pressure Sewer Service w/GPS (lf)	12,000	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	48	20	28
Water Storage (gallons)	304,800	84,500	220,300
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	7.7	3.0	4.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	4,150	-	4,150
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	22,500	-	22,500
<b>Wastewater Collection System</b>			
Insulated Sewer Main with Glycol Heat Trace (lf)	13,700	-	13,700
Residential Grinder Pump Stations (GPS) (ea)	160	-	160
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	12,000	-	12,000
Pressure Sewer Service w GPS (lf)	12,000	-	12,000

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date 2/9/2016		
Community Nunapitchuk		
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	563 people	2015 ADOL
2015 Number of Services	160 services	
Growth Rate (i)		138
2035 Design Population (Capita)		
Growth Rate (i)	1% GW	1%
2035 Design Population (Capita)	687 people	Px(1+i)^n
<b>Water Demand Estimates</b>		
Existing Capacity	20 gpm	
Average Day (ADD)	34,348	50 gallons per Capita
Max Day (MDD)	68,697 gpd	2 x ADD
Peak Hour	143 gpm	3 x MDD
Treatment Capacity	48 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	48 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	84,500 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	68,697 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	206,090 gallons	3 days x DO
Water Storage Tank Volume	304,787 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	LI x (5.057) x (e^-0.0693T)x(e^0.361PH)x(e^0.113RC)
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	243,357 gallons	CT/RCxPeak Hour/BF
Required Water Storage	304,800 gallons	
Required Additional Storage	220,300 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,950 sf	D = 0.103xVg^(1/2) H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Insulated sewer main with glycol heat trace
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Residential Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Water Service Type	0	Static Water Service Line
	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	3 acres	School lagoon only
Organic Loading Based Size check	5.8 acres 409.4	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	7.7 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1
Two cell lagoon, combined acreage	7.7 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Nunaptichuk**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	160	\$26,403.25	\$4,224,521
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	25,700	\$198.35	\$5,097,696
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	4.7	\$709,516.44	\$3,334,727
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	34,500	\$329.63	\$11,372,141
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	220,300	\$2.55	\$561,434
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	4,150	\$319.79	\$1,327,147
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$28,033,975**



# O&M Cost Estimate Piped Water & Sewer System

2/19/2016

**Community:** Nunapitchuk

## General Community Data

Current population	563	persons
Average number of people per house	4.1	
Service Connections		
Number of houses	138	
Number of public buildings	21	
Number of schools	1	
Total number of service connections	160	
Burdened labor rate	\$15	hr
Electricity cost (Public facility)	\$0.35	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW	
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)	Yes	
Location of water line (Above ground (AG) or Buried)	200	

### Water Treatment

Size of water treatment plant building	3250	sf
Raw water quality (Good or Poor)	Poor	

### Water Storage

Size of tank(s)	304,800	gallons
Length of water line to/ from tank	50	ft
Water line heated for freeze protection (Yes or No)	Yes	
Location of water line (Above ground (AG) or Buried)	AG	

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ	
Number of circulating water loops	4	
Total length of Water Main	22480	ft
Water mains heated for freeze protection (Yes or No)	Yes	
Location of the mains (Above ground (AG) or Buried)	AG	
Number of service line circ pumps		
Average service line length	75	ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure	
Number of individual facility pump stations		
Number of community lift/pump stations		
Number of facilities served by lift/pump station #1		
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations		sf
Total length of sewer mains	13660	ft
Sewer mains heated for freeze protection (Yes or No)	Yes	
Number of circulating glycol loops	4	
Location of the mains (Above ground (AG) or Buried)	AG	
Average service line length	75	ft

### Wastewater Treatment / Disposal

Length of force main	1030	ft
Force main heated for freeze protection (Yes or No)	Yes	
Location of force main (Above ground (AG) or Buried)	AG	
Lagoon discharged seasonally with pump (Yes or No)	Yes	

# O&M Cost Estimate

## Piped Water & Sewer System

2/19/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Service line circulation	34	kWh/month/service
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

2/19/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$31,200
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$996 /month	\$7,967.23
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$2,054 /month	\$24,645.89
Water storage tank	\$278 /month	\$2,223.82
Water storage tank line	\$11 /month	\$87.55
Water mains	\$4,920 /month	\$39,363
Service lines	\$2,627 /month	\$21,012
<u>Wastewater system</u>		
Sewer mains	\$2,990 /month	\$23,919
Service lines	\$2,627 /month	\$21,012
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$225 /month	\$1,804
	Subtotal	\$142,000
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$332 /month	\$3,984
HVAC/hydronic system	\$332 /month	\$2,656
Water treatment	\$150 /month	\$1,797
Pumps		
Intake or well	\$150 /month	\$1,797.10
WST circulation	\$47 /month	\$378
Pressure/booster	\$225 /month	\$2,695.64
Main line circulation	\$1,504 /month	\$12,029
Service line circulation	\$0 /month	\$0.00
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$375 /month	\$3,002
Lagoon discharge pump	\$2,158 /year	\$2,158
	Subtotal	\$30,500
<b>Other Costs</b>		
Equipment R&R	\$10,185 /year	\$10,185
Miscellaneous materials & supplies	\$6,111 /year	\$6,111
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$22,300

## Summary

Administration	\$6,000
Labor	\$31,200
Fuel	\$142,000
Electricity	\$30,500
Other	\$22,300
<b>Total</b>	<b>\$232,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 102	138	85%	\$ 143,305
Public/Commerc	\$ 188	21	100%	\$ 47,463
School Service	\$ 4,581	1	100%	\$ 41,232
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 232,000</b>

# Oscarville, Alaska

## Community Information & Existing Infrastructure

Oscarville is a Yupik community of 53 people located on the north bank of the Kuskokwim River, across the river from Napaskiak. There are 16 residential units, 15 commercial/public facilities and one school for a total of 32 services. The existing water and sewer services provided in Oscarville consist of self-haul system from the watering point and honey buckets. The school has a separate water treatment module for potable water, and sewer service that discharges into a timber lined wastewater lagoon. The existing water and sewer infrastructure consists of the following:

- Well – 3.5 gpm transfer pump
- Treated Water Storage – 2,100 gallons
- Watering Point Building – 640 SF, built in 1988
- Water Treatment – Potassium permanganate, greensand filter, chlorine, and fluoride
- Sewage Lagoon – Two Cell, 0.25 acres

Soils in the region consist of stratified deposits of sand, silty sands, and fine silt. Permafrost is locally absent and drainage is fairly good in town, however, much of the surrounding land is poorly drained.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 4,600 feet of pipe, and the pressure sewer system approximately 3,100 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	4	3.5	0.5
<b>Water Storage (gallons)</b>	55,900	2,100	53,800
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	1.1	0.3	0.9
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,090	-	2,090
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	4,600	-	4,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	3,100	-	3,100
Individual Grinder Pump Stations (GPS) (ea)	32	-	32
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,400	-	2,400
Pressure Sewer Service Lines (lf)	2,400	-	2,400



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Oscarville. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village	
				Oscarville	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	32	\$26,403.25	\$844,904
3	Sewage collection mains or services (gravity or force), above ground	LF	5,500	\$213.56	\$1,174,576
10	Sewage lagoon, barrow, local material	Acre	1	\$911,751.90	\$820,577
12	Water distribution, mains or services, above ground	LF	7,000	\$339.19	\$2,374,347
14	Water storage tank, no foundation	Gal	53,800	\$4.78	\$257,310
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
18	Foundation - freeze back piles	SF	2,090	\$366.35	\$765,662
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$8,354,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$9,975,100</b>
27	Individual Grinder Pump Stations	EA	32	\$30,000	\$960,000
28	Electrical Service Upgrades	EA	32	\$5,500	\$176,000
<b>Subtotal</b>					<b>\$11,111,100</b>
29	Construction Contingency (15%)	LS	1	\$1,666,700	\$1,666,700
30	Design & Construction Administration Services (20%)	LS	1	\$2,222,200	\$2,222,200
<b>Total</b>					<b>\$15,000,000</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$28,700
Electricity	\$8,700
Other (R&R, Training, etc.)	\$11,000
<b>Total</b>	<b>\$79,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Oscarville are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 148	16	85%	\$ 24,225
Public/Commercial Service	\$ 156	15	100%	\$ 28,055
School Service	\$ 2,969	1	100%	\$ 26,719
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 79,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Oscarville.dwg



**LEGEND:**

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP



HOME ADDITION FROM HITS MAP



PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
OSCARVILLE

DATE  
MAR 2015

SCALE  
GRAPHIC

FIGURE  
26



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/1/2016  
Oscarville

**Existing Community & System Data**

2015 Population	53
2015 Number of Services	32
HITS Database (E1 & H1-H7)	16
DCED Mapping Commerical/Public Facilities/School	16
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	2100
Water Treatment Capacity	3.5
Existing Sewage Lagoon Size	0.25

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<input checked="" type="checkbox"/>	3100	4600
Gravity Sewer Main			
Pressure Sewer Main	<input checked="" type="checkbox"/>	3100	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      **Oscarville**

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	4		
Req Water Storage (gallons) (less existing)	53,800	890	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	0.9		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	4,600	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	3,100	
	Individual Grinder Pump Stations (GPS) (ea)	32	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	2,400	
	Pressure Sewer Service Lines (lf)	2,400	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	4	3.5	0.5
Water Storage (gallons)	55,900	2,100	53,800
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.1	0.3	0.9
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,090	-	2,090
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	4,600	-	4,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	3,100	-	3,100
Individual Grinder Pump Stations (GPS) (ea)	32	-	32
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,400	-	2,400
Pressure Sewer Service Lines (lf)	2,400	-	2,400



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	4/1/2016	
Community	Oscarville	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	53 people	2015 ADOL
2015 Number of Services	32 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	65 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	3.5 gpm	
Average Day (ADD)	3,234 gpd	50 gallons per Capita
Max Day (MDD)	6,467 gpd	2 x ADD
Peak Hour	13 gpm	3 x MDD
Treatment Capacity	4 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	4 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	2,100 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	6,467 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	19,401 gallons	3 days x DO
Water Storage Tank Volume	55,868 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	22,909 gallons	CT/RCxPeak Hour/BF
Required Water Storage	55,900 gallons	
Required Additional Storage	53,800 gallons	0
Estimate of Min Platform Size (3' clearance around)	890 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.25 acres	
Organic Loading Based Size	0.5 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	125.6	
Hydraulic Loading Based Size	1.1 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	1.1 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

Oscarville

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	32	\$26,403.25	\$844,904
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	5,500	\$213.56	\$1,174,576
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.9	\$911,751.90	\$820,577
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	7,000	\$339.19	\$2,374,347
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	53,800	\$4.78	\$257,310
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	2,090	\$366.35	\$765,662
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$8,353,685**

# O&M Cost Estimate Piped Water & Sewer System

4/14/2016

**Community:** Oscarville

## General Community Data

Current population	53 persons
Average number of people per house	3.3
Service Connections	
Number of houses	16
Number of public/commerical buildings	15
Number of schools	1
Total number of service connections	32
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.35 kWh
Electricity cost (Residential service)	\$0.15 kWh
Cost per gallon for heating oil	\$5.90 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	1840 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	55,900 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	4600 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	3100 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	430 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

4/14/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

4/14/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$554 /month	\$4,435.50
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$190 /month	\$1,520.97
Water storage tank	\$50 /month	\$401.05
Water storage tank line	\$0 /month	\$0.00
Water mains	\$990 /month	\$7,921
Service lines	\$517 /month	\$4,132
<u>Wastewater system</u>		
Sewer mains	\$667 /month	\$5,338
Service lines	\$517 /month	\$4,132
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$93 /month	\$740
	Subtotal	\$28,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$188 /month	\$2,255
HVAC/hydronic system	\$188 /month	\$1,504
Water treatment	\$14 /month	\$169
Pumps		
Intake or well	\$14 /month	\$169.18
WST circulation	\$47 /month	\$378
Pressure/booster	\$21 /month	\$253.76
Main line circulation	\$376 /month	\$3,007
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$94 /month	\$750
Lagoon discharge pump	\$203 /year	\$203
	Subtotal	\$8,700
<b>Other Costs</b>		
Equipment R&R	\$3,113 /year	\$3,113
Miscellaneous materials & supplies	\$1,868 /year	\$1,868
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$11,000

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$28,600
Electricity	\$8,700
Other	\$11,000
<b>Total</b>	<b>\$79,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 148	16	85%	\$ 24,225
Public/Commerc	\$ 155.86	15	100%	\$ 28,055
School Service	\$ 2,968.81	1	100%	\$ 26,719
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 79,000</b>

# Platinum, Alaska

## Community Information & Existing Infrastructure

Platinum is a Yupik community of 60 people located on the Bering Sea coast, below Red Mountain on the south spit of Goodnews Bay. There are 19 residential units, 13 commercial/public facilities and one school for a total of 33 services. Piped water is distributed to approximately 7 homes, the school, and 20 yard hydrants. Residents self-haul water from the hydrants. Sewer services consist of individual septic systems and honeybuckets. The existing water and sewer infrastructure consists of the following:

- Groundwater under the direct influence of surface water – 53 gpm
- Water Storage – 430 gallons
- Pump House Building – 48 SF
- No Treatment
- Sewage Lagoon – N/A

Soils in the region consist of loose and moist to wet. There is a layer of organics across the tundra that overlies 3-8" of poorly graded sand layer. Under the poorly graded sand layer is a layer of poor to well graded sand and gravel. Groundwater is generally present around 8 feet below ground surface. No frozen ground encountered.

## Piped System Description

The piped water system will be a below grade system with static water mains. The water system will consist of approximately 7,300 feet of pipe. The sewer system for the community will consist of individual residential on-site septic systems that include septic tanks and drainfields. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment and water distribution equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	5	53	-
<b>Water Storage (gallons)</b>	59,300	430	58,870
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Residential On-Site Septic System (ea)</b>	33	-	33
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,160	-	2,160
<b>Water Distribution System</b>			
Static Water Main (lf)	7,300	-	7,300
<b>Water &amp; Sewer Service Lines</b>			
Static Water Service Lines (lf)	2,475	-	2,475
Gravity Sewer Service Lines (lf)	2,475	-	2,475

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Platinum. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs					Village Platinum
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	33	\$26,342.77	\$869,312
2	Sewage collection mains or services (gravity or force), buried	LF	2,475	\$367.63	\$ 909,880
6	Septic tank, and drainfield, individual household	EA	33	\$125,292.93	\$4,134,667
13	Water distribution, mains or services, buried	LF	9,775	\$299.80	\$2,930,587
14	Water storage tank, no foundation	Gal	58,870	\$5.51	\$324,194
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
18	Foundation - freeze back piles	SF	2,160	\$341.96	\$738,638
Total Estimated Cost in 2010 dollars (rounded):					<b>\$11,867,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$14,169,800</b>
28	Electrical Service Upgrades	EA	33	\$5,500	\$181,500
Subtotal					<b>\$14,351,300</b>
29	Construction Contingency (15%)	LS	1	\$2,152,700	\$2,152,700
30	Design & Construction Administration Services (20%)	LS	1	\$2,870,300	\$2,870,300
Total					<b>\$19,374,300</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$21,200
Fuel	\$5,000
Electricity	\$4,600
Other (R&R, Training, etc.)	\$8,500
<b>Total</b>	<b>\$45,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Platinum are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 93	19	85%	\$ 17,989
Public/Commercial Service	\$ 93	13	100%	\$ 14,480
School Service	\$ 1,392	1	100%	\$ 12,531
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 45,000</b>



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

9/7/2016  
Platinum

**Existing Community & System Data**

2015 Population	60
2015 Number of Services	33
HITS Database (E1 & H1-H7)	19
DCED Mapping Commercial/Public Facilities/School	14
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	430
Water Treatment Capacity	53
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

	Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost	<input checked="" type="checkbox"/>	7300
Above ground system or buried with permafrost	<input type="checkbox"/>	<input type="checkbox"/>
Gravity Sewer Main	<input type="checkbox"/>	<input type="checkbox"/>
Pressure Sewer Main	<input type="checkbox"/>	<input type="checkbox"/>
Typical Service Line Length (ea)	75	75

**Piped System Requirements**

Community Platinum

**Output for Cost Model (calculated)**

Water Treatment Capacity (gpm)	5	Foundation Size
Req Water Storage (gallons) (less existing)	58,870	960 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf

	Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf) 1,200	
Water Distribution System	Static Water Main (lf) 7,300	
Water & Sewer Service Lines	Static Water Service Line (lf) 2,475 Gravity Sewer Service Lines (lf) 2,475	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	5	53.0	-
Water Storage (gallons)	59,300	430	58,870
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Residential On-Site Septic System (ea)	33	-	33
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	2,160	-	2,160
<b>Water Distribution System</b>			
Static Water Main (lf)	7,300	-	7,300
<b>Water &amp; Sewer Service Lines</b>			
Static Water Service Line (lf)	2,475	-	2,475
Gravity Sewer Service Lines (lf)	2,475	-	2,475

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	9/7/2016	
Community	Platinum	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	60 people	2015 ADOL
2015 Number of Services	33 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	73 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	53 gpm	
Average Day (ADD)	3,661 gpd	50 gallons per Capita
Max Day (MDD)	7,321 gpd	2 x ADD
Peak Hour	15 gpm	3 x MDD
Treatment Capacity	5 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	5 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	430 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	7,321 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	21,963 gallons	3 days x DO
Water Storage Tank Volume	59,285 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	25,935 gallons	CT/RCxPeak Hour/BF
Required Water Storage	59,300 gallons	
Required Additional Storage	58,870 gallons	#VALUE!
Estimate of Min Platform Size (3' clearance around)	960 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	x	Static Water Main (lf)
Above ground system or buried with permafrost	0	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	0	Sewer main with glycol heat trace
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	x	Static Water Service Line (lf)
Circulating Water Main	0	Circulating Water Service Lines
On-Site Septic System	x	Gravity Sewer
Pressure Sewer Main	0	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size	0.6 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	133.7	
Hydraulic Loading Based Size	1.3 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	1.3 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Platinum**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	33	\$26,342.77	\$869,312
2	Sewage collection mains or services (gravity or force), buried	LF	2,475	\$367.63	\$909,880
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	33	\$125,292.93	\$4,134,667
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	9,775	\$299.80	\$2,930,587
14	Water storage tank, no foundation	Gal	58,870	\$5.51	\$324,194
15	Water treatment plant, no foundation	SF	1,200	\$1,633.35	\$1,960,015
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	2,160	\$341.96	\$738,638
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$11,867,293**

# O&M Cost Estimate Piped Water & Sewer System

9/7/2016

**Community:** Platinum

## General Community Data

Current population	60 persons
Average number of people per house	3.2
Service Connections	
Number of houses	19
Number of public/commerical buildings	13
Number of schools	1
Total number of service connections	33
Burdened labor rate	\$17 hr
Electricity cost (Public facility)	\$0.40 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$5.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	2200 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	1200 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	59,300 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Static
Number of circulating water loops	0
Total length of Water Main	7300 ft
Water mains heated for freeze protection (Yes or No)	No
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	
Total length of sewer mains	
Sewer mains heated for freeze protection (Yes or No)	
Number of circulating glycol loops	
Location of the mains (Above ground (AG) or Buried)	
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	
Force main heated for freeze protection (Yes or No)	
Location of force main (Above ground (AG) or Buried)	
Septic system discharged seasonally with pump (Yes or No)	



# O&M Cost Estimate Piped Water & Sewer System

9/7/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Septic system discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/7/2016

## Estimated O&M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$21,216
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$306 /month	\$2,451.46
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$182 /month	\$2,188.80
Water storage tank	\$45 /month	\$360.54
Water storage tank line	\$0 /month	\$0.00
Water mains	\$0 /month	\$0
Service lines	\$0 /month	\$0
<u>Wastewater system</u>		
Sewer mains	\$0 /month	\$0
Service lines	\$0 /month	\$0
Lift/pump station buildings	\$0 /month	\$0.00
Force main to septic system	\$0 /month	\$0
	Subtotal	\$5,000
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$140 /month	\$1,681
HVAC/hydronic system	\$140 /month	\$1,681
Water treatment	\$18 /month	\$219
Pumps		
Intake or well	\$18 /month	\$218.88
WST circulation	\$54 /month	\$432
Pressure/booster	\$27 /month	\$328.32
Main line circulation	\$0 /month	\$0
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$0 /month	\$0
Septic system discharge pump	\$0 /year	\$0
	Subtotal	\$4,600
<b>Other Costs</b>		
Equipment R&R	\$1,541 /year	\$1,541
Miscellaneous materials & supplies	\$924 /year	\$924
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$8,500


## Summary

Administration	\$6,000
Labor	\$21,200
Fuel	\$5,000
Electricity	\$4,600
Other	\$8,500
<b>Total</b>	<b>\$45,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 93	19	85%	\$ 17,989
Public/Commerc	\$ 92.82	13	100%	\$ 14,480
School Service	\$ 1,392.33	1	100%	\$ 12,531
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 45,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Platinum.dwg





# Rampart, Alaska

---

## Community Information & Existing Infrastructure

Rampart is a Koyukon Athabascan community of 45 people located on the south bank of the Yukon River, approximately 75 miles upstream from the Tanana River junction. There are 30 residential units and 19 commercial/public facilities for a total of 49 services. The existing water services provided in Rampart consist of a self-haul system from the watering point and the community water pickup truck. The sewer services consist of outhouses. The school, washeteria, and health clinic have piped water and sewer services. The existing water and sewer infrastructure consists of the following:

- Well – 13 gpm
- Treated Water Storage – 4,000 gallons
- Water Treatment Plant – 2,148 SF, built in 1998
- Water Treatment – Potassium permanganate, greensand filter, and chlorine
- Sewage Lagoon – Single cell, 0.2 acres

Soils around Rampart consist of brown to gray silt with scattered organic material and ice lenses from 1/8" to 1.2'. Material becomes coarser with depth, consisting of interbedded frozen silt and gravel, frozen gravel, and bedrock.

## Piped System Description

The piped water and sewer system will be an above ground system. The water system will consist of approximately 6,900 feet of pipe. The water system will consist of two circulating loops. The sewer system will be a combination of gravity and pressure system. Homes located on the hills can likely accommodate a gravity sewer system (1,950 LF). A total of 19 services will be connected to the gravity sewer and will not require individual grinder pump stations (GPS). The remaining 30 homes and buildings on the lower portion of the community will be connected to the pressure sewer system (3,200 LF) and would require GPS units. The sewer system would require one sewer main lift station, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.



## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	4	13	-
Water Storage (gallons)	52,000	4,000	48,000
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (sf)	1.0	0.2	0.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	2,020	-	2,020
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	6,900	-	6,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,200	-	5,200
Individual Grinder Pump Stations (GPS) (ea)	30	-	30
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,700	-	3,700
Gravity Sewer Service Lines (lf)	1,425	-	1,425
Pressure Sewer Service Lines (lf)	2,250	-	2,250

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Rampart. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Rampart
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	49	\$26,403.25	\$1,293,759
3	Sewage collection mains or services (gravity or force), above ground	LF	8,875	\$209.61	\$1,860,288
4	Sewage lift station	EA	1	\$762,792.59	\$762,793
10	Sewage lagoon, barrow, local material	Acre	0.8	\$1,056,418.57	\$845,135
12	Water distribution, mains or services, above ground	LF	10,600	\$337.97	\$3,582,480
14	Water storage tank, no foundation	Gal	48,000	\$6.40	\$307,196
15	Water treatment plant, no foundation	SF	1,200	\$1,660.79	\$1,992,952
18	Foundation - freeze back piles	SF	2,020	\$384.57	\$776,823
Total Estimated Cost in 2010 dollars (rounded):					<b>\$11,421,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$13,637,300</b>
27	Individual Grinder Pump Stations	EA	30	\$30,000	\$900,000
28	Electrical Service Upgrades	EA	49	\$5,500	\$269,500
<b>Subtotal</b>					<b>\$14,806,800</b>
29	Construction Contingency (15%)	LS	1	\$2,221,000	\$2,221,000
30	Design & Construction Administration Services (20%)	LS	1	\$2,961,400	\$2,961,400
<b>Total</b>					<b>\$19,989,200</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$25,000
Fuel	\$43,200
Electricity	\$20,400
Other (R&R, Training, etc.)	\$13,000
<b>Total</b>	<b>\$108,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Rampart are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 142	30	85%	<b>\$ 43,370</b>
Public/Commercial Service	\$ 283	19	100%	<b>\$ 64,630</b>
School Service	\$ -	0	100%	<b>\$ -</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 108,000</b>

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

9/29/2016  
Rampart

**Existing Community & System Data**

2015 Population	45
2015 Number of Services	49
HITS Database (E1 & H1-H7)	30
DCED Mapping Commerical/Public Facilities/School	19
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	4000
Water Treatment Capacity	13
Existing Sewage Lagoon Size	0.2

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	5150	6900
Gravity Sewer Main	x	1950	
Pressure Sewer Main	x	3200	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Rampart

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	4	
Req Water Storage (gallons) (less existing)	48,000	820 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	0.8	

Quantity Notes

Required Foundation System for WTP and/or WST	Pile Foundation (sf)	2,020
Water Distribution System	Circulating Water Main with Pitorifices (lf)	6,900
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	5,200
	Lift Stations for Sewer Mains	1
	Individual Grinder Pump Stations (GPS) (ea)	30
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	3,700
	Gravity Sewer Service Lines (lf)	1,425
	Pressure Sewer Service Lines (lf)	2,250

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	4	13	-
Water Storage (gallons)	52,000	4,000	48,000
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.0	0.2	0.8
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	2,020	-	2,020
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	6,900	-	6,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,200	-	5,200
Individual Grinder Pump Stations (GPS) (ea)	30	-	30
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,700	-	3,700
Gravity Sewer Service Lines (lf)	1,425	-	1,425
Pressure Sewer Service Lines (lf)	2,250	-	2,250

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	9/29/2016	
Community	Rampart	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	45 people	2015 ADOL
2015 Number of Services	49 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	55 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	13 gpm	
Average Day (ADD)	2,745 gpd	50 gallons per Capita
Max Day (MDD)	5,491 gpd	2 x ADD
Peak Hour	11 gpm	3 x MDD
Treatment Capacity	4 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	4 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	4,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	5,491 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	16,473 gallons	3 days x DO
Water Storage Tank Volume	51,963 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	19,451 gallons	CT/RCxPeak Hour/BF
Required Water Storage	52,000 gallons	
Required Additional Storage	48,000 gallons	
Estimate of Min Platform Size (3' clearance around)	820 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf Existing WTP<800 sf and in poor condition
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Insulated sewer main with glycol heat trace (lf)
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0.2 acres	
Organic Loading Based Size check	0.5 acres 115.7	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	1.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	1.0 acres	Either organic loading based or hydraulic, whichever is greater



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Rampart**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	49	\$26,403.25	\$1,293,759
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	8,875	\$209.61	\$1,860,288
4	Sewage lift station	EA	1	\$762,792.59	\$762,793
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.8	\$1,056,418.57	\$845,135
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	10,600	\$337.97	\$3,582,480
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	48,000	\$6.40	\$307,196
15	Water treatment plant, no foundation	SF	1,200	\$1,660.79	\$1,992,952
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	2,020	\$384.57	\$776,823
19	Foundation - thermosyphen stabilized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$11,421,426**

# O&M Cost Estimate Piped Water & Sewer System

9/29/2016

**Community:** Rampart (Pressure)

## General Community Data

Current population	45 persons
Average number of people per house	3.8
Service Connections (Lowland)	
Number of houses	12
Number of public/commerical buildings	18
Number of schools	0
Total number of service connections	30
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.40 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	3348 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	52,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main (Lowland)	6900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	42
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains (Pressure)	3200 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	200 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/29/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/29/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,026 /month	\$8,207.47
Raw water line	\$22 /month	\$175.10
Raw water heat addition	\$164 /month	\$1,313.28
Water storage tank	\$47 /month	\$379.39
Water storage tank line	\$11 /month	\$87.55
Water mains	\$1,510 /month	\$12,082
Service lines	\$492 /month	\$3,940
<u>Wastewater system</u>		
Sewer mains	\$700 /month	\$5,603
Service lines	\$492 /month	\$3,940
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to lagoon	\$44 /month	\$350
	Subtotal	\$37,300
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$391 /month	\$4,690
HVAC/hydronic system	\$391 /month	\$3,127
Water treatment	\$14 /month	\$164
Pumps		
Intake or well	\$14 /month	\$164.16
WST circulation	\$54 /month	\$432
Pressure/booster	\$21 /month	\$246.24
Main line circulation	\$859 /month	\$6,874
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$58 /month	\$700
HVAC/hydronic system	\$58 /month	\$467
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$57 /month	\$689.47
Sewer/force main glycol circulation	\$214 /month	\$1,715
Lagoon discharge pump	\$197 /year	\$197
	Subtotal	\$19,500
<b>Other Costs</b>		
Equipment R&R	\$4,088 /year	\$4,088
Miscellaneous materials & supplies	\$2,453 /year	\$2,453
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$12,500

## Summary (Pressure)

Administration	\$6,000
Labor	\$25,000
Fuel	\$37,300
Electricity	\$19,500
Other	\$12,500
<b>Total</b>	<b>\$100,000</b>

## Summary (Pressure + Gravity)

Administration	\$6,000
Labor	\$25,000
Fuel	\$43,200
Electricity	\$20,400
Other	\$13,000
<b>Total</b>	<b>\$108,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 142	30	85%	\$ 43,370
Public/Commerc	\$ 283.46	19	100%	\$ 64,630
School Service <sup>(3)</sup>			100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 108,000</b>



# O&M Cost Estimate Piped Water & Sewer System

9/29/2016

**Community:** Rampart (Gravity)

## General Community Data

Current population		persons
Average number of people per house	0.0	
Service Connections (South Side)		
Number of houses	18	
Number of public/commerical buildings	1	
Number of schools	0	
Total number of service connections	19	
Burdened labor rate	\$20	hr
Electricity cost (Public facility)	\$0.40	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))		
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Treatment

Size of water treatment plant building		sf
Raw water quality (Good or Poor)		

### Water Storage

Size of tank(s)		gallons
Length of water line to/ from tank		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Distribution

Type of system (Static or Circulating (Circ))		
Number of circulating water loops		
Total length of Water Main		ft
Water mains heated for freeze protection (Yes or No)		
Location of the mains (Above ground (AG) or Buried)		
Average service line length		ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity	
Number of individual facility pump stations		
Number of community lift/pump stations		
Number of facilities served by lift/pump station #1		
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations		sf
Total length of sewer mains (Gravity)	1950	ft
Sewer mains heated for freeze protection (Yes or No)	Yes	
Number of circulating glycol loops	1	
Location of the mains (Above ground (AG) or Buried)	AG	
Average service line length	75	ft

### Wastewater Treatment / Disposal

Length of force main		ft
Force main heated for freeze protection (Yes or No)		
Location of force main (Above ground (AG) or Buried)		
Lagoon discharged seasonally with pump (Yes or No)		

# O&M Cost Estimate

## Piped Water & Sewer System

9/29/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management /month

#### Labor (Operator)

Hours per week

Less than 50 services 24 hrs/week

Between 50 and 100 services 32 hrs/week

More than 100 services 40 hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel 100,000 BTUs/gallon

Heating season (above ground components) 8 months

Heating season (buried components) 12 months

Buildings 7 BTU/hr/sf

Raw water heat addition (5F) 40 BTU/gallon

Water storage tank 0.5 BTU/gal-day

Above ground mains 5 BTU/hr/ft

Buried mains (permafrost conditions) 3 BTU/hr/ft

#### Electricity

WTP building

Lights and controls 0.4 watts/hr/sf

HVAC/hydronic system 0.4 watts/hr/sf

Water treatment

Good quality water 0.1 watts/gallon

Poor quality water 0.5 watts/gallon

Water system pumps

Intake or well 0.5 watts/gallon

WST circulation 135 kWh/month

Pressure/booster 0.75 watts/gallon

Main line circulation 1074 kWh/month/loop

Sewer system pumps

Individual facility pump stations 0.7 watts/gallon/service

Community lift stations 0.6 watts/gallon

Sewer main glycol circulation 268 kWh/month/loop

Force main 0.6 watts/gallon

Lagoon discharge 0.6 watts/gallon

#### Other Costs

Equipment R&R 5 % of labor, fuel and electricity

Miscellaneous materials & supplies 3 % of labor, fuel and electricity

Water quality testing \$2,000 per year

Operator training \$2,500 per year

Insurance \$1,500 per year

# O&M Cost Estimate Piped Water & Sewer System

9/29/2016

## Estimated O& M Costs


		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$0 /month	\$0
<b>Labor</b> (WTP Operator)	24 hrs/week	\$0
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$0 /month	\$0.00
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$0 /month	\$0.00
Water storage tank	\$0 /month	\$0.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$0 /month	\$0
Service lines	\$0 /month	\$0
<u>Wastewater system</u>		
Sewer mains	\$427 /month	\$3,415
Service lines	\$312 /month	\$2,495
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$0 /month	\$0
	Subtotal	\$5,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Water treatment	\$0 /month	\$0
Pumps		
Intake or well	\$0 /month	\$0.00
WST circulation	\$0 /month	\$0
Pressure/booster	\$0 /month	\$0.00
Main line circulation	\$0 /month	\$0
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$107 /month	\$858
Lagoon discharge pump	\$0 /year	\$0
	Subtotal	\$900
<b>Other Costs</b>		
Equipment R&R	\$340 /year	\$340
Miscellaneous materials & supplies	\$204 /year	\$204
Water quality testing	\$0 /year	\$0
Operator training	\$0 /year	\$0
Insurance	\$0 /year	\$0
	Subtotal	\$500

## Summary (Upland)

Administration	\$0	Covered in Pressure Estimate
Labor	\$0	Covered in Pressure Estimate
Fuel	\$5,900	
Electricity	\$900	
Other	\$500	
<b>Total</b>	<b>\$7,000</b>	



File: J:\Jobsdata\31303.00 VSW - Assessment of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Rampart.dwg



LEGEND:

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



PROPOSED LIFT STATION



EXISTING PUBLIC STRUCTURE SHOWN ON  
DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN  
ON DCRA MAP



PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
RAMPART

DATE  
SEP 2016

SCALE  
GRAPHIC

FIGURE  
42



# Stebbins, Alaska

---

## Community Information & Existing Infrastructure

Stebbins is a Yupik community of 608 people located on the northwest coast of St. Michael Island, on Norton Sound. There are 133 residential units, 25 commercial/public facilities and one school for a total of 159 services. The existing water and sewer services provided in Stebbins consist of self-haul system from the washeteria or through a community watering point and honey buckets. The washeteria, school, and clinic have piped water and sewer services. The existing water and sewer infrastructure consists of the following:

- Clear Lake – 70-80 gpm (Seasonal)
- Treated Water Storage – 500,000 gallons (Recommended for replacement in 2010)
- School Water Storage – 750,000 gallons (Also used for community)
- Water Treatment Plant – 2,432 SF, built in 2015
- Water Treatment – Coagulant, calcium hypo chloride
- Sewage Lagoon – Honeybucket dump

Stebbins was built on discontinuously frozen beach deposits. It has silty soil and high groundwater near the coast.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 21,800 feet of pipe, and the pressure sewer system approximately 13,700 feet of pipe. The water system will consist of three circulating loops. The pressure sewer system would require four sewer main lift stations, individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. Previous analysis by ANTHC (2010 Community Development Plant) suggests that Clear Lake water source could be developed into a year-round source. Needed improvements would include a new 22,000 feet raw water transmission line, and new source intake structure. The existing water storage tank at the school is sufficient for meeting the systems CT requirements (263,000 gallons). For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	52	70	-
Water Storage (gallons)	326,800	750,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	13.0	-	13.0
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	21,800	-	21,800
Raw Water Transmission Line with Heat Trace (lf)	22,000	-	22,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	13,700	-	13,700
Individual Grinder Pump Stations (GPS) (ea)	159	-	159
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	11,900	-	11,900
Pressure Sewer Service Lines (lf)	11,900	-	11,900

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Stebbins. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs				Village Stebbins	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	159	\$22,235.73	\$3,535,482
3	Sewage collection mains or services (gravity or force), above ground	LF	25,600	\$186.02	\$4,762,042
4	Sewage lift station	EA	2	\$ 581,420.38	\$ 1,162,841
10	Sewage lagoon, barrow, local material	Acre	13	\$601,528.27	\$7,819,868
12	Water distribution, mains or services, above ground	LF	55,700	\$286.52	\$15,959,332
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
19	Foundation - thermosyphen stablized gravel pad	SF	1,200	\$499.91	\$599,886
22	Water source - surface water intake	EA	1	\$482,502.97	\$482,503
Total Estimated Cost in 2010 dollars (rounded):					<b>\$36,081,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$43,082,600</b>
27	Individual Grinder Pump Stations	EA	159	\$30,000	\$4,770,000
28	Electrical Service Upgrades	EA	159	\$5,500	\$874,500
<b>Subtotal</b>					<b>\$48,727,100</b>
29	Construction Contingency (15%)	LS	1	\$7,309,100	\$7,309,100
30	Design & Construction Administration Services (20%)	LS	1	\$9,745,400	\$9,745,400
<b>Total</b>					<b>\$65,781,600</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


<b>Estimated O&amp;M Costs</b>	
<b>Description</b>	<b>Cost</b>
Administration	\$6,000
Labor	\$37,400
Fuel	\$179,600
Electricity	\$40,700
Other (R&R, Training, etc.)	\$26,600
<b>Total</b>	<b>\$290,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Stebbins are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 148	133	85%	<b>\$ 201,070</b>
Public/Commercial Service	\$ 185	25	100%	<b>\$ 55,581</b>
School Service	\$ 3,705	1	100%	<b>\$ 33,349</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 290,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Stebbins.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 4/4/2016  
Community Stebbins  
Input

**Existing Community & System Data**

2015 Population	608
2015 Number of Services	159
HITS Database (E1 & H1-H7)	133
DCED Mapping Commerical/Public Facilities/School	26
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	750000
Water Treatment Capacity	70
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	13700	21800
Gravity Sewer Main			
Pressure Sewer Main	x	13700	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Stebbins

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	52	
Req Water Storage (gallons) (less existing)	-	- sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	13.0	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	21,800	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	13,700	
	Individual Grinder Pump Stations (GPS) (ea)	159	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	11,900	
	Pressure Sewer Service Lines (lf)	11,900	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	52	70	-
Water Storage (gallons)	326,800	750,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	13.0	-	13.0
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	21,800	-	21,800
Raw Water Transmission Line with Heat Trace (lf)	22,000	-	22,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	13,700	-	13,700
Individual Grinder Pump Stations (GPS) (ea)	159	-	159
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	11,900	-	11,900
Pressure Sewer Service Lines (lf)	11,900	-	11,900

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		4/4/2016 Stebbins	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	608 people	2015 ADOL	
2015 Number of Services	159 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	742 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	70 gpm		
Average Day (ADD)	37,094 gpd	50 gallons per Capita	
Max Day (MDD)	74,188 gpd	2 x ADD	
Peak Hour	155 gpm	3 x MDD	
Treatment Capacity	52 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	SW		
Required Capacity	52 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	750,000 gallons		
Demand Based Volume (if source is GW)	Check Min CT Requirements		
Daily Operation (DO) (gallons)	74,188 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	222,563 gallons	3 days x DO	
Water Storage Tank Volume	326,750 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$L \times \{5.057\} \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	262,809 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	326,800 gallons		
Required Additional Storage	- gallons	0	
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation	
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad	
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Static Water Mains	
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Bare sewer main, no heat trace	
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft	
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Static Water Service Line	
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	0	Gravity Service Line	
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	6.3 acres 425.4	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	13.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	13.0 acres	Either organic loading based or hydraulic, whichever is greater	

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Stebbins**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	159	\$22,235.73	\$3,535,482
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	25,600	\$186.02	\$4,762,042
4	Sewage lift station	EA	2	\$581,420.38	\$1,162,841
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	13	\$601,528.27	\$7,819,868
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	55,700	\$286.52	\$15,959,332
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	1,200	\$499.91	\$599,886
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	1	\$482,502.97	\$482,503
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$36,080,821**

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Stebbins

### General Community Data

Current population	608 persons
Average number of people per house	4.6
Service Connections	
Number of houses	133
Number of public/commerical buildings	25
Number of schools	1
Total number of service connections	159
Burdened labor rate	\$18 hr
Electricity cost (Public facility)	\$0.40 kWh
Electricity cost (Residential service)	\$0.20 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	22000 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	3632 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	750,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	3
Total length of Water Main	21800 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	150
Number of facilities served by lift/pump station #2	159
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	13700 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	1500 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$37,440
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,113 /month	\$8,903.69
Raw water line	\$4,815 /month	\$38,522.88
Raw water heat addition	\$2,218 /month	\$17,743.87
Water storage tank	\$684 /month	\$5,472.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$4,772 /month	\$38,173
Service lines	\$2,610 /month	\$20,881
<u>Wastewater system</u>		
Sewer mains	\$2,999 /month	\$23,989
Service lines	\$2,610 /month	\$20,881
Lift/pump station buildings	\$306 /month	\$2,451.46
Force main to lagoon	\$328 /month	\$2,627
	Subtotal	\$179,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$424 /month	\$5,088
HVAC/hydronic system	\$424 /month	\$3,392
Water treatment	\$185 /month	\$2,218
Pumps		
Intake or well	\$185 /month	\$2,217.98
WST circulation	\$54 /month	\$432
Pressure/booster	\$277 /month	\$3,326.98
Main line circulation	\$1,289 /month	\$10,310
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$117 /month	\$1,401
HVAC/hydronic system	\$117 /month	\$934
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$515 /month	\$6,183.67
Sewer/force main glycol circulation	\$322 /month	\$2,573
Lagoon discharge pump	\$2,663 /year	\$2,663
	Subtotal	\$40,700
<b>Other Costs</b>		
Equipment R&R	\$12,887 /year	\$12,887
Miscellaneous materials & supplies	\$7,732 /year	\$7,732
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$26,600

## Summary

Administration	\$6,000
Labor	\$37,400
Fuel	\$179,600
Electricity	\$40,700
Other	\$26,600
<b>Total</b>	<b>\$290,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 148	133	85%	\$ 201,070
Public/Commerc	\$ 185.27	25	100%	\$ 55,581
School Service	\$ 3,705.41	1	100%	\$ 33,349
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 290,000</b>

# Stevens Village, Alaska

## Community Information & Existing Infrastructure

Stevens Village is a Kutchin Native community of 46 people located on the north bank of the Yukon River, 17 miles upstream of the Dalton Highway bridge crossing. There are 41 residential units and 10 commercial/public facilities for a total of 51 services. The existing water and sewer services provided in Stevens Village consist of self-haul system from the watering point located at the WTP and honey buckets/outhouses. The existing water and sewer infrastructure consists of the following:

- Well – 40 gpm
- Treated Water Storage – 7,000 gallons
- Water Treatment Plant – 2,000 SF, built in 1981, Upgraded in 1993
- Water Treatment – Calcium hypochlorite, sand filter, and one-micron cartridge filter
- Sewage Lagoon – Single Cell, 0.7 acres

The area around Stevens Village is generally underlain by continuous permafrost. Frozen soils observed near clinic and at power plant location. Thaw bulbs observed at slough near the school.

## Piped System Description

The piped water and sewer system will be a below grade system. The water system will consist of approximately 13,900 feet of pipe, and the gravity sewer system approximately 8,500 feet of pipe. The water system will consist of two circulating loops. The gravity sewer system would require 2 sewer main lift stations and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	4	40	-
<b>Water Storage (gallons)</b>	52,500	7,000	45,500
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	1.0	0.7	0.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,980	-	1,980
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	13,900	-	13,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,500	-	8,800
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,800	-	3,800
Gravity Sewer Service Lines (lf)	3,825	-	3,825

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Stevens Village. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs				Village Stevens Village	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	51	\$28,096.69	\$1,432,931
2	Sewage collection mains or services (gravity or force), buried	LF	12,325	\$568.35	\$ 7,004,890
4	Sewage lift station	EA	2	\$ 1,172,426.77	\$ 2,344,854
10	Sewage lagoon, barrow, local material	Acre	0.3	\$2,504,413.17	\$751,324
13	Water distribution, mains or services, buried	LF	17,700	\$581.77	\$10,297,270
14	Water storage tank, no foundation	Gal	45,500	\$10.67	\$485,394
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
19	Foundation - thermosyphen stabilized gravel pad	SF	1,980	\$549.34	\$1,087,693
Total Estimated Cost in 2010 dollars (rounded):					<b>\$26,380,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$31,499,100</b>
28	Electrical Service Upgrades	EA	51	\$5,500	\$280,500
<b>Subtotal</b>					<b>\$31,779,600</b>
29	Construction Contingency (15%)	LS	1	\$4,766,900	\$4,766,900
30	Design & Construction Administration Services (20%)	LS	1	\$6,355,900	\$6,355,900
<b>Total</b>					<b>\$42,902,400</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$26,600
Fuel	\$83,400
Electricity	\$32,100
Other (R&R, Training, etc.)	\$17,400
<b>Total</b>	<b>\$166,000</b>



VSW - Unserved Communities Project  
Stevens Village Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Stevens Village are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 277	41	85%	<b>\$ 116,050</b>
Public/Commercial Service	\$ 416	10	100%	<b>\$ 49,950</b>
School Service	\$ -	0	100%	<b>\$ -</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 166,000</b>







**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/5/2016  
Stevens Village

**Existing Community & System Data**

2015 Population	46
2015 Number of Services	51
HITS Database (E1 & H1-H7)	41
DCED Mapping Commerical/Public Facilities/School	10
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	7000
Water Treatment Capacity	40
Existing Sewage Lagoon Size	0.7

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	8500	13900
Gravity Sewer Main	x	8500	
Pressure Sewer Main			
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      Stevens Village

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	4	
Req Water Storage (gallons) (less existing)	45,500	780    sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200    sf
Req Sewage Lagoon Size (acre) (less existing)	0.3	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	13,900	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	8,500	
	Lift Stations for Gravity Sewer Main	2	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	3,800	
	Gravity Sewer Service Lines (lf)	3,825	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	4	40.0	-
Water Storage (gallons)	52,500	7,000	45,500
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.0	0.7	0.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,980	-	1,980
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	13,900	-	13,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,500	-	8,500
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	3,800	-	3,800
Gravity Sewer Service Lines (lf)	3,825	-	3,825

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date 4/5/2016 Community Stevens Village			
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	46 people	2015 ADOL	
2015 Number of Services	51 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	56 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	40 gpm		
Average Day (ADD)	2,806 gpd	50 gallons per Capita	
Max Day (MDD)	5,613 gpd	2 x ADD	
Peak Hour	12 gpm	3 x MDD	
Treatment Capacity	4 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	4 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	7,000 gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	5,613 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	16,839 gallons	3 days x DO	
Water Storage Tank Volume	52,451 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$L \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	19,884 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	52,500 gallons		
Required Additional Storage	45,500 gallons	0	
Estimate of Min Platform Size (3' clearance around)	780 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation	
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad	
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Static Water Mains	
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Bare sewer main, no heat trace	
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0	Individual Grinder Pump Stations	
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Static Water Service Line	
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)	Gravity Service Line
Pressure Sewer Main	0	Pressure Service Line with GPS	
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0.7 acres		
Organic Loading Based Size check	0.5 acres 117.0	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	1.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	1.0 acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Stevens Village**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	51	\$28,096.69	\$1,432,931
2	Sewage collection mains or services (gravity or force), buried	LF	12,325	\$568.35	\$7,004,890
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	2	\$1,172,426.77	\$2,344,854
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.3	\$2,504,413.17	\$751,324
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	17,700	\$581.77	\$10,297,270
14	Water storage tank, no foundation	Gal	45,500	\$10.67	\$485,394
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,980	\$549.34	\$1,087,693
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$26,380,014**

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

**Community:** Stevens Village

## General Community Data

Current population	46 persons
Average number of people per house	1.1
Service Connections	
Number of houses	41
Number of public/commerical buildings	10
Number of schools	0
Total number of service connections	51
Burdened labor rate	\$16 hr
Electricity cost (Public facility)	\$0.50 kWh
Electricity cost (Residential service)	\$0.25 kWh
Cost per gallon for heating oil	\$8.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	3200 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	52,500 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	13900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	12
Number of facilities served by lift/pump station #2	46
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	8500 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	1830 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/13/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$26,624
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,307 /month	\$10,459.55
Raw water line	\$29 /month	\$233.47
Raw water heat addition	\$224 /month	\$1,789.95
Water storage tank	\$64 /month	\$510.72
Water storage tank line	\$15 /month	\$116.74
Water mains	\$2,434 /month	\$29,207
Service lines	\$670 /month	\$8,037
<u>Wastewater system</u>		
Sewer mains	\$1,488 /month	\$17,861
Service lines	\$670 /month	\$8,037
Lift/pump station buildings	\$409 /month	\$3,268.61
Force main to lagoon	\$320 /month	\$3,845
	Subtotal	\$83,400
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$467 /month	\$5,603
HVAC/hydronic system	\$467 /month	\$5,603
Water treatment	\$17 /month	\$210
Pumps		
Intake or well	\$17 /month	\$209.76
WST circulation	\$68 /month	\$540
Pressure/booster	\$26 /month	\$314.64
Main line circulation	\$1,074 /month	\$12,888
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$146 /month	\$1,751
HVAC/hydronic system	\$146 /month	\$1,167
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$30 /month	\$356.08
Sewer/force main glycol circulation	\$268 /month	\$3,216
Lagoon discharge pump	\$252 /year	\$252
	Subtotal	\$32,100
<b>Other Costs</b>		
Equipment R&R	\$7,106 /year	\$7,106
Miscellaneous materials & supplies	\$4,264 /year	\$4,264
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$17,400

## Summary

Administration	\$6,000
Labor	\$26,600
Fuel	\$83,400
Electricity	\$32,100
Other	\$17,400
<b>Total</b>	<b>\$166,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 277	41	85%	\$ 116,050
Public/Commerc	\$ 416.25	10	100%	\$ 49,950
School Service	\$ -	0	100%	\$ -
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 166,000</b>



# Stony River, Alaska

## Community Information & Existing Infrastructure

Stony River is a mix of Athabascan Indian and Yupik Eskimo community of 34 people located on the north bank of the Kuskokwim River, 2 miles north of its junction with the Stony River. There are 18 residential units, 7 commercial/public facilities and one school for a total of 26 services. The existing water and sewer services provided in Stony River consist of individual well and septic tanks and absorption fields. The existing water and sewer infrastructure consists of the following:

- Well – 18 gpm
- Treated Water Storage – 3,800 gallons
- Watering Point Building – 914 SF, built in 1990
- Water Treatment – Potassium permanganate, chlorination, fluoridation
- Sewage Lagoon – Individual septic tanks & absorption fields

There is shallow groundwater in the area. The estimated maximum depth of freeze is between 7-10 feet below ground surface.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 5,800 feet of pipe, and the pressure sewer system approximately 6,400 feet of pipe. The water system will consist of a single circulating loop. The pressure sewer system would require individual grinder pump stations at each house, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	3	18	-
<b>Water Storage (gallons)</b>	46,600	3,800	42,800
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	0.7	-	0.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation	1,950	-	1,950
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	5,800	-	5,800
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,400	-	6,400
Individual Grinder Pump Stations (GPS) (ea)	26	-	26
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,000	-	2,000
Pressure Sewer Service Lines (lf)	2,000	-	2,000

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Stony River. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Stony River
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	26	\$28,096.69	\$730,514
2	Sewage collection mains or services (gravity or force), buried	LF	8,400	\$397.75	\$ 3,341,112
10	Sewage lagoon, barrow, local material	Acre	0.7	\$1,557,213.17	\$1,090,049
13	Water distribution, mains or services, buried	LF	7,800	\$423.50	\$3,303,326
14	Water storage tank, no foundation	Gal	42,800	\$11.14	\$476,795
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
18	Foundation - freeze back piles	SF	1,950	\$683.31	\$1,332,454
Total Estimated Cost in 2010 dollars (rounded):					<b>\$13,250,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$15,821,200</b>
27	Individual Grinder Pump Stations	EA	26	\$30,000	\$780,000
28	Electrical Service Upgrades	EA	26	\$5,500	\$143,000
Subtotal					<b>\$16,744,200</b>
29	Construction Contingency (15%)	LS	1	\$2,511,600	\$2,511,600
30	Design & Construction Administration Services (20%)	LS	1	\$3,348,800	\$3,348,800
Total					<b>\$22,604,600</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$33,500
Electricity	\$11,700
Other (R&R, Training, etc.)	\$11,600
<b>Total</b>	<b>\$88,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Stony River are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 243	18	85%	<b>\$ 44,657</b>
Public/Commercial Service	\$ 255	7	100%	<b>\$ 21,453</b>
School Service	\$ 2,432	1	100%	<b>\$ 21,891</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 88,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Stony River.dwg



LEGEND:

- |  |  |
|--|--|
| PROPOSED WATER MAIN                              |  |
| PROPOSED SEWER/FORCE MAIN                        |  |
| EXISTING PUBLIC STRUCTURE SHOWN ON DCRA MAP      |  |
| EXISTING RESIDENTIAL STRUCTURE SHOWN ON DCRA MAP |  |
| HOME ADDITION FROM HITS MAP                      |  |



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
STONY RIVER

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
30



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/6/2016  
Stony River

**Existing Community & System Data**

2015 Population	34
2015 Number of Services	26
HITS Database (E1 & H1-H7)	18
DCED Mapping Commerical/Public Facilities/School	8
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	3800
Water Treatment Capacity	18
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	6400	5800
Gravity Sewer Main			
Pressure Sewer Main	x	6400	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      **Stony River**

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	3		
Req Water Storage (gallons) (less existing)	42,800	750	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	0.7		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	5,800	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	6,400	
	Individual Grinder Pump Stations (GPS) (ea)	26	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	2,000	
	Pressure Sewer Service Lines (lf)	2,000	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	3	18.0	-
Water Storage (gallons)	46,600	3,800	42,800
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	0.7	-	0.7
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	1,950	-	1,950
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	5,800	-	5,800
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,400	-	6,400
Individual Grinder Pump Stations (GPS) (ea)	26	-	26
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,000	-	2,000
Pressure Sewer Service Lines (lf)	2,000	-	2,000

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	4/6/2016	
Community	Stony River	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	34 people	2015 ADOL
2015 Number of Services	26 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	41 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	18 gpm	
Average Day (ADD)	2,074 gpd	50 gallons per Capita
Max Day (MDD)	4,149 gpd	2 x ADD
Peak Hour	9 gpm	3 x MDD
Treatment Capacity	3 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	3 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	3,800 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	4,149 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	12,446 gallons	3 days x DO
Water Storage Tank Volume	46,595 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	14,697 gallons	CT/RCxPeak Hour/BF
Required Water Storage	46,600 gallons	
Required Additional Storage	42,800 gallons	0
Estimate of Min Platform Size (3' clearance around)	750 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size check	0.4 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	100.6	
Hydraulic Loading Based Size	0.7 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	0.7 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Stony River**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	26	\$28,096.69	\$730,514
2	Sewage collection mains or services (gravity or force), buried	LF	8,400	\$397.75	\$3,341,112
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.7	\$1,557,213.17	\$1,090,049
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	7,800	\$423.50	\$3,303,326
14	Water storage tank, no foundation	Gal	42,800	\$11.14	\$476,795
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	1,950	\$683.31	\$1,332,454
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$13,249,908**

# O&M Cost Estimate Piped Water & Sewer System

4/26/2016

**Community:** Stony River

## General Community Data

Current population	34 persons
Average number of people per house	1.9
Service Connections	
Number of houses	18
Number of public/commerical buildings	7
Number of schools	1
Total number of service connections	26
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.35 kWh
Electricity cost (Residential service)	\$0.15 kWh
Cost per gallon for heating oil	\$6.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	90 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	2114 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	46,600 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	1
Total length of Water Main	5800 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	6400 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	1
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	600 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

4/26/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

4/26/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$648 /month	\$5,182.38
Raw water line	\$12 /month	\$141.83
Raw water heat addition	\$124 /month	\$1,488.38
Water storage tank	\$42 /month	\$339.99
Water storage tank line	\$7 /month	\$78.80
Water mains	\$762 /month	\$9,140
Service lines	\$256 /month	\$3,073
<u>Wastewater system</u>		
Sewer mains	\$840 /month	\$10,086
Service lines	\$256 /month	\$3,073
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$79 /month	\$946
	Subtotal	\$33,500
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$216 /month	\$2,591
HVAC/hydronic system	\$216 /month	\$2,591
Water treatment	\$9 /month	\$109
Pumps		
Intake or well	\$9 /month	\$108.53
WST circulation	\$47 /month	\$378
Pressure/booster	\$14 /month	\$162.79
Main line circulation	\$376 /month	\$4,511
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$94 /month	\$1,126
Lagoon discharge pump	\$130 /year	\$130
	Subtotal	\$11,700
<b>Other Costs</b>		
Equipment R&R	\$3,508 /year	\$3,508
Miscellaneous materials & supplies	\$2,105 /year	\$2,105
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$11,600

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$33,500
Electricity	\$11,700
Other	\$11,600
<b>Total</b>	<b>\$88,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 243	18	85%	\$ 44,657
Public/Commerc	\$ 255.39	7	100%	\$ 21,453
School Service	\$ 2,432.28	1	100%	\$ 21,891
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 88,000</b>

# Takotna, Alaska

## Community Information & Existing Infrastructure

Takotna is a mix of non-Native, Ingalik Athabascan, and Yupik community of 62 people located on the north bank of the Takotna River, 17 air miles west of McGrath. There are 16 residential units, 11 commercial/public facilities, 1 high school, and 1 community school for a total of 29 services. The existing water and sewer services provided in Takotna consist of self-haul system from the watering point and on-site septic tanks/pit privy/honey buckets for wastewater disposal. The existing water and sewer infrastructure consists of the following:

- Gold Run Creek – 37 gpm
- Treated Water Storage – 11,000 gallons
- Washeteria/Watering Point Building – 1,800 SF, built in 1980, Upgraded in 1991
- Water Treatment – Sand filters, cartridge filter, chlorine, carbon filter
- Sewage Lagoon – N/A

There is discontinuous permafrost in the region with thin frozen zones reported at several locations in towns. Soils throughout most of developed community are unfrozen except for moss covered lower hills and lowlands are underlain by permafrost.

## Piped System Description

The piped water and sewer system will be a below grade system. The water system will consist of approximately 11,000 feet of pipe, and the gravity sewer system approximately 8,000 feet of pipe. The water system will consist of two circulating loops. The gravity sewer system would require 2 sewer main lift stations and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment. Existing water storage tank does not meet the minimum CT requirements (26,800 gallons).

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	5	37	-
<b>Water Storage (gallons)</b>	60,300	11,000	49,300
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	1.3	-	1.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,030	-	2,030
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	11,000	-	11,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,000	-	8,000
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,200	-	2,200
Gravity Sewer Service Lines (lf)	2,175	-	2,175

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Takotna. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs				Village Takotna	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	29	\$28,096.69	\$814,804
2	Sewage collection mains or services (gravity or force), buried	LF	10,175	\$581.14	\$ 5,913,061
4	Sewage lift station	EA	2	\$ 1,172,426.77	\$ 2,344,854
10	Sewage lagoon, barrow, local material	Acre	1	\$1,229,336.25	\$1,598,137
13	Water distribution, mains or services, buried	LF	13,200	\$596.13	\$7,868,960
14	Water storage tank, no foundation	Gal	49,300	\$10.09	\$497,497
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
19	Foundation - thermosyphen stabilized gravel pad	SF	2,030	\$540.98	\$1,098,190
Total Estimated Cost in 2010 dollars (rounded):					<b>\$23,111,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$27,595,700</b>
28	Electrical Service Upgrades	EA	29	\$5,500	\$159,500
<b>Subtotal</b>					<b>\$27,755,200</b>
29	Construction Contingency (15%)	LS	1	\$4,163,300	\$4,163,300
30	Design & Construction Administration Services (20%)	LS	1	\$5,551,000	\$5,551,000
<b>Total</b>					<b>\$37,469,500</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$49,700
Electricity	\$41,500
Other (R&R, Training, etc.)	\$15,300
<b>Total</b>	<b>\$138,000</b>




The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Takotna are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 331	16	85%	\$ 54,086
Public/Commercial Service	\$ 365	11	100%	\$ 48,121
School Service	\$ 1,988	2	100%	\$ 35,793
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 138,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Takotna.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
TAKOTNA

DATE  
MAR 2015  
SCALE  
GRAPHIC  
FIGURE  
31



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/7/2016  
Takotna

**Existing Community & System Data**

2015 Population	62
2015 Number of Services	29
HITS Database (E1 & H1-H7)	16
DCED Mapping Commerical/Public Facilities/School	13
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	11000
Water Treatment Capacity	37
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	8000	11000
Gravity Sewer Main	x	8000	
Pressure Sewer Main			
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
**Takotna**

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	5	
Req Water Storage (gallons) (less existing)	49,300	830 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	1.3	

Quantity      Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200
Water Distribution System	Circulating Water Main with Pitorifices (lf)	11,000
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	8,000
	Lift Stations for Gravity Sewer Main	2
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	2,200
	Gravity Sewer Service Lines (lf)	2,175

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	5	37.0	-
Water Storage (gallons)	60,300	11,000	49,300
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	1.3	-	1.3
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,030	-	2,030
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	11,000	-	11,000
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,000	-	8,000
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	2,200	-	2,200
Gravity Sewer Service Lines (lf)	2,175	-	2,175

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		4/7/2016 Takotna	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	62 people	2015 ADOL	
2015 Number of Services	29 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	76 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	37 gpm		
Average Day (ADD)	3,783 gpd	50 gallons per Capita	
Max Day (MDD)	7,565 gpd	2 x ADD	
Peak Hour	16 gpm	3 x MDD	
Treatment Capacity	5 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	SW		
Required Capacity	5 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	11,000 gallons		
Demand Based Volume (if source is GW)	Check Min CT Requirements		
Daily Operation (DO) (gallons)	7,565 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	22,696 gallons	3 days x DO	
Water Storage Tank Volume	60,261 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$L \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	26,800 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	60,300 gallons	0	
Required Additional Storage	49,300 gallons	0	
Estimate of Min Platform Size (3' clearance around)	830 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Thermosyphon stabilized gravel pad (sf)	Pile Foundation
Firm soils, or continuous permafrost	x		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Circulating Water Main with Pitorifices (lf)	Static Water Mains
Above ground system or buried with permafrost	x		Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Sewer Main with Glycol Heat Trace (lf)	Bare sewer main, no heat trace
Above ground or buried with permafrost	x		Sewer main with glycol heat trace
Gravity Sewer Main	x		Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0		Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Circulating Water Service Lines (lf)	Static Water Service Line
Circulating Water Main	x		Circulating Water Service Lines
Gravity Sewer Main	x		Gravity Service Line
Pressure Sewer Main	0		Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	0.6 acres 135.9	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	1.3 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	1.3 acres	Either organic loading based or hydraulic, whichever is greater	



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Takotna**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	29	\$28,096.69	\$814,804
2	Sewage collection mains or services (gravity or force), buried	LF	10,175	\$581.14	\$5,913,061
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	2	\$1,172,426.77	\$2,344,854
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	1.3	\$1,229,336.25	\$1,598,137
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	13,200	\$596.13	\$7,868,960
14	Water storage tank, no foundation	Gal	49,300	\$10.09	\$497,497
15	Water treatment plant, no foundation	SF	1,200	\$2,479.71	\$2,975,658
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	2,030	\$540.98	\$1,098,190
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$23,111,161**

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

**Community:** Takotna

## General Community Data

Current population	62 persons
Average number of people per house	3.9
Service Connections	
Number of houses	16
Number of public/commerical buildings	11
Number of schools	2
Total number of service connections	29
Burdened labor rate	\$20 hr
Electricity cost (Public facility)	\$0.64 kWh
Electricity cost (Residential service)	\$0.38 kWh
Cost per gallon for heating oil	\$5.75 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	470 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	3000 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	60,300 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	11000 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	20
Number of facilities served by lift/pump station #2	27
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	8000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	820 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	24 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$881 /month	\$7,047.94
Raw water line	\$59 /month	\$709.83
Raw water heat addition	\$217 /month	\$2,601.02
Water storage tank	\$53 /month	\$421.62
Water storage tank line	\$6 /month	\$75.51
Water mains	\$1,384 /month	\$16,613
Service lines	\$274 /month	\$3,285
<u>Wastewater system</u>		
Sewer mains	\$1,007 /month	\$12,082
Service lines	\$274 /month	\$3,285
Lift/pump station buildings	\$294 /month	\$2,349.31
Force main to lagoon	\$103 /month	\$1,238
	Subtotal	\$49,700
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$560 /month	\$6,724
HVAC/hydronic system	\$560 /month	\$6,724
Water treatment	\$30 /month	\$362
Pumps		
Intake or well	\$30 /month	\$361.88
WST circulation	\$86 /month	\$691
Pressure/booster	\$45 /month	\$542.82
Main line circulation	\$1,375 /month	\$16,497
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$187 /month	\$2,241
HVAC/hydronic system	\$187 /month	\$1,494
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$106 /month	\$1,275.63
Sewer/force main glycol circulation	\$343 /month	\$4,116
Lagoon discharge pump	\$434 /year	\$434
	Subtotal	\$41,500
<b>Other Costs</b>		
Equipment R&R	\$5,808 /year	\$5,808
Miscellaneous materials & supplies	\$3,485 /year	\$3,485
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$15,300

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$49,700
Electricity	\$41,500
Other	\$15,300
<b>Total</b>	<b>\$138,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 331	16	85%	\$ 54,086
Public/Commerc	\$ 364.55	11	100%	\$ 48,121
School Service	\$ 1,988.47	2	100%	\$ 35,793
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 138,000</b>



# Teller, Alaska

---

## Community Information & Existing Infrastructure

Teller is a Kawerak Eskimo community of 256 people located on a spit between Port Clarence and Grantley Harbor on the Seward Peninsula. There are 89 residential units, 16 commercial/public facilities, one head start school, and one K-12 school for a total of 107 services. The existing water and sewer services provided in Teller consist of self-haul system from the watering point and honey buckets. The school has piped water and sewer service that discharges into the school sewage lagoon. The existing water and sewer infrastructure consists of the following:

- Coyote Creek – 60 gpm (Seasonal)
- Treated Water Storage – 1,000,000 gallons
- Watering Point Building – 3,300 SF, built in 1978, Upgraded in 1993
- Water Treatment – Sand filters, chlorine
- Honeybucket Lagoon – 0.12 acres

Soils in the region consist of sands and gravelly sands low in fines and moderately well-sorted. Active zone varies from a few inches to several feet.

## Piped System Description

The piped water and pressure sewer system will be a buried system. The water system will consist of approximately 12,400 feet of pipe, and the pressure sewer system approximately 10,700 feet of pipe. There will be two separate water and sewer systems for the current Townsite area and the Newsite area in the Coyote Subdivision. The existing Townsite water system will consist of two circulating loops, and the Newsite will consist of a single circulating loop. The pressure sewer system would require glycol heat trace for freeze protection. Both areas would utilize a large septic system. The Newsite would rely on gravity systems whereas the Townsite area would require a lift station. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. Based on average per capita water consumption of 50 gallons per person per day, the existing water storage capacity would need to be increased to provide sufficient water year round. Approximately 2.5 million gallons of raw water in addition to the treated water would need to be stored during the operation of the seasonal water source to provide water for the piped system when the source is non-producing (Assume freezing season is 9 months). The existing 1,000,000 gallon tank located at the Townsite would be used as a raw water tank and a new smaller treated water tank would be installed. Newsite would also have raw water and treated water storage tanks. For the purposes of this assessment, a new 1,200 sf facility is included at both the existing Townsite and the Newsite to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	22	60	-
<b>Raw Water Storage (gallons)</b>	2,500,000	1,000,000	1,500,000
<b>Treated Water Storage (gallons)</b>	100,000	-	100,000
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,400	-	2,400
<b>Septic System (sf)</b>	40,000	-	40,000
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	20,970	-	20,970
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,800	-	9,800
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,000	-	8,000
Individual Grinder Pump Stations (GPS) (ea)	79	-	79
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,000	-	8,000
Gravity Sewer Service Lines (lf)	2,100	-	2,100
Pressure Sewer Service Lines (lf)	5,900	-	5,900

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Teller. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

VSW - Unserved Communities Project  
Teller Piped Water & Sewer Assessment

Estimated Capital Costs				Village	
				Teller	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	107	\$22,235.73	\$2,379,223
2	Sewage collection mains or services (gravity or force), buried	LF	4,000	\$274.11	\$ 1,096,424
3	Sewage collection mains or services (gravity or force), above ground	LF	12,000	\$189.55	\$2,274,557
4	Sewage lift station	EA	1	\$ 638,316.38	\$ 638,316
7	Septic tank, community	EA	2	\$293,350.26	\$586,701
8	Drainfield, community	SF	40,000	\$20.82	\$832,964
12	Water distribution, mains or services, above ground	LF	13,900	\$290.52	\$4,038,161
13	Water distribution, mains or services, buried	LF	3,900	\$294.34	\$1,147,923
14	Water storage tank, no foundation	Gal	1,600,000	\$1.79	\$2,858,965
15	Water treatment plant, no foundation	SF	2,400	\$1,415.98	\$3,398,341
19	Foundation - thermosyphen stablized gravel pad	SF	20,970	\$156.25	\$3,276,483
Total Estimated Cost in 2010 dollars (rounded):					<b>\$22,528,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$26,899,600</b>
27	Individual Grinder Pump Stations	EA	79	\$30,000	\$2,370,000
28	Electrical Service Upgrades	EA	107	\$5,500	\$588,500
<b>Subtotal</b>					<b>\$29,858,100</b>
29	Construction Contingency (15%)	LS	1	\$4,478,700	\$4,478,700
30	Design & Construction Administration Services (20%)	LS	1	\$5,971,600	\$5,971,600
<b>Total</b>					<b>\$40,308,400</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$33,300
Fuel	\$86,500
Electricity	\$34,200
Other (R&R, Training, etc.)	\$18,300
<b>Total</b>	<b>\$178,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Teller are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 114	89	85%	<b>\$ 103,622</b>
Public/Commercial Service	\$ 120	16	100%	<b>\$ 23,012</b>
School Service	\$ 5,707	1	100%	<b>\$ 51,366</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 178,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Teller.dwg





File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Teller.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/8/2016  
Teller

**Existing Community & System Data**

2015 Population	256
2015 Number of Services	107
HITS Database (E1 & H1-H7)	89
DCED Mapping Commerical/Public Facilities/School	18
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	1000000
Water Treatment Capacity	60
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	8000	9800
Gravity Sewer Main	x	1900	
Pressure Sewer Main	x	6100	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community  
Teller

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	22	
Req Water Storage (gallons) (less existing)	1,600,000	18,570 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	2,400 sf
Req Septic System w/ Drainfield (sf) (less existing)	40,000	

Quantity Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	2,400
Water Distribution System	Circulating Water Main with Pitorifices (lf)	9,800
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	8,000
	Individual Grinder Pump Stations (GPS) (ea)	107
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	8,000
	Gravity Sewer Service Lines (lf)	2,100
	Pressure Sewer Service Lines (lf)	5,900

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	22	60	-
Raw Water Storage (gallons)	2,500,000	1,000,000	1,500,000
Treated Water Storage (gallons)	100,000	-	100,000
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	-	2,400
Septic System (sf)	40,000	-	40,000
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	20,970	-	20,970
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	9,800	-	9,800
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	8,000	-	8,000
Individual Grinder Pump Stations (GPS) (ea)	79	-	79
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,000	-	8,000
Gravity Sewer Service Lines (lf)	2,100	-	2,100
Pressure Sewer Service Lines (lf)	5,900	-	5,900

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date 4/8/2016 Community Teller			
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years		20 years
2015 Population (P)	256 people		2015 ADOL
2015 Number of Services	107 services		
Growth Rate (i)	1%		1%
2035 Design Population (Capita)	312 people		$P \times (1+i)^n$
<b>Water Demand Estimates</b>			
Existing Capacity	60 gpm		
Average Day (ADD)	15,618 gpd		50 gallons per Capita
Max Day (MDD)	31,237 gpd		2 x ADD
Peak Hour	65 gpm		3 x MDD
Treatment Capacity	22 gpm		MDD
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	SW		
Required Capacity	22 gpm		MDD
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	1,000,000 gallons		
<u>Demand Based Volume (if source is GW)</u>	Check Min CT Requirements		
Daily Operation (DO) (gallons)	31,237 gallons		Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons		500 gpm for 60 minutes
Reserve Volume (RV)	93,711 gallons		3 days x DO
Water Storage Tank Volume	154,947 gallons		DO + FF + RV
<u>CT Based Volume (min if source is SW)</u>	Required		
Chlorine Residual Concentration (RC)	0.4 mg/L		0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation		1.0-log Inactivation
Temperature (T)	4.4 C		4.4 celsius/40 F
pH (PH)	7		7
Contact Time Required (CT)	49 minutes		$LI \times (5.057) \times (e^{-(0.0693T)}) \times (e^{(0.361PH)}) \times (e^{(0.113RC)})$
Baffling Coefficient (BF)	0.1		0.1
Required Volume to meet CT*	110,656 gallons		CT/RCxPeak Hour/BF
Required Water Storage	154,900 gallons		
Required Additional Storage	1,600,000 gallons		0
Estimate of Min Platform Size (3' clearance around)	18,570 sf		$D = 0.103 \times Vg^{(1/2)}$ H=16 assumed (H is height of tank)
			0
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor		Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf		Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0		Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0		Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0		Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0		Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	2.7 acres		0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per acre
	276.1		
Hydraulic Loading Based Size	5.5 acres		Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	5.5 acres		Either organic loading based or hydraulic, whichever is greater



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Teller**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	107	\$22,235.73	\$2,379,223
2	Sewage collection mains or services (gravity or force), buried	LF	4,000	\$274.11	\$1,096,424
3	Sewage collection mains or services (gravity or force), above ground	LF	12,000	\$189.55	\$2,274,557
4	Sewage lift station	EA	1	\$638,316.38	\$638,316
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	2	\$293,350.26	\$586,701
8	Drainfield, community	SF	40,000	\$20.82	\$832,964
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	13,900	\$290.52	\$4,038,161
13	Water distribution, mains or services, buried	LF	3,900	\$294.34	\$1,147,923
14	Water storage tank, no foundation	Gal	1,600,000	\$1.79	\$2,858,965
15	Water treatment plant, no foundation	SF	2,400	\$1,415.98	\$3,398,341
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	20,970	\$156.25	\$3,276,483
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$22,528,058**

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

**Community:** Teller (Newsite)

## General Community Data

Current population		persons
Average number of people per house	0.0	
Service Connections (Newsite)		
Number of houses	28	
Number of public/commerical buildings		
Number of schools		
Total number of service connections	28	
Burdened labor rate	\$20	hr
Electricity cost (Public facility)	\$0.42	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))		
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Treatment

Size of water treatment plant building		sf
Raw water quality (Good or Poor)		

### Water Storage

Size of tank(s)		gallons
Length of water line to/ from tank		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Distribution

Type of system (Static or Circulating (Circ))		Circ
Number of circulating water loops		1
Total length of Water Main		1800 ft
Water mains heated for freeze protection (Yes or No)		Yes
Location of the mains (Above ground (AG) or Buried)		Buried
Average service line length		75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)		
Number of individual facility pump stations		
Number of community lift/pump stations		
Number of facilities served by lift/pump station #1		
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations		sf
Total length of sewer mains		1900 ft
Sewer mains heated for freeze protection (Yes or No)		Yes
Number of circulating glycol loops		1
Location of the mains (Above ground (AG) or Buried)		Buried
Average service line length		75 ft

### Wastewater Treatment / Disposal

Length of force main		500 ft
Force main heated for freeze protection (Yes or No)		Yes
Location of force main (Above ground (AG) or Buried)		Buried
Septic system discharged seasonally with pump (Yes or No)		Yes

# O&M Cost Estimate

## Piped Water & Sewer System

9/14/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management		/month
-----------------------------	--	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Septic system discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$0 /month	\$0
<b>Labor</b> (WTP Operator)	24 hrs/week	\$0
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$0 /month	\$0.00
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$0 /month	\$0.00
Water storage tank	\$0 /month	\$0.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$236 /month	\$2,837
Service lines	\$276 /month	\$3,309
<u>Wastewater system</u>		
Sewer mains	\$250 /month	\$2,994
Service lines	\$276 /month	\$3,309
Lift/pump station buildings	\$0 /month	\$0.00
Force main to septic system	\$66 /month	\$788
	Subtotal	\$13,200
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Water treatment	\$0 /month	\$0
Pumps		
Intake or well	\$0 /month	\$0.00
WST circulation	\$0 /month	\$0
Pressure/booster	\$0 /month	\$0.00
Main line circulation	\$451 /month	\$5,413
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$113 /month	\$1,351
Septic system discharge pump	\$0 /year	\$0
	Subtotal	\$6,800
<b>Other Costs</b>		
Equipment R&R	\$1,000 /year	\$1,000
Miscellaneous materials & supplies	\$600 /year	\$600
Water quality testing	\$0 /year	\$0
Operator training	\$0 /year	\$0
Insurance	\$0 /year	\$0
	Subtotal	\$1,600

## Summary (Newsite)

Administration	\$0	Covered in Townsite Estimate
Labor	\$0	Covered in Townsite Estimate
Fuel	\$13,200	
Electricity	\$6,800	
Other	\$1,600	
<b>Total</b>	<b>\$22,000</b>	



# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

**Community:** Teller (Townsite)

## General Community Data

Current population	256	persons
Average number of people per house	4.2	
Service Connections (Townsite)		
Number of houses	61	
Number of public/commerical buildings	16	
Number of schools	2	
Total number of service connections	79	
Burdened labor rate	\$20	hr
Electricity cost (Public facility)	\$0.42	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.00	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	SW
Length of raw water line	11500 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	4500 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	1,050,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main (Lowland)	8000 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	55
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains (North Side)	6100 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	215 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Septic system discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Septic system discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Estimated O&M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$33,280
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,379 /month	\$11,031.55
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$934 /month	\$7,471.10
Water storage tank	\$958 /month	\$7,660.80
Water storage tank line	\$11 /month	\$87.55
Water mains	\$1,751 /month	\$14,008
Service lines	\$1,297 /month	\$10,375
<u>Wastewater system</u>		
Sewer mains	\$1,335 /month	\$10,681
Service lines	\$1,297 /month	\$10,375
Lift/pump station buildings	\$153 /month	\$1,225.73
Force main to septic system	\$47 /month	\$376
	Subtotal	\$73,300
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$552 /month	\$6,619
HVAC/hydronic system	\$552 /month	\$4,413
Water treatment	\$82 /month	\$981
Pumps		
Intake or well	\$82 /month	\$980.58
WST circulation	\$57 /month	\$454
Pressure/booster	\$123 /month	\$1,470.87
Main line circulation	\$902 /month	\$7,217
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$61 /month	\$735
HVAC/hydronic system	\$61 /month	\$490
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$88 /month	\$1,060.96
Sewer/force main glycol circulation	\$225 /month	\$1,801
Septic system discharge pump	\$1,177 /year	\$1,177
	Subtotal	\$27,400
<b>Other Costs</b>		
Equipment R&R	\$6,699 /year	\$6,699
Miscellaneous materials & supplies	\$4,019 /year	\$4,019
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$16,700

### Summary (Townsite)

Administration	\$6,000
Labor	\$33,300
Fuel	\$73,300
Electricity	\$27,400
Other	\$16,700
<b>Total</b>	<b>\$157,000</b>

### Summary (Townsite & Newsite)

Administration	\$6,000
Labor	\$33,300
Fuel	\$86,500
Electricity	\$34,200
Other	\$18,300
<b>Total</b>	<b>\$178,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 114	89	85%	\$ 103,622
Public/Commerc	\$ 119.85	16	100%	\$ 23,012
School Service	\$ 5,707.32	1	100%	\$ 51,366
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 178,000</b>

# Tetlin, Alaska

## Community Information & Existing Infrastructure

Tetlin is an Athabascan community of 131 people located along the Tetlin River, between Tetlin Lake and the Tanana River. There are 43 residential units, 10 commercial/public facilities and one school for a total of 54 services. The existing water and sewer services provided in Tetlin consist of self-haul system from the watering point located at the washeteria and pit privies/honey buckets. Few homes in the community have 350 gallon sewer holding tanks for wastewater disposal. The existing water and sewer infrastructure consists of the following:

- Well – 40 gpm
- Treated Water Storage – N/A
- Watering Point Building – 1,500 SF, built in 1999
- Water Treatment – Grit separator, bag filter
- Sewage Lagoon – Two Cell, 0.25 acres

Soils in the region consist of fine, medium dense, stiff silty sands and silts. Permafrost is pervasive throughout the community; however, cleared areas were found to be thawed to depths of 5-6 feet.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 10,300 feet of pipe, and the pressure sewer system approximately 6,600 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	11	40	-
<b>Water Storage (gallons)</b>	93,900	-	93,900
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	2.8	0.3	2.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,610	-	2,610
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	10,300	-	10,300
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,600	-	6,600
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Tetlin. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village
					Tetlin
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$28,096.69	\$1,517,221
3	Sewage collection mains or services (gravity or force), above ground	LF	10,700	\$301.01	\$3,220,820
10	Sewage lagoon, barrow, local material	Acre	2.5	\$880,950.77	\$2,202,377
12	Water distribution, mains or services, above ground	LF	14,400	\$420.25	\$6,051,565
14	Water storage tank, no foundation	Gal	93,900	\$3.84	\$360,441
15	Water treatment plant, no foundation	SF	1,200	\$2,372.01	\$2,846,410
19	Foundation - thermosyphen stablized gravel pad	SF	2,610	\$255.26	\$666,230
Total Estimated Cost in 2010 dollars (rounded):					<b>\$16,865,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$20,137,700</b>
27	Individual Grinder Pump Stations	EA	54	\$30,000	\$1,620,000
28	Electrical Service Upgrades	EA	54	\$5,500	\$297,000
<b>Subtotal</b>					<b>\$22,054,700</b>
29	Construction Contingency (15%)	LS	1	\$3,308,200	\$3,308,200
30	Design & Construction Administration Services (20%)	LS	1	\$4,410,900	\$4,410,900
<b>Total</b>					<b>\$29,773,800</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$28,300
Fuel	\$27,500
Electricity	\$10,500
Other (R&R, Training, etc.)	\$11,300
<b>Total</b>	<b>\$84,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Tetlin are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 109	43	85%	\$ 47,748
Public/Commercial Service	\$ 114	10	100%	\$ 13,717
School Service	\$ 2,504	1	100%	\$ 22,535
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 84,000</b>

File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Tetlin.dwg



Image © 2016 DigitalGlobe

LEGEND:

PROPOSED WATER MAIN



PROPOSED SEWER/FORCE MAIN



EXISTING PUBLIC STRUCTURE SHOWN ON  
DCRA MAP



EXISTING RESIDENTIAL STRUCTURE SHOWN  
ON DCRA MAP



HOME ADDITION FROM HITS MAP



PROJECT: 31303.00

STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
TETLIN

DATE  
MAR 2015

SCALE  
GRAPHIC

FIGURE  
34

**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 4/11/2016  
 Community Tetlin  
 Input

**Existing Community & System Data**

2015 Population	131
2015 Number of Services	54
HITS Database (E1 & H1-H7)	43
DCED Mapping Commerical/Public Facilities/School	11
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	0
Water Treatment Capacity	40
Existing Sewage Lagoon Size	0.25

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	6600	10300
Gravity Sewer Main			
Pressure Sewer Main	x	6600	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Tetlin

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	11	
Req Water Storage (gallons) (less existing)	93,900	1,410 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	2.5	

Quantity Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200
Water Distribution System	Circulating Water Main with Pitorifices (lf)	10,300
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	6,600
	Individual Grinder Pump Stations (GPS) (ea)	54
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	4,100
	Pressure Sewer Service Lines (lf)	4,100

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	11	40	-
Water Storage (gallons)	93,900	-	93,900
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	2.8	0.3	2.5
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,610	-	2,610
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	10,300	-	10,300
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	6,600	-	6,600
Individual Grinder Pump Stations (GPS) (ea)	54	-	54
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	4,100	-	4,100
Pressure Sewer Service Lines (lf)	4,100	-	4,100



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		4/11/2016 Tetlin	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	131 people	2015 ADOL	
2015 Number of Services	54 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	160 people	Px(1+i)^n	
<b>Water Demand Estimates</b>			
Existing Capacity	40 gpm		
Average Day (ADD)	7,992 gpd	50 gallons per Capita	
Max Day (MDD)	15,984 gpd	2 x ADD	
Peak Hour	33 gpm	3 x MDD	
Treatment Capacity	11 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	11 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	- gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	15,984 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	47,953 gallons	3 days x DO	
Water Storage Tank Volume	93,938 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	LI x (5.057) x (e^-0.0693T)x(e^0.361PH)x(e^0.113RC)	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	56,625 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	93,900 gallons		
Required Additional Storage	93,900 gallons	0	
Estimate of Min Platform Size (3' clearance around)	1,410 sf	D = 0.103xVg^(1/2) H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Thermosyphon stabilized gravel pad (sf)	Pile Foundation
Firm soils, or continuous permafrost	x		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Circulating Water Main with Pitorifices (lf)	Static Water Mains
Above ground system or buried with permafrost	x		Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Sewer Main with Glycol Heat Trace (lf)	Bare sewer main, no heat trace
Above ground or buried with permafrost	x		Sewer main with glycol heat trace
Gravity Sewer Main	0		Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)	Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Circulating Water Service Lines (lf)	Static Water Service Line
Circulating Water Main	x		Circulating Water Service Lines
Gravity Sewer Main	0		Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0.25 acres		
Organic Loading Based Size check	1.4 acres 197.5	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
Hydraulic Loading Based Size	2.8 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	2.8 acres	Either organic loading based or hydraulic, whichever is greater	

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Tetlin**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	54	\$28,096.69	\$1,517,221
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	10,700	\$301.01	\$3,220,820
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	2.5	\$880,950.77	\$2,202,377
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	14,400	\$420.25	\$6,051,565
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	93,900	\$3.84	\$360,441
15	Water treatment plant, no foundation	SF	1,200	\$2,372.01	\$2,846,410
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	2,610	\$255.26	\$666,230
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$16,865,064**

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

**Community:** Tetlin

## General Community Data

Current population	131	persons
Average number of people per house	3.0	
Service Connections		
Number of houses	43	
Number of public/commerical buildings	10	
Number of schools	1	
Total number of service connections	54	
Burdened labor rate	\$17	hr
Electricity cost (Public facility)	\$0.24	kWh
Electricity cost (Residential service)	\$0.21	kWh
Cost per gallon for heating oil	\$2.80	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	2700 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	93,900 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	10300 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	6600 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	1130 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$28,288
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$386 /month	\$3,088.83
Raw water line	\$3 /month	\$36.77
Raw water heat addition	\$223 /month	\$2,676.17
Water storage tank	\$40 /month	\$319.71
Water storage tank line	\$5 /month	\$40.86
Water mains	\$1,052 /month	\$8,417
Service lines	\$414 /month	\$3,309
<u>Wastewater system</u>		
Sewer mains	\$674 /month	\$5,393
Service lines	\$414 /month	\$3,309
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$115 /month	\$923
	Subtotal	\$27,500
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$189 /month	\$2,269
HVAC/hydronic system	\$189 /month	\$1,513
Water treatment	\$24 /month	\$287
Pumps		
Intake or well	\$24 /month	\$286.73
WST circulation	\$32 /month	\$259
Pressure/booster	\$36 /month	\$430.10
Main line circulation	\$516 /month	\$4,124
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$129 /month	\$1,029
Lagoon discharge pump	\$344 /year	\$344
	Subtotal	\$10,500
<b>Other Costs</b>		
Equipment R&R	\$3,314 /year	\$3,314
Miscellaneous materials & supplies	\$1,989 /year	\$1,989
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$11,300

## Summary

Administration	\$6,000
Labor	\$28,300
Fuel	\$27,500
Electricity	\$10,500
Other	\$11,300
<b>Total</b>	<b>\$84,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 109	43	85%	\$ 47,748
Public/Commerc	\$ 114.31	10	100%	\$ 13,717
School Service	\$ 2,503.89	1	100%	\$ 22,535
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 84,000</b>

# Tuluksak, Alaska

## Community Information & Existing Infrastructure

Tuluksak is a Yupik Eskimo community of 372 people located on the south bank of the Tuluksak River at its junction with the Kuskokwim River. There are 92 residential units, 21 commercial/public facilities and one school for a total of 114 services. The existing water and sewer services provided in Tuluksak consist of self-haul system from the watering point attached to the washeteria and pit privies. The existing water and sewer infrastructure consists of the following:

- Well – 20 gpm
- Treated Water Storage – 100,000 gallons
- Water Treatment Plant – 2,048 SF, built in 1982, Upgraded in 2003
- Water Treatment – Chlorine, Potassium permanganate, Greensand filter
- Sewage Lagoon – Two cell, 0.52 acre

Soils around Tuluksak consist of silt with silty sand. Groundwater level is close to the level of the river.

## Piped System Description

The piped water and sewer system will be a buried system. The water system will consist of approximately 13,400 feet of pipe, and the gravity sewer system approximately 12,200 feet of pipe. The water system will consist of two circulating loops. The pressure sewer system would require one sewer main lift station (existing), individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	32	20	12
<b>Water Storage (gallons)</b>	211,600	100,000	111,600
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	7.9	0.5	7.4
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,830	-	2,830
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	13,400	-	13,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,200	-	12,200
Individual Grinder Pump Stations (GPS) (ea)	114	-	114
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,600	-	8,600
Gravity Sewer Service Lines (lf)	8,550	-	8,550

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Tuluksak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs				Village	
				Tuluksak	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	114	\$26,403.25	\$3,009,971
2	Sewage collection mains or services (gravity or force), buried	LF	20,750	\$254.26	\$ 5,275,960
10	Sewage lagoon, barrow, local material	Acre	7.4	\$692,040.19	\$5,121,097
13	Water distribution, mains or services, buried	LF	22,000	\$280.91	\$6,179,961
14	Water storage tank, no foundation	Gal	111,600	\$3.25	\$362,886
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
19	Foundation - thermosyphen stablized gravel pad	SF	2,830	\$266.47	\$754,111
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$22,820,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$27,248,300</b>
27	Individual Grinder Pump Stations	EA	114	\$30,000	\$3,420,000
28	Electrical Service Upgrades	EA	114	\$5,500	\$627,000
<b>Subtotal</b>					<b>\$31,295,300</b>
29	Construction Contingency (15%)	LS	1	\$4,694,300	\$4,694,300
30	Design & Construction Administration Services (20%)	LS	1	\$6,259,100	\$6,259,100
<b>Total</b>					<b>\$42,248,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$26,000
Fuel	\$99,900
Electricity	\$24,000
Other (R&R, Training, etc.)	\$18,000
<b>Total</b>	<b>\$174,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Tuluksak are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 104	92	85%	\$ 98,032
Public/Commercial Service	\$ 115	21	100%	\$ 28,958
School Service	\$ 5,223	1	100%	\$ 47,010
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 174,000</b>



File: J:\jobdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Tuluksak.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 4/19/2016  
 Community Tuluksak  
 Input

**Existing Community & System Data**

2015 Population	372
2015 Number of Services	114
HITS Database (E1 & H1-H7)	92
DCED Mapping Commercial/Public Facilities/School	22
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	100000
Water Treatment Capacity	20
Existing Sewage Lagoon Size	0.52

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	12200	13400
Gravity Sewer Main	x	12200	
Pressure Sewer Main			
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Tuluksak

**Output for Cost Model (calculated)**

		Foundation Size
Water Treatment Capacity (gpm)	32	
Req Water Storage (gallons) (less existing)	111,600	1,630 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Sewage Lagoon Size (acre) (less existing)	7.4	

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	13,400	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	12,200	
	Lift Stations for Gravity Sewer Mains	1	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	8,600	
	Gravity Sewer Service Lines (lf)	8,550	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	32	20	12
Water Storage (gallons)	211,600	100,000	111,600
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	7.9	0.5	7.4
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	2,830	-	2,830
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	13,400	-	13,400
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	12,200	-	12,200
Individual Grinder Pump Stations (GPS) (ea)	114	-	114
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	8,600	-	8,600
Gravity Sewer Service Lines (lf)	8,550	-	8,550

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date Community		4/19/2016 Tuluksak	
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	372 people	2015 ADOL	
2015 Number of Services	114 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	454 people	$P \times (1+i)^n$	
<b>Water Demand Estimates</b>			
Existing Capacity	20 gpm		
Average Day (ADD)	22,696 gpd	50 gallons per Capita	
Max Day (MDD)	45,391 gpd	2 x ADD	
Peak Hour	95 gpm	3 x MDD	
Treatment Capacity	32 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	32 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	100,000 gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	45,391 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	136,173 gallons	3 days x DO	
Water Storage Tank Volume	211,564 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	$L \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	160,797 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	211,600 gallons		
Required Additional Storage	111,600 gallons	0	
Estimate of Min Platform Size (3' clearance around)	1,630 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation	
Firm soils, or continuous permafrost	x	Thermosyphon stabilized gravel pad (sf)	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad	
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Static Water Mains	
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)	Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Bare sewer main, no heat trace	
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)	Sewer main with glycol heat trace
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	0	Individual Grinder Pump Stations	
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Static Water Service Line	
Circulating Water Main	x	Circulating Water Service Lines (lf)	Circulating Water Service Lines
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)	Gravity Service Line
Pressure Sewer Main	0	Pressure Service Line with GPS	
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0.52 acres		
Organic Loading Based Size check	3.9 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
	332.8		
Hydraulic Loading Based Size	7.9 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	7.9 acres	Either organic loading based or hydraulic, whichever is greater	

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Tuluksak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	114	\$26,403.25	\$3,009,971
2	Sewage collection mains or services (gravity or force), buried	LF	20,750	\$254.26	\$5,275,960
3	Sewage collection mains or services (gravity or force), above ground	LF	0	#DIV/0!	\$0
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	7.4	\$692,040.19	\$5,121,097
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	0	#DIV/0!	\$0
13	Water distribution, mains or services, buried	LF	22,000	\$280.91	\$6,179,961
14	Water storage tank, no foundation	Gal	111,600	\$3.25	\$362,886
15	Water treatment plant, no foundation	SF	1,200	\$1,635.59	\$1,962,712
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stablized gravel pad	SF	2,830	\$266.47	\$754,111
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$22,820,295**



# O&M Cost Estimate Piped Water & Sewer System

10/7/2016

**Community:** Tuluksak

## General Community Data

Current population	372 persons
Average number of people per house	4.0
Service Connections	
Number of houses	92
Number of public/commerical buildings	21
Number of schools	1
Total number of service connections	114
Burdened labor rate	\$13 hr
Electricity cost (Public facility)	\$0.30 kWh
Electricity cost (Residential service)	\$0.66 kWh
Cost per gallon for heating oil	\$6.13 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	Buried

### Water Treatment

Size of water treatment plant building	3248 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	211,600 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	13400 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by existing lift/pump station	114
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	12200 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	Buried
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	2125 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	Buried
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

10/7/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

10/7/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$26,000
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,017 /month	\$8,134.85
Raw water line	\$7 /month	\$80.50
Raw water heat addition	\$1,386 /month	\$16,637.51
Water storage tank	\$197 /month	\$1,577.28
Water storage tank line	\$11 /month	\$89.45
Water mains	\$1,798 /month	\$21,575
Service lines	\$1,147 /month	\$13,766
<u>Wastewater system</u>		
Sewer mains	\$1,637 /month	\$19,643
Service lines	\$1,147 /month	\$13,766
Lift/pump station buildings	\$157 /month	\$1,252.29
Force main to lagoon	\$285 /month	\$3,421
	Subtotal	\$99,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$284 /month	\$3,412
HVAC/hydronic system	\$284 /month	\$3,412
Water treatment	\$85 /month	\$1,018
Pumps		
Intake or well	\$85 /month	\$1,017.79
WST circulation	\$41 /month	\$324
Pressure/booster	\$127 /month	\$1,526.69
Main line circulation	\$644 /month	\$7,733
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$44 /month	\$525
HVAC/hydronic system	\$44 /month	\$350
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$126 /month	\$1,513.41
Sewer/force main glycol circulation	\$161 /month	\$1,930
Lagoon discharge pump	\$1,222 /year	\$1,222
	Subtotal	\$24,000
<b>Other Costs</b>		
Equipment R&R	\$7,495 /year	\$7,495
Miscellaneous materials & supplies	\$4,497 /year	\$4,497
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,000

## Summary

Administration	\$6,000
Labor	\$26,000
Fuel	\$99,900
Electricity	\$24,000
Other	\$18,000
<b>Total</b>	<b>\$174,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 104	92	85%	\$ 98,032
Public/Commerc	\$ 114.91	21	100%	\$ 28,958
School Service	\$ 5,223.34	1	100%	\$ 47,010
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 174,000</b>

# Tuntutuliak, Alaska

## Community Information & Existing Infrastructure

Tuntutuliak is a Yupik Eskimo community of 437 people located on the Qinaq River, approximately 3 miles from its confluence with the Kuskokwim River. There are 105 residential units, 19 commercial/public facilities and one school for a total of 125 services. The existing water and sewer services provided in Tuntutuliak consist of self-haul system from either the watering point attached to the washeteria or rainwater/ice collection, and pit privies/honey bucket bunkers. The existing water and sewer infrastructure consists of the following:

- Well – 12 gpm
- Treated Water Storage – 20,000 gallons
- Water Treatment Plant – 2,240 SF, built in 1983, Upgraded in 2015
- Water Treatment – Greensand filter, chlorine, potassium permanganate
- Sewage Lagoon – Single cell, 1.4 acre

Soils around Tuntutuliak consist of ice rich silt. High settlement in soil is anticipated if thawed due to high ice content and fine grained and organic materials.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 17,600 feet of pipe, and the pressure sewer system approximately 14,700 feet of pipe. The water system will consist of two separate systems for the east and west sides of the community. Each system will have a single circulating loop. The pressure sewer system would require one sewer main lift station, individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, two new 1200 sf facilities are included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	37	12	25
<b>Water Storage (gallons)</b>	243,300	20,000	223,300
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	2,400	-	2,400
<b>Sewage Lagoon Size (acre)</b>	9.3	1.4	7.9
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	5,390	-	5,390
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,600	-	17,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,700	-	14,700
Individual Grinder Pump Stations (GPS) (ea)	125	-	125
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,400	-	9,400
Pressure Sewer Service Lines (lf)	9,400	-	9,400



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Tuntutuliak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Tuntutuliak
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	125	\$26,342.77	\$3,292,847
3	Sewage collection mains or services (gravity or force), above ground	LF	24,100	\$194.96	\$4,698,582
4	Sewage lift station	EA	1	\$ 662,130.80	\$ 662,131
10	Sewage lagoon, barrow, local material	Acre	7.9	\$683,500.68	\$5,399,655
12	Water distribution, mains or services, above ground	LF	27,000	\$327.06	\$8,830,671
14	Water storage tank, no foundation	Gal	223,300	\$2.49	\$556,081
15	Water treatment plant, no foundation	SF	2,400	\$1,583.60	\$3,800,638
18	Foundation - freeze back piles	SF	5,390	\$299.51	\$1,614,365
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$29,009,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$34,638,300</b>
27	Individual Grinder Pump Stations	EA	125	\$30,000	\$3,750,000
28	Electrical Service Upgrades	EA	125	\$5,500	\$687,500
<b>Subtotal</b>					<b>\$39,075,800</b>
29	Construction Contingency (15%)	LS	1	\$5,861,400	\$5,861,400
30	Design & Construction Administration Services (20%)	LS	1	\$7,815,200	\$7,815,200
<b>Total</b>					<b>\$52,752,400</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$25,000
Fuel	\$97,600
Electricity	\$31,600
Other (R&R, Training, etc.)	\$18,300
<b>Total</b>	<b>\$179,000</b>


VSW - Unserved Communities Project  
Tuntutuliak Piped Water & Sewer Assessment

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Tuntutuliak are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 98	105	85%	<b>\$ 105,485</b>
Public/Commercial Service	\$ 128	19	100%	<b>\$ 29,193</b>
School Service	\$ 4,925	1	100%	<b>\$ 44,322</b>
Local Capital Contribution				<b>\$ -</b>
<b>Total Revenue</b>				<b>\$ 179,000</b>



File: J:\Jobsdata\31303.00 VSW - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Tuntutuliak.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date  
Community  
Input

4/20/2016  
Tuntutuliak

**Existing Community & System Data**

2015 Population	437
2015 Number of Services	125
HITS Database (E1 & H1-H7)	105
DCED Mapping Commerical/Public Facilities/School	20
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	20000
Water Treatment Capacity	12
Existing Sewage Lagoon Size	1.4

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	<input checked="" type="checkbox"/>
Firm soils, or continuous permafrost	<input type="checkbox"/>
Stiff soils, no permafrost	<input type="checkbox"/>

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	<input checked="" type="checkbox"/>	14700	17600
Gravity Sewer Main			
Pressure Sewer Main	<input checked="" type="checkbox"/>	14700	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community      Tuntutuliak

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	37		
Req Water Storage (gallons) (less existing)	223,300	2,990	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	2,400	sf
Req Sewage Lagoon Size (acre) (less existing)	7.9		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf)	2,400	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	17,600	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	14,700	
	Individual Grinder Pump Stations (GPS) (ea)	125	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	9,400	
	Pressure Sewer Service Lines (lf)	9,400	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	37	12	25
Water Storage (gallons)	243,300	20,000	223,300
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	2,400	-	2,400
Sewage Lagoon Size (acre)	9.3	1.4	7.9
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	5,390	-	5,390
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	17,600	-	17,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	14,700	-	14,700
Individual Grinder Pump Stations (GPS) (ea)	125	-	125
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,400	-	9,400
Pressure Sewer Service Lines (lf)	9,400	-	9,400



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	4/20/2016	
Community	Tuntutuliak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	437 people	2015 ADOL
2015 Number of Services	125 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	533 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	12 gpm	
Average Day (ADD)	26,661 gpd	50 gallons per Capita
Max Day (MDD)	53,322 gpd	2 x ADD
Peak Hour	111 gpm	3 x MDD
Treatment Capacity	37 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	37 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	20,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	53,322 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	159,967 gallons	3 days x DO
Water Storage Tank Volume	243,289 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	188,894 gallons	CT/RCxPeak Hour/BF
Required Water Storage	243,300 gallons	
Required Additional Storage	223,300 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,990 sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	1.4 acres	
Organic Loading Based Size check	4.5 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
	360.7	
Hydraulic Loading Based Size	9.3 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	9.3 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

Tuntutuliak

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	125	\$26,342.77	\$3,292,847
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	24,100	\$194.96	\$4,698,582
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	7.9	\$683,500.68	\$5,399,655
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	27,000	\$327.06	\$8,830,671
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	223,300	\$2.49	\$556,081
15	Water treatment plant, no foundation	SF	2,400	\$1,583.60	\$3,800,638
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	5,390	\$299.51	\$1,614,365
19	Foundation - thermosyphen stablized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$29,008,567**

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

**Community:** Tuntutuliak

## General Community Data

Current population	437	persons
Average number of people per house	4.2	
Service Connections		
Number of houses	105	
Number of public/commerical buildings	19	
Number of schools	1	
Total number of service connections	125	
Burdened labor rate	\$12	hr
Electricity cost (Public facility)	\$0.41	kWh
Electricity cost (Residential service)	\$0.24	kWh
Cost per gallon for heating oil	\$4.88	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Treatment

Size of water treatment plant building	4640 sf
Raw water quality (Good or Poor)	Poor

### Water Storage

Size of tank(s)	243,300 gallons
Length of water line to/ from tank	100 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	17600 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	1
Number of facilities served by lift/pump station #1	125
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	14700 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

### Wastewater Treatment / Disposal

Length of force main	1800 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

9/14/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	40 hrs/week	\$24,960
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,156 /month	\$9,251.47
Raw water line	\$18 /month	\$142.42
Raw water heat addition	\$1,297 /month	\$10,372.77
Water storage tank	\$180 /month	\$1,443.76
Water storage tank line	\$18 /month	\$142.42
Water mains	\$3,133 /month	\$25,066
Service lines	\$1,669 /month	\$13,352
<u>Wastewater system</u>		
Sewer mains	\$2,617 /month	\$20,935
Service lines	\$1,669 /month	\$13,352
Lift/pump station buildings	\$125 /month	\$996.93
Force main to lagoon	\$320 /month	\$2,564
	Subtotal	\$97,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$555 /month	\$6,662
HVAC/hydronic system	\$555 /month	\$4,442
Water treatment	\$136 /month	\$1,634
Pumps		
Intake or well	\$136 /month	\$1,634.03
WST circulation	\$55 /month	\$443
Pressure/booster	\$204 /month	\$2,451.05
Main line circulation	\$881 /month	\$7,045
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$60 /month	\$718
HVAC/hydronic system	\$60 /month	\$479
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$195 /month	\$2,334.33
Sewer/force main glycol circulation	\$220 /month	\$1,758
Lagoon discharge pump	\$1,962 /year	\$1,962
	Subtotal	\$31,600
<b>Other Costs</b>		
Equipment R&R	\$7,708 /year	\$7,708
Miscellaneous materials & supplies	\$4,625 /year	\$4,625
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$18,300

## Summary

Administration	\$6,000
Labor	\$25,000
Fuel	\$97,600
Electricity	\$31,600
Other	\$18,300
<b>Total</b>	<b>\$179,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 98	105	85%	\$ 105,485
Public/Commerc	\$ 128.04	19	100%	\$ 29,193
School Service	\$ 4,924.62	1	100%	\$ 44,322
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 179,000</b>

# Tununak, Alaska

---

## Community Information & Existing Infrastructure

Tununak is a Yupik Eskimo community of 384 people located in a small bay on the northeast coast of Nelson Island. There are 99 residential units, 22 commercial/public facilities and one school for a total of 122 services. The existing water and sewer services provided in Tununak consist of self-haul system from watering points and honey buckets. There are two septic tanks in the community. One septic tank serves the water treatment plant/washeteria, school, and teacher housing. The second septic tank is used for the disposal of wastewater collected from haul system. The water treatment plant provides service to the washeteria and the clinic. The existing water and sewer infrastructure consists of the following:

- Unnamed Creek – N/A
- Treated Water Storage – 50,000 gallons
- Water Treatment Plant/Washeteria – 2,048 SF, built in 1980
- Water Treatment – Granular media filtration, bag filtration, chlorination
- Septic Tanks – 12,000 gallons (failing)
- Sewage Lagoon – N/A

The area around Tununak is underlain by discontinuous permafrost. Conditions vary considerably from toe of hill to vicinity of creek. There is a very high ice content in organic soils blanketing the area, and is very thaw unstable.

## Piped System Description

The piped water and sewer system will be a combination of above and below grade piping. The lowland part of the community is flat terrain and would best be served by an above ground pressure sewer system (4,800 LF) and circulating water loop (9,300 LF). The upland part of the community is built on a hillside and can likely accommodate a buried gravity sewer system (5,100 linear feet) and circulating water main (5,800 LF). A total of 22 services will be connected to the buried gravity sewer will not require individual grinder pump stations (GPS). Approximately 100 homes and buildings on the lower portion of the community would require GPS units. The current water source is seasonal; however, many residents obtain drinking water from the school which uses a well. For the purposes of this assessment a new well is proposed. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The following table summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	33	-	33
<b>Water Storage (gallons)</b>	217,400	50,000	167,400
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Septic System (sf)</b>	40,000	-	40,000
<b>Required Foundation System for WTP and/or WST</b>			
Pile foundation (sf)	3,520	-	3,520
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	15,100	-	15,100
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,900	-	9,900
Individual Grinder Pump Stations (GPS) (ea)	100	-	100
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,200	-	9,200
Pressure Sewer Service Lines (lf)	7,500	-	7,500
Gravity Sewer Service Lines (lf)	1,700	-	1,700

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Tununak. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

VSW - Unserved Communities Project  
Tununak Piped Water & Sewer Assessment

Estimated Capital Costs				Village	
				Tununak	
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	122	\$26,342.77	\$3,213,818
2	Sewage collection mains or services (gravity or force), buried	LF	6,800	\$273.12	\$1,857,230
3	Sewage collection mains or services (gravity or force), above ground	LF	12,300	\$199.20	\$2,450,128
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
7	Septic tank, community	EA	2	\$298,917.16	\$597,834
8	Drainfield, community	SF	40000	\$21.63	\$865,249
12	Water distribution, mains or services, above ground	LF	16,800	\$328.95	\$5,526,373
13	Water distribution, mains or services, buried	LF	7,500	\$297.51	\$2,231,320
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
18	Foundation - freeze back piles	SF	3,520	\$318.83	\$1,122,279
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
Total Estimated Cost in 2010 dollars (rounded):					<b>\$20,610,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$24,609,400</b>
27	Individual Grinder Pump Stations	EA	100	\$30,000	\$3,000,000
28	Electrical Service Upgrades	EA	122	\$5,500	\$671,000
Subtotal					<b>\$28,280,400</b>
29	Construction Contingency (15%)	LS	1	\$4,242,100	\$4,242,100
30	Design & Construction Administration Services (20%)	LS	1	\$5,656,100	\$5,656,100
Total					<b>\$38,178,600</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$23,300
Fuel	\$118,000
Electricity	\$22,200
Other (R&R, Training, etc.)	\$19,100
<b>Total</b>	<b>\$189,000</b>




The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Tununak are listed below:

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 109	99	85%	\$ 109,875
Public/Commercial Service	\$ 114	22	100%	\$ 30,162
School Service	\$ 5,440	1	100%	\$ 48,964
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 189,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Tununak.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 4/22/2016  
 Community Tununak  
 Input

**Existing Community & System Data**

2015 Population	384
2015 Number of Services	122
HITS Database (E1 & H1-H7)	99
DCED Mapping Commercial/Public Facilities/School	23
Type (surface water or groundwater)	SW
Water quality (Poor or Good)	Poor
Water Storage Tank	50000
Water Treatment Capacity	0
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	x
Firm soils, or continuous permafrost	
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	9900	15100
Gravity Sewer Main	x	5100	
Pressure Sewer Main	x	4800	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Tununak

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	33	
Req Water Storage (gallons) (less existing)	167,400	2,320 sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Septic System w/ Drainfield (sf) (less existing)	40,000	

	Quantity	Notes
Required Foundation System for WTP and/or WST	Pile Foundation (sf) 1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf) 15,100	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf) 9,900 Lift Stations for Gravity Sewer Mains 1 Individual Grinder Pump Stations (GPS) (ea) 100	
Water & Sewer Service Lines	Circulating Water Service Lines (lf) 9,200 Gravity Sewer Service Lines (lf) 1,700 Pressure Sewer Service Lines (lf) 7,500	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	33	-	33
Water Storage (gallons)	217,400	50,000	167,400
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	40,000	-	40,000
<b>Required Foundation System for WTP and/or WST</b>			
Pile Foundation (sf)	3,520	-	3,520
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	15,100	-	15,100
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	9,900	-	9,900
Individual Grinder Pump Stations (GPS) (ea)	100	-	100
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	9,200	-	9,200
Pressure Sewer Service Lines (lf)	7,500	-	7,500
Gravity Sewer Service (lf)	1,700	-	1,700

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date Community	4/22/2016 Tununak	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	384 people	2015 ADOL
2015 Number of Services	122 services	Only 55 will require GPS units
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	469 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	0 gpm	
Average Day (ADD)	23,428 gpd	50 gallons per Capita
Max Day (MDD)	46,855 gpd	2 x ADD
Peak Hour	98 gpm	3 x MDD
Treatment Capacity	33 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	33 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	50,000 gallons	Built in 2010
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	46,855 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	140,566 gallons	3 days x DO
Water Storage Tank Volume	217,421 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{(-0.0693T)}) \times (e^{(0.361PH)}) \times (e^{(0.113RC)})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	165,984 gallons	CT/RCxPeak Hour/BF
Required Water Storage	217,400 gallons	
Required Additional Storage	167,400 gallons	0
Estimate of Min Platform Size (3' clearance around)	2,320 sf	$D = 0.103 \times Vg^{(1/2)}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	x	Pile Foundation (sf)
Firm soils, or continuous permafrost	0	Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	x	Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	x	Gravity Sewer Service Lines (lf)
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	0 acres	
Organic Loading Based Size check	4.0 acres 338.1	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
Hydraulic Loading Based Size	8.2 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	8.2 acres	Either organic loading based or hydraulic, whichever is greater



**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Tununak**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	122	\$26,342.77	\$3,213,818
2	Sewage collection mains or services (gravity or force), buried	LF	6,800	\$273.12	\$1,857,230
3	Sewage collection mains or services (gravity or force), above ground	LF	12,300	\$199.20	\$2,450,128
4	Sewage lift station	EA	1	\$662,130.80	\$662,131
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	2	\$298,917.16	\$597,834
8	Drainfield, community	SF	40,000	\$21.63	\$865,249
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	16,800	\$328.95	\$5,526,373
13	Water distribution, mains or services, buried	LF	7,500	\$297.51	\$2,231,320
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$1,608.15	\$1,929,775
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	3,520	\$318.83	\$1,122,279
19	Foundation - thermosyphen stabilized gravel pad	SF	0	#DIV/0!	\$0
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	1	\$153,596.80	\$153,597
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$20,609,734**

# O&M Cost Estimate Piped Water & Sewer System

9/16/2016

**Community:** Tununak (Lowland)

## General Community Data

Current population	384	persons
Average number of people per house	7.1	
Service Connections (Lowland)		
Number of houses	54	
Number of public/commerical buildings	19	
Number of schools	0	
Total number of service connections	73	
Burdened labor rate	\$14	hr
Electricity cost (Public facility)	\$0.34	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.95	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))		
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)	Yes	
Location of water line (Above ground (AG) or Buried)	Buried	

### Water Treatment

Size of water treatment plant building	3248	sf
Raw water quality (Good or Poor)	Poor	

### Water Storage

Size of tank(s)	217,400	gallons
Length of water line to/ from tank	50	ft
Water line heated for freeze protection (Yes or No)	Yes	
Location of water line (Above ground (AG) or Buried)	AG	

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ	
Number of circulating water loops	1	
Total length of Water Main (Lowland)	9300	ft
Water mains heated for freeze protection (Yes or No)	Yes	
Location of the mains (Above ground (AG) or Buried)	AG	
Average service line length	75	ft

### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure	
Number of individual facility pump stations		
Number of community lift/pump stations		
Number of facilities served by lift/pump station #1		
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations	500	sf
Total length of sewer mains (North Side)	4800	ft
Sewer mains heated for freeze protection (Yes or No)	Yes	
Number of circulating glycol loops	1	
Location of the mains (Above ground (AG) or Buried)	AG	
Average service line length	75	ft

### Wastewater Treatment / Disposal

Length of force main	565	ft
Force main heated for freeze protection (Yes or No)	Yes	
Location of force main (Above ground (AG) or Buried)	AG	
Lagoon discharged seasonally with pump (Yes or No)	Yes	

# O&M Cost Estimate Piped Water & Sewer System

9/16/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/16/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$23,296
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,153 /month	\$9,223.03
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$1,623 /month	\$19,471.56
Water storage tank	\$230 /month	\$1,837.29
Water storage tank line	\$13 /month	\$101.41
Water mains	\$2,358 /month	\$18,863
Service lines	\$1,388 /month	\$11,105
<u>Wastewater system</u>		
Sewer mains	\$1,217 /month	\$9,736
Service lines	\$1,388 /month	\$11,105
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$143 /month	\$1,146
	Subtotal	\$82,600
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$322 /month	\$3,867
HVAC/hydronic system	\$322 /month	\$2,578
Water treatment	\$99 /month	\$1,191
Pumps		
Intake or well	\$99 /month	\$1,190.71
WST circulation	\$46 /month	\$367
Pressure/booster	\$149 /month	\$1,786.06
Main line circulation	\$365 /month	\$2,921
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$91 /month	\$729
Lagoon discharge pump	\$1,430 /year	\$1,430
	Subtotal	\$16,100
<b>Other Costs</b>		
Equipment R&R	\$6,100 /year	\$6,100
Miscellaneous materials & supplies	\$3,660 /year	\$3,660
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$15,800

### Summary (Lowland)

Administration	\$6,000
Labor	\$23,300
Fuel	\$82,600
Electricity	\$16,100
Other	\$15,800
<b>Total</b>	<b>\$144,000</b>

### Summary (Lowland & Upland)

Administration	\$6,000
Labor	\$23,300
Fuel	\$118,000
Electricity	\$22,200
Other	\$19,100
<b>Total</b>	<b>\$189,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 109	99	85%	\$ 109,875
Public/Commerc	\$ 114.25	22	100%	\$ 30,162
School Service	\$ 5,440.41	1	100%	\$ 48,964
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 189,000</b>



# O&M Cost Estimate Piped Water & Sewer System

9/16/2016

**Community:** Tununak (Upland)

## General Community Data

Current population		persons
Average number of people per house	7.1	
Service Connections (South Side)		
Number of houses	45	
Number of public/commerical buildings	3	
Number of schools	1	
Total number of service connections	49	
Burdened labor rate	\$14	hr
Electricity cost (Public facility)	\$0.34	kWh
Electricity cost (Residential service)	\$0.20	kWh
Cost per gallon for heating oil	\$6.95	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

## Water & Sewer System Characteristics

### Water Source

Type of system (Surface(SW) or Groundwater(GW))		
Length of raw water line		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Treatment

Size of water treatment plant building		sf
Raw water quality (Good or Poor)		

### Water Storage

Size of tank(s)		gallons
Length of water line to/ from tank		ft
Water line heated for freeze protection (Yes or No)		
Location of water line (Above ground (AG) or Buried)		

### Water Distribution

Type of system (Static or Circulating (Circ))	Circ	
Number of circulating water loops	1	
Total length of Water Main	5800	ft
Water mains heated for freeze protection (Yes or No)	Yes	
Location of the mains (Above ground (AG) or Buried)	Buried	
Average service line length	75	ft

### Wastewater Collection

Type of system (Gravity or Pressure)		
Number of individual facility pump stations		
Number of community lift/pump stations	1	
Number of facilities served by lift/pump station #1	22	
Number of facilities served by lift/pump station #2		
Number of facilities served by lift/pump station #3		
Number of facilities served by lift/pump station #4		
Number of facilities served by lift/pump station #5		
Size of lift stations		sf
Total length of sewer mains	5100	ft
Sewer mains heated for freeze protection (Yes or No)	Yes	
Number of circulating glycol loops	1	
Location of the mains (Above ground (AG) or Buried)	Buried	
Average service line length	75	ft

### Wastewater Treatment / Disposal

Length of force main	1167	ft
Force main heated for freeze protection (Yes or No)	Yes	
Location of force main (Above ground (AG) or Buried)	Buried	
Lagoon discharged seasonally with pump (Yes or No)	Yes	

# O&M Cost Estimate

## Piped Water & Sewer System

9/16/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management		/month
-----------------------------	--	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/16/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$0 /month	\$0
<b>Labor</b> (WTP Operator)	24 hrs/week	\$0
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$0 /month	\$0.00
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$0 /month	\$0.00
Water storage tank	\$0 /month	\$0.00
Water storage tank line	\$0 /month	\$0.00
Water mains	\$882 /month	\$10,588
Service lines	\$559 /month	\$6,709
<u>Wastewater system</u>		
Sewer mains	\$776 /month	\$9,310
Service lines	\$559 /month	\$6,709
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$178 /month	\$2,130
	Subtotal	\$35,400
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Water treatment	\$0 /month	\$0
Pumps		
Intake or well	\$0 /month	\$0.00
WST circulation	\$0 /month	\$0
Pressure/booster	\$0 /month	\$0.00
Main line circulation	\$365 /month	\$4,382
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$48 /month	\$581.21
Sewer/force main glycol circulation	\$91 /month	\$1,093
Lagoon discharge pump	\$0 /year	\$0
	Subtotal	\$6,100
<b>Other Costs</b>		
Equipment R&R	\$2,075 /year	\$2,075
Miscellaneous materials & supplies	\$1,245 /year	\$1,245
Water quality testing	\$0 /year	\$0
Operator training	\$0 /year	\$0
Insurance	\$0 /year	\$0
	Subtotal	\$3,300

## Summary (Upland)

Administration	\$0	Covered in Lowland Estimate
Labor	\$0	Covered in Lowland Estimate
Fuel	\$35,400	
Electricity	\$6,100	
Other	\$3,300	
<b>Total</b>	<b>\$45,000</b>	

# Venetie, Alaska

## Community Information & Existing Infrastructure

Venetie is a Gwich'in community of 186 people located on the north side of the Chandalar River. There are 76 residential units, 16 commercial/public facilities and one school for a total of 93 services. The existing water and sewer services provided in Venetie consist of self-haul system from the watering point attached to the water treatment plant and pit privies/honey bucket. The school, clinic, teacher housing have piped water and sewer services. The existing water and sewer infrastructure consists of the following:

- Well – 30 gpm
- Treated Water Storage – 428,000 gallons
- Water Treatment Plant – 1,536 SF, built in 1987, Upgraded in 2013
- Water Treatment – Bag filters, hypochlorite
- Sewage Lagoon – Three cell, 3.3 acre

Soils around Venetie generally consist of soft poorly drained soils with discontinuous permafrost. Sandy gravel underlies Venetie at depths of 3-7 feet and extends to depths of 30 feet or more.

## Piped System Description

The piped water and pressure sewer system will be an above grade system. The water system will consist of approximately 25,900 feet of pipe, and the pressure sewer system approximately 16,000 feet of pipe. The water system will consist of three circulating loops. The pressure sewer system would require individual grinder pump stations at each house and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	16	30	-
<b>Water Storage (gallons)</b>	120,800	428,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Sewage Lagoon Size (acre)</b>	4.0	3.3	0.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	25,900	-	25,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	16,000	-	16,000
Individual Grinder Pump Stations (GPS) (ea)	93	-	93
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	7,000	-	7,000
Pressure Sewer Service Lines (lf)	7,000	-	7,000



## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Venetie. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 27-30).

Estimated Capital Costs					Village Venetie
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	93	\$28,096.69	\$2,612,992
3	Sewage collection mains or services (gravity or force), above ground	LF	23,000	\$303.80	\$6,987,444
10	Sewage lagoon, barrow, local material	Acre	0.7	\$1,461,213.17	\$1,022,849
12	Water distribution, mains or services, above ground	LF	32,900	\$422.45	\$13,898,753
15	Water treatment plant, no foundation	SF	1,200	\$2,467.77	\$2,961,322
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$691.55	\$829,855
Total Estimated Cost in 2010 dollars (rounded):					<b>\$28,313,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$33,807,200</b>
27	Individual Grinder Pump Stations	EA	93	\$30,000	\$2,790,000
28	Electrical Service Upgrades	EA	93	\$5,500	\$511,500
Subtotal					<b>\$37,108,700</b>
29	Construction Contingency (15%)	LS	1	\$5,566,300	\$5,566,300
30	Design & Construction Administration Services (20%)	LS	1	\$7,421,700	\$7,421,700
Total					<b>\$50,096,700</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.


Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$23,300
Fuel	\$164,900
Electricity	\$30,900
Other (R&R, Training, etc.)	\$23,500
<b>Total</b>	<b>\$249,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Venetie are listed below.

Estimated User Fees				
Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Service	\$ 180	76	85%	\$ 139,388
Public/Commercial Service	\$ 234	16	100%	\$ 44,880
School Service	\$ 7,192	1	100%	\$ 64,731
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 249,000</b>



File: J:\Jobsdata\31303.00 Vsw - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Venetie.dwg





**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 4/22/2016  
Community Venetie  
Input

**Existing Community & System Data**

2015 Population	186
2015 Number of Services	93
HITS Database (E1 & H1-H7)	76
DCED Mapping Commerical/Public Facilities/School	17
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	428000
Water Treatment Capacity	30
Existing Sewage Lagoon Size	3.3

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	16000	25900
Gravity Sewer Main			
Pressure Sewer Main	x	16000	
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Venetie

**Output for Cost Model (calculated)**

		<b>Foundation Size</b>	
Water Treatment Capacity (gpm)	16		
Req Water Storage (gallons) (less existing)	-	-	sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200	sf
Req Sewage Lagoon Size (acre) (less existing)	0.7		

		Quantity	Notes
Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200	
Water Distribution System	Circulating Water Main with Pitorifices (lf)	25,900	
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	16,000	
	Individual Grinder Pump Stations (GPS) (ea)	93	
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	7,000	
	Pressure Sewer Service Lines (lf)	7,000	

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	16	30	-
Water Storage (gallons)	120,800	428,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Sewage Lagoon Size (acre)	4.0	3.3	0.7
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	25,900	-	25,900
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	16,000	-	16,000
Individual Grinder Pump Stations (GPS) (ea)	93	-	93
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	7,000	-	7,000
Pressure Sewer Service Lines (lf)	7,000	-	7,000



VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model		
Date	4/22/2016	
Community	Venetie	
System Parameters	Model Results	Criteria & Calculations
<b>Design Population</b>		
Duration (n)	20 years	20 years
2015 Population (P)	186 people	2015 ADOL
2015 Number of Services	93 services	
Growth Rate (i)	1%	1%
2035 Design Population (Capita)	227 people	$P \times (1+i)^n$
<b>Water Demand Estimates</b>		
Existing Capacity	30 gpm	
Average Day (ADD)	11,348 gpd	50 gallons per Capita
Max Day (MDD)	22,696 gpd	2 x ADD
Peak Hour	47 gpm	3 x MDD
Treatment Capacity	16 gpm	MDD
<b>Water Source Assumptions</b>		
Type (surface water or groundwater)	GW	
Required Capacity	16 gpm	MDD
<b>Water Storage Tank Sizing</b>		
Existing Water Storage Tank	428,000 gallons	
Demand Based Volume (if source is GW)	Applicable	
Daily Operation (DO) (gallons)	22,696 gallons	Max Day (MDDx1 day)
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes
Reserve Volume (RV)	68,087 gallons	3 days x DO
Water Storage Tank Volume	120,782 gallons	DO + FF + RV
CT Based Volume (min if source is SW)	Not Required	
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation
Temperature (T)	4.4 C	4.4 celsius/40 F
pH (PH)	7	7
Contact Time Required (CT)	49 minutes	$LI \times (5.057) \times (e^{-0.0693T}) \times (e^{0.361PH}) \times (e^{0.113RC})$
Baffling Coefficient (BF)	0.1	0.1
Required Volume to meet CT*	80,399 gallons	CT/RCxPeak Hour/BF
Required Water Storage	120,800 gallons	
Required Additional Storage	- gallons	0
Estimate of Min Platform Size (3' clearance around)	- sf	$D = 0.103 \times Vg^{1/2}$ H=16 assumed (H is height of tank)
		0
<b>Water Treatment Plant Requirements*</b>		
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf
<b>Foundation (WST and WTP)</b>		
Soft poorly drained soils or discontinuous permafrost	0	Pile Foundation
Firm soils, or continuous permafrost	x	Thermosyphon
Stiff soils, no permafrost	0	Gravel pad
<b>Water Distribution (Check either or both)</b>		
Buried system with no permafrost	0	Static Water Mains
Above ground system or buried with permafrost	x	Circulating Water Main with Pitorifices (lf)
<b>Wastewater Collection (Check all that apply)</b>		
Buried system with no permafrost	0	Bare sewer main, no heat trace
Above ground or buried with permafrost	x	Sewer Main with Glycol Heat Trace (lf)
Gravity Sewer Main	0	Lift stations for gravity sewer mains, every 1,000 ft
Pressure Sewer Main	x	Individual Grinder Pump Stations (GPS) (ea)
<b>Water &amp; Sewer Services (Check all that apply)</b>		
Static Water Main	0	Static Water Service Line
Circulating Water Main	x	Circulating Water Service Lines (lf)
Gravity Sewer Main	0	Gravity Service Line
Pressure Sewer Main	x	Pressure Sewer Service Lines (lf)
<b>Sewage Lagoon Size</b>		
Existing Sewage Lagoon	3.3 acres	
Organic Loading Based Size	1.9 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per
check	235.3	
Hydraulic Loading Based Size	4.0 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)
Two cell lagoon, combined acreage	4.0 acres	Either organic loading based or hydraulic, whichever is greater

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**  
**Venetie**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	93	\$28,096.69	\$2,612,992
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	23,000	\$303.80	\$6,987,444
4	Sewage lift station	EA	0	#DIV/0!	\$0
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	0	#DIV/0!	\$0
8	Drainfield, community	SF	0	#DIV/0!	\$0
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0.7	\$1,461,213.17	\$1,022,849
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	32,900	\$422.45	\$13,898,753
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$2,467.77	\$2,961,322
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$691.55	\$829,855
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$28,313,215**

# O&M Cost Estimate

## Piped Water & Sewer System

4/27/2016

**Community:** Venetie

### General Community Data

Current population	186	persons
Average number of people per house	2.4	
Service Connections		
Number of houses	76	
Number of public/commerical buildings	16	
Number of schools	1	
Total number of service connections	93	
Burdened labor rate	\$14	hr
Electricity cost (Public facility)	\$0.54	kWh
Electricity cost (Residential service)	\$0.36	kWh
Cost per gallon for heating oil	\$8.50	gal
Water consumption per capita	50	gpd
Wastewater generation per capita	50	gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	1350 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	2736 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	428,000 gallons
Length of water line to/ from tank	125 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	3
Total length of Water Main	25900 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Pressure
Number of individual facility pump stations	
Number of community lift/pump stations	
Number of facilities served by lift/pump station #1	
Number of facilities served by lift/pump station #2	
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	16000 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	3
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	435 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Lagoon discharged seasonally with pump (Yes or No)	Yes

# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Operation & Maintenance Cost Assumptions

### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year



# O&M Cost Estimate Piped Water & Sewer System

4/27/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$23,296
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,188 /month	\$9,501.84
Raw water line	\$419 /month	\$3,348.86
Raw water heat addition	\$961 /month	\$7,689.98
Water storage tank	\$553 /month	\$4,423.81
Water storage tank line	\$39 /month	\$310.08
Water mains	\$8,031 /month	\$64,249
Service lines	\$2,163 /month	\$17,302
<u>Wastewater system</u>		
Sewer mains	\$4,961 /month	\$39,690
Service lines	\$2,163 /month	\$17,302
Lift/pump station buildings	\$0 /month	\$0.00
Force main to lagoon	\$135 /month	\$1,079
	Subtotal	\$164,900
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$431 /month	\$5,174
HVAC/hydronic system	\$431 /month	\$3,449
Water treatment	\$76 /month	\$916
Pumps		
Intake or well	\$76 /month	\$916.01
WST circulation	\$73 /month	\$583
Pressure/booster	\$115 /month	\$1,374.02
Main line circulation	\$1,740 /month	\$13,919
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$0 /month	\$0
HVAC/hydronic system	\$0 /month	\$0
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$0 /month	\$0.00
Sewer/force main glycol circulation	\$434 /month	\$3,473
Lagoon discharge pump	\$1,100 /year	\$1,100
	Subtotal	\$30,900
<b>Other Costs</b>		
Equipment R&R	\$10,955 /year	\$10,955
Miscellaneous materials & supplies	\$6,573 /year	\$6,573
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$23,500

## Summary

Administration	\$6,000
Labor	\$23,300
Fuel	\$164,900
Electricity	\$30,900
Other	\$23,500
<b>Total</b>	<b>\$249,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 180	76	85%	\$ 139,388
Public/Commerc	\$ 233.75	16	100%	\$ 44,880
School Service	\$ 7,192.37	1	100%	\$ 64,731
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 249,000</b>

# Wales, Alaska

## Community Information & Existing Infrastructure

Wales is a Kinugmiut Eskimo community of 146 people located on Cape Prince of Wales, at the western tip of the Seward Peninsula. There are 58 residential units, 9 commercial/public facilities and one school for a total of 68 services. The existing water and sewer services provided in Wales consist of self-haul system from the watering point attached to the washeteria and honey buckets. The school, teacher's housing, clinic, and the old city office has piped water service. The existing water and sewer infrastructure consists of the following:

- Well – 40 gpm
- Treated Water Storage – 500,000 gallons
- Water Treatment Plant – 2,912 SF, built in 1979
- Water Treatment – No treatment
- Sewage Lagoon – N/A

Soils around Wales consist of soft poorly drained soils near the beach and firm soils away from the beach area. Geotechnical explorations along the beach identified permafrost approximately 20-25 feet below ground surface.

## Piped System Description

The piped water and sewer system will be an above ground system. The community is located in an area that is archeologically sensitive, and therefore would greatly increase the capital costs if the system was buried. The water system will consist of approximately 10,600 feet of pipe, and the gravity sewer system approximately 5,600 feet of pipe. The water system will consist of two circulating loops. The gravity sewer system would require two sewer main lift stations, and glycol heat trace for freeze protection. Additionally, it is assumed that approximately 75 feet of pipe would be required for each service line for both water and sewer services. For the purposes of this assessment, a new 1,200 sf facility is included to house the equipment needed for additional treatment, water distribution and wastewater collection equipment.

The table below summarizes the results of the Piped System Model. The full model output is attached to this assessment.

## Piped System Analysis Model Results

System Description	Piped System Need	Existing Facility	Net Need
<b>Water Treatment Capacity (gpm)</b>	12	40	-
<b>Water Storage (gallons)</b>	101,300	500,000	-
<b>W&amp;S Utility Bldg/Water Treatment Plant/Addition (sf)</b>	1,200	-	1,200
<b>Septic System (sf)</b>	20,000	-	20,000
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	10,600	-	10,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,600	-	5,600
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,100	-	5,100
Gravity Sewer Service Lines (lf)	5,100	-	5,100

## Project Cost Summary

The following tables summarize the estimated capital and O&M costs for a piped system in Wales. The capital costs were determined using the State-provided capital cost model. Additional items not included in the cost model are noted below (items 28-30).

Estimated Capital Costs					Village
					Wales
Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	68	\$22,235.73	\$1,512,030
3	Sewage collection mains or services (gravity or force), above ground	LF	10,700	\$193.45	\$2,069,913
4	Sewage lift station	EA	2	\$581,420.38	\$1,162,841
7	Septic tank, community	EA	1	\$377,798.26	\$377,798
8	Drainfield, community	SF	20000	\$47.42	\$948,482
12	Water distribution, mains or services, above ground	LF	15,700	\$291.75	\$4,580,451
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$499.91	\$599,886
Total Estimated Cost in 2010 dollars (rounded):					<b>\$13,010,000</b>
Total with Inflation (3% per year for 6 years)					<b>\$15,534,600</b>
28	Electrical Service Upgrades	EA	68	\$5,500	\$374,000
Subtotal					<b>\$15,908,600</b>
29	Construction Contingency (15%)	LS	1	\$2,386,300	\$2,386,300
30	Design & Construction Administration Services (20%)	LS	1	\$3,181,700	\$3,181,700
Total					<b>\$21,476,600</b>

The O&M Costs were estimated based on the current population and community and system specific assumptions. Note that O&M costs are largely dependent on labor, fuel and electricity costs which can be highly variable. The assumptions and model results of both the cost models are included with this assessment.

Estimated O&M Costs	
Description	Cost
Administration	\$6,000
Labor	\$30,000
Fuel	\$78,100
Electricity	\$29,000
Other (R&R, Training, etc.)	\$17,000
<b>Total</b>	<b>\$160,000</b>

The estimated user fees that would be needed to cover the costs of operating the proposed pipe system in Wales are listed below.

<b>Estimated User Fees</b>				
<b>Revenue Source</b>	<b>Monthly Rate</b>	<b># of Customers</b>	<b>Collection Rate</b>	<b>Yearly Revenues</b>
Residential Service	\$ 156	58	85%	\$ 92,474
Public/Commercial Service	\$ 234	9	100%	\$ 25,322
School Service	\$ 4,689	1	100%	\$ 42,204
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 160,000</b>



**VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model**

Date 9/6/2016  
Community Wales  
Input

**Existing Community & System Data**

2015 Population	146
2015 Number of Services	68
HITS Database (E1 & H1-H7)	58
DCED Mapping Commerical/Public Facilities/School	10
Type (surface water or groundwater)	GW
Water quality (Poor or Good)	Poor
Water Storage Tank	500000
Water Treatment Capacity	40
Existing Sewage Lagoon Size	0

**Soil Conditions (check only one)**

Soft poorly drained soils or discontinuous permafrost	
Firm soils, or continuous permafrost	x
Stiff soils, no permafrost	

**Piping Configurations (check all that apply)**

		Sewer Main Length (ft)	Water Main Length (ft)
Buried system with no permafrost			
Above ground system or buried with permafrost	x	5600	10600
Gravity Sewer Main	x	5600	
Pressure Sewer Main			
Typical Service Line Length (ea)		75	75

**Piped System Requirements**

Community Wales

**Output for Cost Model (calculated)**

**Foundation Size**

Water Treatment Capacity (gpm)	12	
Req Water Storage (gallons) (less existing)	(398,700)	- sf
Req W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	1,200 sf
Req Septic System w/ Drainfield (sf) (less existing)	20,000	

Quantity Notes

Required Foundation System for WTP and/or WST	Thermosyphon stabilized gravel pad (sf)	1,200
Water Distribution System	Circulating Water Main with Pitorifices (lf)	10,600
Wastewater Collection System	Sewer Main with Glycol Heat Trace (lf)	5,600
	Lift Stations for Gravity Sewer Mains	2
Water & Sewer Service Lines	Circulating Water Service Lines (lf)	5,100
	Gravity Sewer Service Lines (lf)	5,100

System Description	Piped System Need	Existing Facility	Net Need
Water Treatment Capacity (gpm)	12	40	-
Water Storage (gallons)	101,300	500,000	-
W&S Utility Bldg/Water Treatment Plant/Addition (sf)	1,200	-	1,200
Septic System (sf)	20,000	-	20,000
<b>Required Foundation System for WTP and/or WST</b>			
Thermosyphon stabilized gravel pad (sf)	1,200	-	1,200
<b>Water Distribution System</b>			
Circulating Water Main with Pitorifices (lf)	10,600	-	10,600
<b>Wastewater Collection System</b>			
Sewer Main with Glycol Heat Trace (lf)	5,600	-	5,600
<b>Water &amp; Sewer Service Lines</b>			
Circulating Water Service Lines (lf)	5,100	-	5,100
Gravity Sewer Service Lines (lf)	5,100	-	5,100

VSW Unserved Communities - Piped Water & Sewer System Type and Sizing Model			
Date	9/6/2016		
Community	Wales		
System Parameters	Model Results	Criteria & Calculations	
<b>Design Population</b>			
Duration (n)	20 years	20 years	
2015 Population (P)	146 people	2015 ADOL	
2015 Number of Services	68 services		
Growth Rate (i)	1%	1%	
2035 Design Population (Capita)	178 people	Px(1+i)^n	
<b>Water Demand Estimates</b>			
Existing Capacity	40 gpm		
Average Day (ADD)	8,907 gpd	50 gallons per Capita	
Max Day (MDD)	17,815 gpd	2 x ADD	
Peak Hour	37 gpm	3 x MDD	
Treatment Capacity	12 gpm	MDD	
<b>Water Source Assumptions</b>			
Type (surface water or groundwater)	GW		
Required Capacity	12 gpm	MDD	
<b>Water Storage Tank Sizing</b>			
Existing Water Storage Tank	500,000 gallons		
Demand Based Volume (if source is GW)	Applicable		
Daily Operation (DO) (gallons)	17,815 gallons	Max Day (MDDx1 day)	
Fire Flow (FF)	30,000 gallons	500 gpm for 60 minutes	
Reserve Volume (RV)	53,444 gallons	3 days x DO	
Water Storage Tank Volume	101,259 gallons	DO + FF + RV	
CT Based Volume (min if source is SW)	Not Required		
Chlorine Residual Concentration (RC)	0.4 mg/L	0.4 mg/L	
Disinfection/Log Inactivation (LI)	1.0 log inactivation	1.0-log Inactivation	
Temperature (T)	4.4 C	4.4 celsius/40 F	
pH (PH)	7	7	
Contact Time Required (CT)	49 minutes	LI x (5.057) x (e^-0.0693T)x(e^0.361PH)x(e^0.113RC)	
Baffling Coefficient (BF)	0.1	0.1	
Required Volume to meet CT*	63,109 gallons	CT/RCxPeak Hour/BF	
Required Water Storage	101,300 gallons		
Required Additional Storage	(398,700) gallons	0	
Estimate of Min Platform Size (3' clearance around)	- sf	D = 0.103xVg^(1/2) H=16 assumed (H is height of tank)	
		0	
<b>Water Treatment Plant Requirements*</b>			
Water Quality	Poor	Poor Water Quality (CF or DF) = 1200 sf	
Minimum WTP Size	1,200 sf	Good Water Quality (no treatment other than CL) = 800 sf	
<b>Foundation (WST and WTP)</b>			
Soft poorly drained soils or discontinuous permafrost	0	Thermosyphon stabilized gravel pad (sf)	Pile Foundation
Firm soils, or continuous permafrost	x		Thermosyphon stabilized gravel pad
Stiff soils, no permafrost	0		Gravel pad
<b>Water Distribution (Check either or both)</b>			
Buried system with no permafrost	0	Circulating Water Main with Pitorifices (lf)	Static Water Mains
Above ground system or buried with permafrost	x		Circulating Water Main with Pitorifices
<b>Wastewater Collection (Check all that apply)</b>			
Buried system with no permafrost	0	Sewer Main with Glycol Heat Trace (lf)	Bare sewer main, no heat trace
Above ground or buried with permafrost	x		Sewer main with glycol heat trace
Gravity Sewer Main	x		Lift Stations for Gravity Sewer Mains, every 1,000 ft (ea)
Pressure Sewer Main	0		Individual Grinder Pump Stations
<b>Water &amp; Sewer Services (Check all that apply)</b>			
Static Water Main	0	Circulating Water Service Lines (lf)	Static Water Service Line
Circulating Water Main	x		Circulating Water Service Lines
Gravity Sewer Main	x		Gravity Service Line
Pressure Sewer Main	0		Pressure Service Line with GPS
<b>Sewage Lagoon Size</b>			
Existing Sewage Lagoon	0 acres		
Organic Loading Based Size check	1.5 acres	0.17 lbs of BOD5 per capita day x Design Population / 20 lbs BOD5 per	
	208.5		
Hydraulic Loading Based Size	3.1 acres	Volume is based on ADDx365x20% factor to account for precipitation, Lagoon depth assumed to be 5 ft, berm slopes 3:1, Factor of 1.3 for top of berms (area to be fenced)	
Two cell lagoon, combined acreage	3.1 acres	Either organic loading based or hydraulic, whichever is greater	

**Capital Cost Estimate  
Piped Water & Sewer System**

**Village**

**Wales**

Item No.	Line Item Description	Unit	Estimated Quantity	Adjusted Unit Cost	Total Cost
1	Household water and sewer plumbing	EA	68	\$22,235.73	\$1,512,030
2	Sewage collection mains or services (gravity or force), buried	LF	0	#DIV/0!	\$0
3	Sewage collection mains or services (gravity or force), above ground	LF	10,700	\$193.45	\$2,069,913
4	Sewage lift station	EA	2	\$581,420.38	\$1,162,841
5	Vacuum sewer plant, no foundation	SF	0	#DIV/0!	\$0
6	Septic tank, and drainfield, individual household	EA	0	#DIV/0!	\$0
7	Septic tank, community	EA	1	\$377,798.26	\$377,798
8	Drainfield, community	SF	20,000	\$47.42	\$948,482
9	Utilidors, above ground, including water and sewer, mains or services	LF	0	#DIV/0!	\$0
10	Sewage lagoon, barrow, local material	Acre	0	#DIV/0!	\$0
11	Sewage ocean outfall	LF	0	#DIV/0!	\$0
12	Water distribution, mains or services, above ground	LF	15,700	\$291.75	\$4,580,451
13	Water distribution, mains or services, buried	LF	0	#DIV/0!	\$0
14	Water storage tank, no foundation	Gal	0	#DIV/0!	\$0
15	Water treatment plant, no foundation	SF	1,200	\$1,465.72	\$1,758,867
16	Washeteria, no foundation	SF	0	#DIV/0!	\$0
17	Foundation - conventional, local gravel material	SF	0	#DIV/0!	\$0
18	Foundation - freeze back piles	SF	0	#DIV/0!	\$0
19	Foundation - thermosyphen stabilized gravel pad	SF	1,200	\$499.91	\$599,886
20	Boardwalk	LF	0	#DIV/0!	\$0
21	Road, local gravel source	LF	0	#DIV/0!	\$0
22	Water source - surface water intake	EA	0	#DIV/0!	\$0
23	Water source - ground water well	EA	0	#DIV/0!	\$0
24	Solid waste site - closure, local material	Acre	0	#DIV/0!	\$0
25	Solid waste site - development, local material w/ equipment	Acre	0	#DIV/0!	\$0
26	Shop / Garage, no foundation, concrete floor	SF	0	#DIV/0!	\$0

Total Estimated Cost: **\$13,010,268**

# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

**Community:** Wales

### General Community Data

Current population	146 persons
Average number of people per house	2.5
Service Connections	
Number of houses	58
Number of public/commerical buildings	9
Number of schools	1
Total number of service connections	68
Burdened labor rate	\$18 hr
Electricity cost (Public facility)	\$0.48 kWh
Electricity cost (Residential service)	\$0.21 kWh
Cost per gallon for heating oil	\$7.00 gal
Water consumption per capita	50 gpd
Wastewater generation per capita	50 gpd

### Water & Sewer System Characteristics

#### Water Source

Type of system (Surface(SW) or Groundwater(GW))	GW
Length of raw water line	6350 ft
Water line heated for freeze protection (Yes or No)	No
Location of water line (Above ground (AG) or Buried)	AG

#### Water Treatment

Size of water treatment plant building	4112 sf
Raw water quality (Good or Poor)	Poor

#### Water Storage

Size of tank(s)	500,000 gallons
Length of water line to/ from tank	50 ft
Water line heated for freeze protection (Yes or No)	Yes
Location of water line (Above ground (AG) or Buried)	AG

#### Water Distribution

Type of system (Static or Circulating (Circ))	Circ
Number of circulating water loops	2
Total length of Water Main	10600 ft
Water mains heated for freeze protection (Yes or No)	Yes
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Collection

Type of system (Gravity or Pressure)	Gravity
Number of individual facility pump stations	
Number of community lift/pump stations	2
Number of facilities served by lift/pump station #1	21
Number of facilities served by lift/pump station #2	45
Number of facilities served by lift/pump station #3	
Number of facilities served by lift/pump station #4	
Number of facilities served by lift/pump station #5	
Size of lift stations	500 sf
Total length of sewer mains	5600 ft
Sewer mains heated for freeze protection (Yes or No)	Yes
Number of circulating glycol loops	2
Location of the mains (Above ground (AG) or Buried)	AG
Average service line length	75 ft

#### Wastewater Treatment / Disposal

Length of force main	100 ft
Force main heated for freeze protection (Yes or No)	Yes
Location of force main (Above ground (AG) or Buried)	AG
Septic system discharged seasonally with pump (Yes or No)	Yes



# O&M Cost Estimate

## Piped Water & Sewer System

9/9/2016

### Operation & Maintenance Cost Assumptions

#### Administration

Billing, CCR and management	\$500	/month
-----------------------------	-------	--------

#### Labor (Operator)

Hours per week		
Less than 50 services	24	hrs/week
Between 50 and 100 services	32	hrs/week
More than 100 services	40	hrs/week

#### Fuel (Heating)

Available energy per gallon of heating fuel	100,000	BTUs/gallon
Heating season (above ground components)	8	months
Heating season (buried components)	12	months
Buildings	7	BTU/hr/sf
Raw water heat addition (5F)	40	BTU/gallon
Water storage tank	0.5	BTU/gal-day
Above ground mains	5	BTU/hr/ft
Buried mains (permafrost conditions)	3	BTU/hr/ft

#### Electricity

WTP building		
Lights and controls	0.4	watts/hr/sf
HVAC/hydronic system	0.4	watts/hr/sf
Water treatment		
Good quality water	0.1	watts/gallon
Poor quality water	0.5	watts/gallon
Water system pumps		
Intake or well	0.5	watts/gallon
WST circulation	135	kWh/month
Pressure/booster	0.75	watts/gallon
Main line circulation	1074	kWh/month/loop
Sewer system pumps		
Individual facility pump stations	0.7	watts/gallon/service
Community lift stations	0.6	watts/gallon
Sewer main glycol circulation	268	kWh/month/loop
Force main	0.6	watts/gallon
Lagoon discharge	0.6	watts/gallon

#### Other Costs

Equipment R&R	5	% of labor, fuel and electricity
Miscellaneous materials & supplies	3	% of labor, fuel and electricity
Water quality testing	\$2,000	per year
Operator training	\$2,500	per year
Insurance	\$1,500	per year

# O&M Cost Estimate Piped Water & Sewer System

9/9/2016

## Estimated O& M Costs

		<b>Annual Cost</b>
<b>Administration</b> (Utility management, billings, etc.)	\$500 /month	\$6,000
<b>Labor</b> (WTP Operator)	32 hrs/week	\$29,952
<b>Fuel</b> (Heating Demand)		
<u>Water system</u>		
WTP building	\$1,470 /month	\$11,760.45
Raw water line	\$0 /month	\$0.00
Raw water heat addition	\$621 /month	\$4,971.01
Water storage tank	\$532 /month	\$4,256.00
Water storage tank line	\$13 /month	\$102.14
Water mains	\$2,707 /month	\$21,655
Service lines	\$1,302 /month	\$10,419
<u>Wastewater system</u>		
Sewer mains	\$1,430 /month	\$11,440
Service lines	\$1,302 /month	\$10,419
Lift/pump station buildings	\$358 /month	\$2,860.03
Force main to lagoon	\$26 /month	\$204
	Subtotal	\$78,100
<b>Electricity</b>		
<u>Water system</u>		
WTP building		
Lights and controls	\$576 /month	\$6,912
HVAC/hydronic system	\$576 /month	\$4,608
Water treatment	\$53 /month	\$639
Pumps		
Intake or well	\$53 /month	\$639.13
WST circulation	\$65 /month	\$518
Pressure/booster	\$80 /month	\$958.69
Main line circulation	\$1,031 /month	\$8,248
<u>Wastewater system</u>		
Lift /pump station buildings		
Lights and controls	\$140 /month	\$1,681
HVAC/hydronic system	\$140 /month	\$1,121
Pumps		
Individual facility pump stations	\$0 /month	\$0
Community lift/pump station(s)	\$73 /month	\$872.74
Sewer/force main glycol circulation	\$257 /month	\$2,058
Lagoon discharge pump	\$767 /year	\$767
	Subtotal	\$29,000
<b>Other Costs</b>		
Equipment R&R	\$6,853 /year	\$6,853
Miscellaneous materials & supplies	\$4,112 /year	\$4,112
Water quality testing	\$2,000 /year	\$2,000
Operator training	\$2,500 /year	\$2,500
Insurance	\$1,500 /year	\$1,500
	Subtotal	\$17,000


## Summary

Administration	\$6,000
Labor	\$30,000
Fuel	\$78,100
Electricity	\$29,000
Other	\$17,000
<b>Total</b>	<b>\$160,000</b>

Revenue Source	Monthly Rate	# of Customers	Collection Rate	Yearly Revenues
Residential Serv	\$ 156	58	85%	\$ 92,474
Public/Commerc	\$ 234.47	9	100%	\$ 25,322
School Service	\$ 4,689.33	1	100%	\$ 42,204
Local Capital Contribution				\$ -
<b>Total Revenue</b>				<b>\$ 160,000</b>



File: J:\Jobsdata\31303.00 View - Assessment Of Unserved Communities\00 CADD\01 Working Set\01 Civil\31303.00 Wales.dwg



PROJECT: 31303.00  
STATUS: PRELIM.

VSW ASSESSMENT OF  
UNSERVED COMMUNITIES  
WALES

DATE  
SEP 2016  
SCALE  
GRAPHIC  
FIGURE  
39