



ALASKA POLLUTANT DISCHARGE ELIMINATION SYSTEM

**GENERAL PERMIT FOR
HYDROSTATIC AND AQUIFER PUMP TESTING**

Permit Number: AKG003000

**ALASKA DEPARTMENT OF ENVIRONMENTAL CONSERVATION
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, AK 99501**

In compliance with the provisions of the Clean Water Act (CWA), 33 U.S.C. §1251 *et seq.*, as amended by the Water Quality Act of 1987, P.L. 100-4, this permit is issued under provisions of Alaska Statutes (AS) 46.03; the Alaska Administrative Code (AAC) as amended; and other applicable State laws and regulations.

Entities with discharges associated with hydrostatic testing, including flushing, and aquifer pump testing are authorized to discharge to lands or waters of the U.S., only in accordance with effluent limitations, monitoring requirements, and other conditions set forth herein.

**A COPY OF THIS GENERAL PERMIT
MUST BE KEPT AT THE SITE WHERE DISCHARGES OCCUR.**

This permit is effective **August 1, 2014**.

This permit and the authorization to discharge shall expire at midnight on **July 31, 2019**.

Signature

June 30, 2014

Date

Wade Strickland
Printed Name

Program Manager
Title

TABLE OF CONTENTS

SCHEDULE OF SUBMISSIONS.....	4
1.0 PERMIT COVERAGE	6
1.1 Permit Area	6
1.2 Eligibility	6
1.3 Authorized Discharges.....	6
1.4 Exclusions.....	6
1.5 Requiring an Individual Permit.....	7
2.0 AUTHORIZATION.....	7
2.1 Obtaining Authorization	7
2.2 Notice of Intent (NOI) Submittal Requirements.....	8
2.3 Continuation of Expiring General Permit	10
3.0 COMPLIANCE WITH STANDARDS AND LIMITS.....	10
3.1 Requirements for all Projects.....	10
3.2 Discharge to Impaired Water Body	11
4.0 CONTROL MEASURES	11
4.1 Erosion and Sediment Control Measures.....	11
5.0 LIMITATIONS, INSPECTIONS, AND MONITORING REQUIREMENTS.....	12
5.1 Land Disposal Discharges of Hydrostatic Testing.....	12
5.2 Surface Water Discharges of Hydrostatic Testing.....	12
5.3 Land Disposal Discharges of Aquifer Pump Testing Water.....	14
5.4 Surface Water Discharges of Aquifer Pump Testing Water	15
5.5 Quality Assurance Project Plan	17
6.0 REPORTING AND RECORDKEEPING	18
6.1 Daily Inspection monitoring and record keeping.....	18
6.2 Discharge Monitoring Report (DMR)	18
6.3 Standard Conditions Applicable to Reporting Requirements	18
7.0 TERMINATION OF COVERAGE	18
7.1 When to Submit a Notice of Termination.....	18
7.2 Submitting a Notice of Termination	19

LIST OF TABLES

Table 1: Schedule of Submissions	4
Table 2: NOI Submittal Application Requirements.....	5
Table 3: Effluent Monitoring Requirements for Land Disposal Discharges	12
Table 4: Effluent Limits and Monitoring Requirements for Hydrostatic Testing Discharges to Waters of the U.S.....	13
Table 5: Effluent Monitoring Requirements for Land Disposal Discharges	14
Table 6: Effluent Limits and Monitoring Requirements for Aquifer Pump Testing Discharges to Waters of the U.S.	16

LIST OF APPENDICES

APPENDIX A	STANDARD CONDITIONS	A-1
APPENDIX B	ACRONYMS.....	B-1
APPENDIX C	DEFINITIONS.....	C-1
APPENDIX D	FORMS	D-1

SCHEDULE OF SUBMISSIONS

The Table 1: Schedule of Submissions summarizes some of the required submissions and activities in addition to Table 2: NOI Submittal Application Requirements, which the permittee must complete and submit to the Alaska Department of Environmental Conservation (DEC or Department) during the term of this permit. The permittee is responsible for all submissions and activities even if they are not summarized below.

Table 1: Schedule of Submissions

Permit Part	Submittal or Completion	Frequency	Due Date	Submit to ^a
3.1.6	Alaska Department of Environmental Conservation Division of Spill Prevention and Response	Upon observation of Product or Oil Sheen	Contact the Division of Spill Prevention and Response at 1-800-478-9300 immediately upon the observation of an oil sheen or product either within the soil or groundwater to be discharged.	Contact the Division of Spill Prevention and Response
6.2	Discharge Monitoring Report	Monthly	Submitted no later than the 15 th day of the month following the month each discharge to waters of the U.S. occurs	Compliance Program
7.1	Notice of Termination	At completion of Project	Within 30 days upon completion of all hydrostatic and aquifer pump testing authorized through the submittal of an NOI	Permitting Program
Appendix A, 3.4	Oral notification of noncompliance	As Necessary	Within 24 hours from the time the permittee becomes aware of the circumstances of noncompliance	Compliance Program
	Written documentation of noncompliance	As Necessary	Within 5 days after the permittee becomes aware of the circumstances	Compliance Program
Note: a. See Appendix A, Part 1.1 for Permitting and Compliance Program contact information and addresses.				

NOTICE OF INTENT SUBMITTAL REQUIREMENTS

The Notice of Intent (NOI) submittal requirements found in Part 2.2 are summarized below since formal application requirements for permit coverage may vary dependent on the discharge location.

Table 2: NOI Submittal Application Requirements

Permit Part	Description of Discharge Activity	Submittal Requirement	Due Date	Submit to ^a
2.1.3	Aquifer pump test discharges to land with the following conditions: • is less than 30,000 gpd, • greater than 1,500 feet from an “DEC-identified contaminated site or contaminated groundwater plume”	No NOI submittal required as discharge is authorized in accordance to Parts 4.0, 5.3, and 6.0	N/A	Copy of permit to be kept onsite and made available upon request by the Department
2.1.3	Hydrostatic discharges to land	No NOI submittal required as discharge is authorized in accordance to Parts 4.0, 5.1, and 6.0	N/A	Copy of permit to be kept onsite and made available upon request by the Department
2.2.1	Aquifer pump test or hydrostatic discharges to waters of the U.S.	Submit NOI and Best Management Practices (BMP) Plan in accordance to Parts 2.2 and 2.2.8	30 days prior to anticipated discharge	Permitting Program
2.2.1	Aquifer pump testing discharges to land with the following conditions: • equal to or greater than 30,000 gallons per day, or • within 1,500 feet of an “DEC-identified contaminated site or groundwater plume”	Submit NOI and BMP Plan in accordance to Parts 2.2 and 2.2.8	30 days prior to anticipated discharge	Permitting Program
Note: a. See Appendix A, Part 1.1 for Permitting and Compliance Program contact information and addresses.				

1.0 PERMIT COVERAGE

- 1.1 **Permit Area** Hydrostatic testing and aquifer pump testing discharges in all regions of Alaska with exception to the Denali National Park and Preserve and the Indian Reservation of Metlakatla are eligible for coverage under this permit. Hydrostatic testing associated with oil and gas exploration facilities located in the North Slope Borough or for hydrocarbon transport pipeline projects are eligible for alternative general permits listed in Parts 1.4.1.5 and 1.4.1.6.
- 1.2 **Eligibility** Subject to the restrictions and conditions of this general permit, applicants with hydrostatic or aquifer pump testing discharges may be authorized to discharge to land or waters of the U.S. after receiving written authorization from DEC (Part 2.1).

1.3 Authorized Discharges

- 1.3.1 The following discharges associated with hydrostatic testing are authorized under this permit:
- 1.3.1.1 Hydrostatic testing and flushing discharges of new/unused tanks, utility lines, pipelines, and similar containers; and
 - 1.3.1.2 Hydrostatic testing and flushing discharges of used tanks, utility lines, pipelines, and similar containers.
- 1.3.2 The following discharges associated with aquifer pump testing are authorized under this permit:
- 1.3.2.1 Aquifer pump testing used to conduct water quality, water quantity tests or hydrogeological investigations in support of mineral mining development and exploration.

1.4 Exclusions

- 1.4.1 The following discharges are not authorized under this permit:
- 1.4.1.1 Discharges defined as “Potable Water Distribution Systems Releases” that are incidental to the normal operation and maintenance of a public water system;
 - 1.4.1.2 Uncontrolled public water system releases produced by system failures are not required to seek coverage under this permit;
 - 1.4.1.3 A wastewater discharge that is mixed with any other discharges that are not associated with hydrostatic testing and/or aquifer pump testing discharges;
 - 1.4.1.4 A wastewater discharge authorized or eligible for coverage under another Alaska Pollutant Discharge Elimination System (APDES) permit;
 - 1.4.1.5 A hydrostatic discharge associated with oil and natural gas facilities located on the North Slope Borough eligible for coverage under permit AKG331000 or more recent version;
 - 1.4.1.6 A hydrostatic discharge from hydrocarbon transport pipelines eligible for coverage under the statewide Hydrocarbon Transport general permit AKG332000 (pending);

- 1.4.1.7 A discharge of solid or liquid waste material or water discharges incidental to water well drilling and geophysical drilling which does not directly discharge into a surface water;
- 1.4.1.8 A discharge associated with a petroleum related corrective action under the management of the Department's Spill Prevention and Response Division;
- 1.4.1.9 A discharge to land from remediation related activities all conducted under a Department-approved remedial work plan; and
- 1.4.1.10 A discharge to a combined or sanitary sewer system.

1.5 Requiring an Individual Permit

- 1.5.1 In accordance with 18 AAC 83.215, the Department may require or allow an applicant authorized under this permit to apply for and obtain an individual APDES permit.
- 1.5.2 The Department will require an applicant to obtain an individual permit when the wastewater discharge does not meet the eligibility criteria of this general permit, contributes to pollution, has the potential to cause or causes an adverse impact on public health or water quality, or a change occurs in the availability of technology for the control of pollutants in the discharge.
- 1.5.3 The Department will notify an applicant in writing by certified mail that an individual APDES permit application is required. If the applicant fails to submit an application by the date required in the notification, coverage under this general permit is automatically terminated at the end of the day specified for application submittal.

2.0 AUTHORIZATION

2.1 Obtaining Authorization

- 2.1.1 Authorization to discharge under this general permit requires the applicant seeking authorization to submit a completed NOI to DEC in accordance with the requirements listed herein (Part 2.2). With exception of activities meeting the exclusions in Part 2.1.3, the applicant must receive written notification of authorization from DEC that coverage has been granted and that a specific authorization number has been assigned prior to discharging.
- 2.1.2 A permittee is authorized to discharge under the terms and conditions of this permit upon the date specified in the issuance of the DEC authorization letter, which is posted to DEC's website <http://dec.alaska.gov/Applications/Water/WaterPermitSearch/Search.aspx> and expires at midnight on the signature date of the Notice of Termination (NOT).
- 2.1.3 **Automatic Authorization.** The following discharges, consistent with the permit eligibility provisions in Part 1.2 are automatically authorized by this permit. Applicants proposing to discharge hydrostatic testing and aquifer pump testing wastewater are not required to submit an NOI to receive discharge authorization consistent with the following:
 - 2.1.3.1 Discharge is to land only in accordance with Parts 4.0, and either Parts 5.1 or 5.3 dependent on the type of discharge, and Part 6.0 of the permit, and
 - 2.1.3.2 Discharge activity does not meet the NOI submittal criteria in Part 2.2.1.

2.2 Notice of Intent (NOI) Submittal Requirements

- 2.2.1 A minimum of 30 days prior to the date on which the discharge is to commence, the applicant conducting hydrostatic or aquifer pump testing must submit an NOI and certified best management practices (BMP, Part 2.2.8) plan to DEC for the following:
- 2.2.1.1 Discharges to waters of the U.S., or
 - 2.2.1.2 Aquifer pump testing discharges to land with the following conditions:
 - 2.2.1.2.1 Greater than or equal to 30,000 gallons per day, or
 - 2.2.1.2.2 Within a 1,500 feet of an “DEC-identified contaminated site or groundwater plume¹”, or
- 2.2.2 An applicant with discharges meeting conditions of Parts 2.2.1.2.2 , see Part 2.2.7 for additional submittal requirements.
- 2.2.3 The NOI may be submitted electronically via the Permit Application Portal at: <http://www.dec.alaska.gov/water/wnpspc/stormwater/APDESeNOI.html> or by completing a paper form found at <http://dec.alaska.gov/water/wnpspc/stormwater/Forms.htm> and sent to the DEC Permitting Program address located in Appendix A, Part 1.1.1.
- 2.2.4 The NOI must be signed by the applicant in accordance with Signatory Requirements in Appendix A, Part 1.12 and submitted to the DEC address located in Appendix A, Part 1.12. A copy of the completed NOI shall be retained on site in accordance with Appendix A, Part 1.11 (Monitoring and Records).
- 2.2.5 The NOI must be accompanied by the appropriate fee as found in 18 AAC 72.956.
- 2.2.6 The NOI shall contain a general location map (e.g., United States Geological Survey (USGS) quadrangle map, a portion of a city or borough map, or other map) with sufficient detail to identify the location of the discharge and waters of the U.S. within one mile of the site.
- 2.2.7 **Contaminated Site** Applicants conducting aquifer pump testing meeting condition in Part 2.2.1.2.2 shall in addition to the NOI (Part 2.2.1) and BMP Plan (Part 2.2.8), provide the following information:
- 2.2.7.1 Identify the potential pollutants of concern that may be present or become present in the wastewater discharge related to the aquifer pump testing activity. The applicant shall review available data about the contaminated site(s) including the type and concentration of contaminants, whether the contaminant(s) are in soil and/or groundwater and the size and location of any contaminated plumes²;

¹ A contaminated site or groundwater plume with an “Active” or “Cleanup Complete-Institutional Controls” status identified by DEC Contaminated Sites Program. For assistance in locating mapped contaminated sites and listing of groundwater plumes see <http://dec.alaska.gov/Water/wnpspc/stormwater/edhsgp.html>.

² The permittee should refer to DEC’s website (<http://dec.alaska.gov/Water/wnpspc/stormwater/edhsgp.html>) for additional information for access to DEC’s Contaminated Sites database, summaries, map, and listing of contaminated sites as an aid in assessing pollutants of concern that may be potentially present in the wastewater discharge.

- 2.2.7.2 Identify a proposed treatment methodology to be incorporated into the BMP plan if contaminants can become entrained in the pumped groundwater and the contaminant discharge concentrations;
- 2.2.7.3 The Department may additionally request a hydrogeologic report be prepared by a “qualified person” as defined in 18 AAC 75.990 or “qualified groundwater scientist” as defined in 18 AAC 60.990. This report must specifically address the impact of the proposed pumping activity on the location of any adjacent contaminated site(s) within the area of influence of the pumping activity and contain at a minimum the following:
 - 2.2.7.3.1 A description of the aquifer conditions (e.g. confined, semi-confined, unconfined), thickness, static water level, and lateral transmissivity;
 - 2.2.7.3.2 Using proposed or existing monitoring wells that are capable of providing information on groundwater elevations, determine whether contaminants are being smeared below the natural minimum groundwater elevation, whether the contaminant plume is being diverted, and whether contaminant migration rates are increasing; and
 - 2.2.7.3.3 When the dewatering activity may adversely affect a contaminated site by moving or smearing contaminants, the applicant must use construction practices such as cofferdams, or other methods to prevent adverse effects upon groundwater quality.
- 2.2.7.4 The information described in Part 2.2.7.3 is not required if the applicant can demonstrate that the contaminated site(s) within 1,500 feet of the dewatering activity does not affect the groundwater within the dewatering area of influence. The following activities may be used to demonstrate this:
 - 2.2.7.4.1 Using existing groundwater monitoring wells to generate a groundwater flow map that includes the static water level of all wells, groundwater flow direction, and groundwater elevation contours to demonstrate dewatering activities will not impact the plume; or
 - 2.2.7.4.2 A simulated aquifer pump test conducted with groundwater modeling software or a similar study at the projected maximum pumping rate to determine, radii of influence, drawdown, and rate of recharge, which verifies pumping will not affect the contaminated plume.
- 2.2.8 **Best Management Practices (BMP) Plan.** An applicant with hydrostatic testing or aquifer pump testing discharges to waters of the U.S. and land discharges is required to submit an NOI under Part 2.2.1 and shall submit the following to the Department with the NOI in addition to items in Part 2.2 to receive discharge authorization:
 - 2.2.8.1 A BMP plan that describes how the wastewater will be managed with a description of each BMP to be implemented on-site;
 - 2.2.8.2 A description of the land disposal site conditions such as soils, topography, drainage patterns, depth to groundwater, and existing vegetation;

- 2.2.8.3 A detailed site map to scale that shows the discharge points, infiltration areas, drainage boundaries, flow direction of discharged water, location of all waters of the U.S. on site and those located within 2,500 feet of the site boundary, and location of BMPs to be implemented; and
- 2.2.8.4 A signed and certified by the applicant BMP plan in accordance to the requirements of Appendix A, Part 1.12.
- 2.2.9 **Emergency Repairs or Reconstruction of a Facility.** Discharges from hydrostatic or aquifer pump testing activities conducted in response to a disaster (as defined in AS 26.23.900) are conditionally authorized, provided that a NOI for coverage under this permit is filed with the Department within thirty (30) calendar days following the commencement of hydrostatic or aquifer pump testing activities. For discharges occurring during the initial thirty (30) day period, the permittee must demonstrate compliance with the terms and conditions of this permit to the extent practicable depending on the disaster.
- 2.3 **Continuation of Expiring General Permit** If this permit is not reissued prior to the expiration date, it will be administratively continued in accordance with 18 AAC 83.155(c) and remain in force and effect so long as prior to the expiration date, the permittee complies with the requirements of 18 AAC 83.155(c)(1). A permittee granted permit coverage prior to the expiration date will automatically be covered under the administratively continued permit until the earliest of:
 - 2.3.1 Reissuance or replacement of this permit, at which time the permittee must comply with the conditions of the new permit, as it applies to ongoing projects, to maintain authorization to discharge;
 - 2.3.2 Submittal of a NOT;
 - 2.3.3 Issuance of an individual permit for the project's discharges; or
 - 2.3.4 A formal permit decision by DEC to not reissue this general permit, at which time the permittee must seek coverage under an alternative general permit or an individual permit.

3.0 COMPLIANCE WITH STANDARDS AND LIMITS

3.1 Requirements for all Projects

- 3.1.1 The discharge to waters of the U.S. shall not cause a violation of the Alaska Water Quality Standards (WQS) (18 AAC 70).
- 3.1.2 A permittee must select, install, implement and maintain control measures (described in Part 4.0) at the hydrostatic and aquifer pump testing project site that minimize pollutants in the discharge. A permittee must comply with all permit conditions with respect to installation and maintenance of control measures, inspections, monitoring (if necessary), corrective actions, reporting and recordkeeping.
- 3.1.3 DEC may determine that the permittee's hydrostatic and aquifer pump testing discharges will cause, have reasonable potential to cause, or contribute to an excursion above any applicable WQS. If such a determination is made, DEC may require the permittee to:

- 3.1.3.1 Take corrective actions and modify the control measures to adequately address the identified water quality concerns;
- 3.1.3.2 Submit valid and verifiable data and information that are representative of ambient conditions and indicate that the receiving water is attaining WQS; or
- 3.1.3.3 DEC may impose additional permit stipulations on a site-specific basis, or require the permittee to obtain coverage under an individual permit, if information in a permittee's NOI, required reports, or from other sources indicates that the discharges are not controlled as necessary to meet applicable WQS.
- 3.1.4 The discharge shall be free of (a) any additives such as antifreeze solutions, methanol solvents, and corrosion inhibitors; (b) solid wastes and garbage; (c) toxic substances; (d) grease or oils which exceed the effluent limitations in Parts 5.2.1.3 or 5.4.1.5 or produce a sheen; (e) foam in other than trace amounts; or (f) other contaminants.
- 3.1.5 Chemicals may not be added to the discharge unless the Department grants specific permission, which will be stated in the discharge authorization letter. In granting the use of chemicals, special conditions and monitoring requirements may be addressed in the authorization to discharge.
- 3.1.6 The permittee shall contact the Alaska Department of Environmental Conservation Division of Spill Prevention and Response immediately at 1-800-478-9300 upon the observation of any oil sheen or product within the groundwater to be discharged. The hydrostatic or aquifer pump test activities shall not resume until DEC approval is granted from a member of the spill response staff at the above number.
- 3.2 **Discharge to Impaired Water Body** The CWA §303(d) impaired waterbodies are those cited in the Final DEC 2010 Integrated Report³ or the most current version. If the permittee discharges into a waterbody with an EPA-established or approved Total Maximum Daily Load (TMDL), the permittee must implement measures to ensure that the discharge of pollutants from the site is consistent with the assumptions and requirements of the EPA-established or approved TMDL, including ensuring that the discharge does not exceed specific wasteload or load allocation that has been established that would apply to the discharge. The permittee must also evaluate the recommendations in the Implementation Section of the TMDL and incorporate applicable measures into the operations.

4.0 CONTROL MEASURES A permittee must select, design, install, and implement control measures (including BMPs) that minimize pollutants in the discharge at the point of discharge.

- 4.1 **Erosion and Sediment Control Measures** A permittee must minimize erosion and sedimentation and the resultant discharge of pollutants from the hydrostatic testing and aquifer pump testing discharges using structural and/or non-structural control measures.
 - 4.1.1 A permittee must place flow velocity dissipation devices at discharge locations and within outfall channels where necessary to reduce erosion and settle out pollutants; and

³ DEC, 2010 Integrated Water Quality Monitoring and Assessment Report – Alaska's List of Impaired or 303(d) listed waterbodies. <http://dec.alaska.gov/water/wqsar/waterbody/integratedreport.htm> and the Alaska's Section 303(d) List of Impaired Waterbodies at http://dec.alaska.gov/water/wqsar/Docs/2010impaired_waters.pdf.

- 4.1.2 A permittee must use BMPs such as temporary lined settling basins, filter bags, or other similar filtering and retention mechanisms where necessary to minimize sediment deposition either to the land or waters of the U.S.

5.0 LIMITATIONS, INSPECTIONS, AND MONITORING REQUIREMENTS

5.1 Land Disposal Discharges of Hydrostatic Testing

- 5.1.1 The discharge shall be to an area with soils capable of infiltration with no discharge to the waters of the U.S.;
- 5.1.2 Necessary erosion and sediment controls in Part 4.0 shall be implemented at the discharge point to prevent erosion and any sedimentation beyond the disposal area;
- 5.1.3 A written visual inspection record for erosion, sheen, and a daily flow rate estimate must be kept by the permittee in accordance with Part 6.0;
- 5.1.4 If a visual sheen is observed in the discharge, all discharging shall cease until DEC approval is granted in accordance to Part 3.1.6 and necessary corrective actions taken to prevent a sheen discharge, which may include but not be limited to: additional monitoring requirements and flowing the discharge through a temporary lined impoundment where skimmers, booms, absorbent pads, etc. could be used to remove any visual sheen; and
- 5.1.5 A land disposal discharge authorized under this permit must be monitored as listed in Table 3.

Table 3: Effluent Monitoring Requirements for Land Disposal Discharges			
Effluent Characteristic	Monitoring Location	Monitoring Frequency	Sample Type
Erosion	Point of Discharge	Daily	Visual
Sheen*	Effluent	Daily	Visual
Flow Rate	Effluent	Daily	24-hour Estimate or Measured
* Discharge shall be free of any visible sheen.			

5.2 Surface Water Discharges of Hydrostatic Testing

- 5.2.1 The permittee is authorized to discharge wastewater authorized in Part 1.3 to waters of the U.S. in accordance to the following effluent limitations:
- 5.2.1.1 The discharge must not cause re-suspension of sediments upon discharge to receiving waters as well as physical erosion or downstream flooding;
- 5.2.1.2 The discharge must not cause adverse effects to aquatic or plant life, their reproduction or habitats;
- 5.2.1.3 If a visual sheen is observed in the discharge, all discharging shall cease until DEC approval is granted in accordance to Part 3.1.6 and necessary corrective actions taken to prevent a sheen discharge, which may include but not be limited to: flowing through a temporary lined impoundment where skimmers, booms, absorbent pads, etc. could be used to remove any visual sheen; and

5.2.1.4 Discharges must meet the effluent limits and monitoring requirements as listed in Table 4.

Table 4: Effluent Limits and Monitoring Requirements for Hydrostatic Testing Discharges to Waters of the U.S.

Effluent Characteristic	Maximum Value	Monitoring Location	Monitoring Frequency	Sample Type	Sample Method
pH	6.5- 8.5 SU ^a	Effluent	Before discharge and once per week	Grab	Field
		Upstream			
Settleable Solids	0.2 ml/L above natural conditions	Effluent	Once a month	Grab	Field (see note 11 to 18 AAC 70.020(b))
		Upstream			
Sheen	No presence	Effluent	Daily	Grab	Visual
Total Aqueous Hydrocarbons ^b (TAqH)	15 µg/L	Effluent	Before discharge	Grab	Lab (See note 7 to 18 AAC 70.020(b))
Total Aromatic Hydrocarbons ^b (TAH)	10 µg/L	Effluent	Before discharge	Grab	Lab Method 602 (plus Xylenes) or EPA Method 624 (see note 7 to 18 AAC 70.020(b))
Total Flow	No limit	Effluent	Daily	24- Hour Estimate or Measured	Field
Total Residual Chlorine ^c	19 µg/L fresh water or 13 µg/L marine	Effluent	Before discharge and once per week	Grab	Field
Turbidity (marine)	25 NTUs	Effluent	Before discharge and once per week	Grab	Field
Turbidity (freshwater)	5 NTUs above natural conditions ^d	Effluent	Before discharge and once per week	Grab	Field
		Upstream			
Notes: a. The effluent limit for pH shall be between 6.5 and 8.5 pH units and within 0.2 units (marine water), and 0.5 units (fresh water) of the receiving water pH at all times. b. TAH and TAqH monitoring is not required for all new/unused tanks, pipelines or similar vessels in addition to testing or flushing of public water supply systems. TAqH and TAH shall be monitored if a visual sheen is detected in the discharge. If a sheen is detected, the permittee shall notify DEC in accordance with Permit Part 3.1.6, and a sample for TAqH and TAH shall be collected and corrective actions or treatment devices implemented to prevent an oily sheen discharge. c. Total Residual Chlorine (TRC) monitoring is waived for all discharges that do not contain chlorinated water. The TRC limits are not quantifiable using EPA-approved analytical methods so the minimum level (ML) of 0.1 mg/L (100 µg/L) will be used as the compliance evaluation level for this parameter. d. Turbidity shall not have more than a 10% increase when the natural condition is more than 50 NTU, not to exceed a maximum increase of 15 NTU. Shall not exceed 5 NTU over natural conditions for all lake waters.					

5.2.2 All samples for monitoring purposes must be representative of the discharge activity, as outlined in Appendix A, Part 3.1.

- 5.2.3 If the permittee monitors any pollutants or background water quality parameters identified in this permit more frequently than required, the results of such monitoring shall be reported to the Department in the monthly Discharge Monitoring Report required under Part 6.2.
- 5.2.4 Test procedures used for sample analysis shall conform to methods cited in 18 AAC 70.020(c). The permittee may substitute alternative methods of monitoring or analysis upon receipt of prior written approval from the Department.
- 5.2.5 Unless otherwise noted, the permittee must use EPA-approved analytical methods that can achieve a method detection limit (MDL) less than the effluent limit.
- 5.2.6 The permittee must use current calibrated equipment when taking field measurements and shall use sample bottles provided by a certified laboratory conducting wastewater analysis in accordance to 18 AAC 70.020(c), 40 CFR Part 136 and/or the most current version of Standard Methods of Water and Wastewater Analysis.
- 5.2.7 For discharges to Impaired Waters, see Part 3.2 for additional monitoring requirements.
- 5.3 Land Disposal Discharges of Aquifer Pump Testing Water** The permittee is authorized to discharge wastewater authorized in Part 1.3 to land in accordance with the following effluent limitations:
- 5.3.1 The discharge shall be to an area with soils capable of infiltration with no discharge to waters of the U.S.;
- 5.3.2 Necessary erosion and sediment controls in Part 4.0 shall be implemented at the discharge point to prevent erosion and any sedimentation from occurring beyond the disposal area;
- 5.3.3 A written visual inspection record for erosion, sheen, and a daily flow rate estimate must be kept by the permittee in accordance to the Standard Conditions found Appendix A, Part 1.11.2;
- 5.3.4 If a visual sheen is observed in the discharge all discharging shall cease until DEC approval is granted in accordance to Part 3.1.6 and necessary corrective actions taken to prevent a sheen discharge, which may include but not be limited to: additional monitoring requirements and flowing through a temporary lined impoundment where skimmers, booms, absorbent pads, etc. could be used to remove any visual sheen; and
- 5.3.5 A land disposal discharge authorized under this permit must be monitored in accordance to Table 5.

Table 5: Effluent Monitoring Requirements for Land Disposal Discharges

Effluent Characteristic	Monitoring Location	Monitoring Frequency	Sample Type
Erosion	Point of Discharge	Daily	Visual
Sheen*	Effluent	Daily	Visual
Flow Rate	Effluent	Daily	24-hour Estimate or Measured
* Discharge shall be free of any visible sheen.			

5.4 Surface Water Discharges of Aquifer Pump Testing Water The permittee is authorized to discharge wastewater authorized in Part 1.3 to waters of the U.S. in accordance with the following effluent limitations:

- 5.4.1.1 The discharge shall not cause re-suspension of sediments upon discharge to receiving waters as well as physical erosion or downstream flooding;
- 5.4.1.2 The discharge shall not cause adverse effects to aquatic or plant life, their reproduction or habitats;
- 5.4.1.3 The discharge shall not exceed any WQS developed for any known contaminant which may be present within the contaminant plume of the “DEC-identified contaminated site or groundwater plume” located within 1,500 feet of the aquifer pump testing activities;
- 5.4.1.4 If a visual sheen is observed in the discharge all discharging shall cease until DEC approval is granted in accordance to Part 3.1.6 and necessary corrective actions taken to prevent a sheen discharge, which may include but not be limited to: flowing through a temporary lined impoundment where skimmers, booms, absorbent pads, etc. could be used to remove any visual sheen; and
- 5.4.1.5 Discharges must meet the effluent limits and monitoring requirements as listed in Table 6.

(See Table 6: Effluent Limits and Monitoring Requirements for Aquifer Pump Testing Discharges to Waters of the U.S. located on the following page.)

Table 6: Effluent Limits and Monitoring Requirements for Aquifer Pump Testing Discharges to Waters of the U.S.

Effluent Characteristic	Maximum Value	Monitoring Location	Monitoring Frequency	Sample Type	Sample Method
pH	6.5- 8.5 ^a SU	Effluent Upstream	Daily	Grab	Field
Settleable Solids	0.2 ml/L above natural conditions	Effluent Upstream	Once a month	Grab	Field (see note 11 to 18 AAC 70.020(b))
Sheen	No presence	Effluent	Daily	Grab	Visual
Total Aqueous Hydrocarbons (TAqH)	15 µg/L	Effluent	Before discharge	Grab	Lab(See note 7 to 18 AAC 70.020(b))
Total Aromatic Hydrocarbons (TAH)	10 µg/L	Effluent	Before discharge	Grab	Lab Method 602 (plus Xylenes) or EPA Method 624 (see note 7 to 18 AAC 70.020(b))
Total Antimony	6 µg/L	Effluent	With NOI	Grab	Lab
Total Arsenic ^b	10 µg/L	Effluent	With NOI	Grab	Lab
Total Cadmium ^b	5 µg/L	Effluent	With NOI	Grab	Lab
Total Chromium	100 µg/L	Effluent	With NOI	Grab	Lab
Total Copper ^b	200 µg/L	Effluent	With NOI	Grab	Lab
Total Lead ^b	50 µg/L	Effluent	With NOI	Grab	Lab
Total Mercury ^{b, c}	2 µg/L	Effluent	With NOI	Grab	Lab
Total Molybdenum	10 µg/L	Effluent	With NOI	Grab	Lab
Total Nickel ^b	200 µg/L	Effluent	With NOI	Grab	Lab
Total Selenium ^b	10 µg/L	Effluent	With NOI	Grab	Lab
Total Zinc ^b	2,000 µg/L	Effluent	With NOI	Grab	Lab
Total Dissolved Solids ^d (freshwater)	500 mg/L	Effluent	Before discharge and once per week	Grab	Lab
Total Flow	No limit	Effluent	Daily	24- hr. est. or measured	Field
Turbidity (marine)	25 NTUs	Effluent	Before discharge and once per week	Grab	Field
Turbidity (freshwater)	5 NTUs above natural conditions ^e	Effluent Upstream	Before discharge and once per week	Grab	Field

Notes:

- The effluent limit for pH shall be between 6.5 and 8.5 pH units and within 0.2 units (marine water), and 0.5 units (fresh water) of the receiving water pH at all times.
- Effluent Limits for protection of aquatic life or human health criteria for fresh water and marine water may be added per permit authorization.
- Mercury shall be analyzed using either Method 1631E or 245.7 to ensure meaningful analytical results in light of the very low applicable water quality standards for this metal.
- The concentration of chlorides and sulfates which make up the total dissolved solids shall not exceed 250 mg/L for sulfates, and 230 mg/L for chlorides.
- Turbidity shall not have more than a 10% increase in turbidity when the natural condition is more than 50 NTU, not to exceed a maximum increase of 15 NTU. Shall not exceed 5 NTU over natural conditions for all lake waters.

- 5.4.2 All samples for monitoring purposes must be representative of the discharge activity, as outlined in Appendix A, Part 3.1.
- 5.4.3 If the permittee monitors any pollutants or background water quality parameters identified in this permit more frequently than required, the results of such monitoring shall be reported to the Department in the monthly Discharge Monitoring Report required under Part 6.2.
- 5.4.4 Test procedures used for sample analysis shall conform to methods cited in 18 AAC 70.020 (c), or as such regulations may be amended. The permittee may substitute alternative methods of monitoring or analysis upon receipt of prior written approval from the Department.
- 5.4.5 Unless otherwise noted, the permittee must use EPA-approved analytical methods that can achieve a MDL less than the effluent limit.
- 5.4.6 The permittee shall use current calibrated equipment when taking field measurements and shall use sample bottles provided by a certified laboratory conducting wastewater analysis in accordance to 18 AAC 70.020(c), 40 CFR 136 and/or the most current version of Standard Methods of Water and Wastewater Analysis.
- 5.4.7 For discharges to Impaired Waters, see Part 3.2 for additional monitoring requirements.

5.5 Quality Assurance Project Plan

- 5.5.1 The permittee must develop and implement a quality assurance project plan (QAPP) for all monitoring required by this permit for discharges to waters of the U.S. Any existing QAPP may be modified under this section.
- 5.5.2 The permittee must design the QAPP must be designed to assist in planning for the collection and analysis of effluent and receiving water samples in support of the permit and to help explain data anomalies whenever they occur.
- 5.5.3 The permittee may use either the generic DEC QAPP or develop a site-specific QAPP. There is some facility specific information that is still required in order to complete the QAPP when using the generic DEC QAPP. A generic DEC QAPP is located at http://dec.alaska.gov/water/wqapp/wqapp_index.htm.
- 5.5.4 Throughout all sample collection and analysis activities, the permittee must use DEC-approved Quality Assurance/Quality Control and chain-of-custody procedures as described in the Requirements for Quality Assurance Project Plans (EPA/QA/R-5) at <http://www.epa.gov/quality/qs-docs/r5-final.pdf> and Guidance for Quality Assurance Project Plans (EPA/QA/G-5) at <http://www.epa.gov/quality/qs-docs/g5-final.pdf>. The QAPP must be prepared in the format specified in these documents.
- 5.5.5 At a minimum, a site-specific QAPP must include the following:
 - 5.5.5.1 Details on number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements;
 - 5.5.5.2 Maps indicating the location of each sampling point;

- 5.5.5.3 Qualification and training of personnel; and
- 5.5.5.4 Name, address and telephone number of all laboratories used by or proposed to be used by the permittee.
- 5.5.6 The permittee must amend the site-specific QAPP whenever sample collection, sample analysis, or other procedure addressed by the QAPP is are modified.
- 5.5.7 A copy Copies of the QAPP must be kept onsite and made available to DEC upon request.

6.0 REPORTING AND RECORDKEEPING

6.1 Daily Inspection monitoring and record keeping

- 6.1.1 The permittee must maintain daily records of all information resulting from any inspections and daily monitoring as required in Appendix A Part 3.0.

6.2 Discharge Monitoring Report (DMR)

- 6.2.1 Required effluent monitoring data for all discharges to waters of the U.S. shall be recorded on a DMR form and submitted no later than the 15th day of the month following the month that each sampling occurs. Reporting shall begin when the discharge begins. Reporting shall be done on the DMR form located at <http://dec.alaska.gov/water/Compliance/permittee.html> or the paper form included in Appendix E, and submitted to the Compliance Program at the address listed in Appendix A Part 1.1.2.

6.3 Standard Conditions Applicable to Reporting Requirements

- 6.3.1 The permittee must also comply with the following recording and reporting requirements, as described in Appendix A, Standard Conditions:
 - 6.3.1.1 Retention of Records, Part 1.11.2;
 - 6.3.1.2 Records Contents, Part 1.11.3;
 - 6.3.1.3 Special Reporting Obligations, Part 2.0; and
 - 6.3.1.4 Monitoring, Recording, and Reporting Requirements, Part 3.0.

7.0 TERMINATION OF COVERAGE

7.1 When to Submit a Notice of Termination

- 7.1.1 Within thirty (30) days upon completion of hydrostatic or aquifer pump testing, the permittee must submit a Notice of Termination (NOT) to terminate coverage under this permit when having submitted an NOI in accordance with Part 2.2.

7.2 Submitting a Notice of Termination

7.2.1 The complete and accurate NOT can be submitted either:

7.2.1.1 Electronically (strongly encouraged) at
<http://www.dec.alaska.gov/water/wnpspc/stormwater/APDESeNOI.html> or

7.2.1.2 A paper copy (available at the above Web site) to:

Alaska Department of Environmental Conservation
Wastewater Discharge Authorization Program
Storm Water NOI
555 Cordova Street
Anchorage, AK 99501

APPENDIX A

STANDARD CONDITIONS

APDES PERMIT

NONDOMESTIC DISCHARGES

TABLE OF CONTENTS

1.0	Standard Conditions Applicable to All Permits	A-1
1.1	Contact Information and Addresses	A-1
1.2	Duty to Comply	A-1
1.3	Duty to Reapply	A-2
1.4	Need to Halt or Reduce Activity Not a Defense	A-2
1.5	Duty to Mitigate	A-2
1.6	Proper Operation and Maintenance	A-2
1.7	Permit Actions	A-2
1.8	Property Rights	A-2
1.9	Duty to Provide Information	A-2
1.10	Inspection and Entry	A-3
1.11	Monitoring and Records	A-3
1.12	Signature Requirement and Penalties	A-4
1.13	Proprietary or Confidential Information	A-5
1.14	Oil and Hazardous Substance Liability	A-5
1.15	Cultural and Paleontological Resources	A-6
1.16	Fee	A-6
1.17	Other Legal Obligations	A-6
2.0	Special Reporting Obligations	A-6
2.1	Planned Changes	A-6
2.2	Anticipated Noncompliance	A-6
2.3	Transfers	A-7
2.4	Compliance Schedules	A-7
2.5	Corrective Information	A-7
2.6	Bypass of Treatment Facilities	A-7
2.7	Upset Conditions	A-8
2.8	Existing Manufacturing, Commercial, Mining, and Silvicultural Discharges	A-8
3.0	Monitoring, Recording, and Reporting Requirements	A-9
3.1	Representative Sampling	A-9
3.2	Reporting of Monitoring Results	A-9
3.3	Additional Monitoring by Permittee	A-9
3.4	Twenty-four Hour Reporting	A-9
3.5	Other Noncompliance Reporting	A-10
4.0	Penalties for Violations of Permit Conditions	A-10
4.1	Civil Action	A-10
4.2	Injunctive Relief	A-11
4.3	Criminal Action	A-11
4.4	Other Fines	A-11

Appendix A of the permit contains standard regulatory language that must be included in all APDES permits. These requirements are based on the regulations and cannot be challenged in the context of an individual APDES permit action. The standard regulatory language covers requirements such as monitoring, recording, reporting requirements, compliance responsibilities, and other general requirements. Appendix A, Standard Conditions is an integral and enforceable part of the permit. Failure to comply with a Standard Condition in this Appendix constitutes a violation of the permit and is subject to enforcement.

1.0 Standard Conditions Applicable to All Permits

1.1 Contact Information and Addresses

1.1.1 Permitting Program

Documents, reports, and plans required under the permit and Appendix A are to be sent to the following address:

State of Alaska
Department of Environmental Conservation
Division of Water
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, Alaska 99501
Telephone (907) 269-6285
Fax (907) 269-3487
Email: DEC.WQPermit@alaska.gov

1.1.2 Compliance and Enforcement Program

Documents and reports required under the permit and Appendix A relating to compliance are to be sent to the following address:

State of Alaska
Department of Environmental Conservation
Division of Water
Compliance and Enforcement Program
555 Cordova Street
Anchorage, Alaska 99501
Telephone Nationwide (877) 569-4114
Anchorage Area / International (907) 269-4114
Fax (907) 269-4604
Email: dec-wqreporting@alaska.gov

1.2 Duty to Comply

A permittee shall comply with all conditions of the permittee's APDES permit. Any permit noncompliance constitutes a violation of 33 U.S.C 1251-1387 (Clean Water Act) and state law and is grounds for enforcement action including termination, revocation and reissuance, or modification of a permit, or denial of a permit renewal application. A permittee shall comply with effluent standards or prohibitions established under 33 U.S.C. 1317(a) for toxic pollutants within the time provided in the regulations that establish those effluent standards or prohibitions even if the permit has not yet been modified to incorporate the requirement.

1.3 Duty to Reapply

If a permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee must apply for and obtain a new permit. In accordance with 18 AAC 83.105(b), a permittee with a currently effective permit shall reapply by submitting a new application at least 180 days before the existing permit expires, unless the Department has granted the permittee permission to submit an application on a later date. However, the Department will not grant permission for an application to be submitted after the expiration date of the existing permit.

1.4 Need to Halt or Reduce Activity Not a Defense

In an enforcement action, a permittee may not assert as a defense that compliance with the conditions of the permit would have made it necessary for the permittee to halt or reduce the permitted activity.

1.5 Duty to Mitigate

A permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

1.6 Proper Operation and Maintenance

1.6.1 A permittee shall at all times properly operate and maintain all facilities and systems of treatment and control and related appurtenances that the permittee installs or uses to achieve compliance with the conditions of the permit. The permittee's duty to operate and maintain properly includes using adequate laboratory controls and appropriate quality assurance procedures. However, a permittee is not required to operate back-up or auxiliary facilities or similar systems that a permittee installs unless operation of those facilities is necessary to achieve compliance with the conditions of the permit.

1.6.2 Operation and maintenance records shall be retained and made available at the site.

1.7 Permit Actions

A permit may be modified, revoked and reissued, or terminated for cause as provided in 18 AAC 83.130. If a permittee files a request to modify, revoke and reissue, or terminate a permit, or gives notice of planned changes or anticipated noncompliance, the filing or notice does not stay any permit condition.

1.8 Property Rights

A permit does not convey any property rights or exclusive privilege.

1.9 Duty to Provide Information

A permittee shall, within a reasonable time, provide to the Department any information that the Department requests to determine whether a permittee is in compliance with the permit, or whether cause exists to modify, revoke and reissue, or terminate the permit. A permittee shall also provide to the Department, upon request, copies of any records the permittee is required to keep under the permit.

1.10 Inspection and Entry

A permittee shall allow the Department, or an authorized representative, including a contractor acting as a representative of the Department, at reasonable times and on presentation of credentials establishing authority and any other documents required by law, to:

- 1.10.1 Enter the premises where a permittee's regulated facility or activity is located or conducted, or where permit conditions require records to be kept;
- 1.10.2 Have access to and copy any records that permit conditions require the permittee to keep;
- 1.10.3 Inspect any facilities, equipment, including monitoring and control equipment, practices, or operations regulated or required under a permit; and
- 1.10.4 Sample or monitor any substances or parameters at any location for the purpose of assuring permit compliance or as otherwise authorized by 33 U.S.C. 1251-1387 (Clean Water Act).

1.11 Monitoring and Records

A permittee must comply with the following monitoring and recordkeeping conditions:

- 1.11.1 Samples and measurements taken for the purpose of monitoring must be representative of the monitored activity.
- 1.11.2 The permittee shall retain records in Alaska of all monitoring information for at least three years, or longer at the Department's request at any time, from the date of the sample, measurement, report, or application. Monitoring records required to be kept include:
 - 1.11.2.1 All calibration and maintenance records,
 - 1.11.2.2 All original strip chart recordings or other forms of data approved by the Department for continuous monitoring instrumentation,
 - 1.11.2.3 All reports required by a permit,
 - 1.11.2.4 Records of all data used to complete the application for a permit,
 - 1.11.2.5 Field logbooks or visual monitoring logbooks,
 - 1.11.2.6 Quality assurance chain of custody forms,
 - 1.11.2.7 Copies of discharge monitoring reports, and
 - 1.11.2.8 A copy of this APDES permit.
- 1.11.3 Records of monitoring information must include:
 - 1.11.3.1 The date, exact place, and time of any sampling or measurement;
 - 1.11.3.2 The name(s) of any individual(s) who performed the sampling or measurement(s);
 - 1.11.3.3 The date(s) and time any analysis was performed;
 - 1.11.3.4 The name(s) of any individual(s) who performed any analysis;
 - 1.11.3.5 Any analytical technique or method used; and
 - 1.11.3.6 The results of the analysis.

1.11.4 Monitoring Procedures

Analyses of pollutants must be conducted using test procedures approved under 40 CFR Part 136, adopted by reference at 18 AAC 83.010, for pollutants with approved test procedures, and using test procedures specified in the permit for pollutants without approved methods.

1.12 Signature Requirement and Penalties

- 1.12.1 Any application, report, or information submitted to the Department in compliance with a permit requirement must be signed and certified in accordance with 18 AAC 83.385. Any person who knowingly makes any false material statement, representation, or certification in any application, record, report, or other document filed or required to be maintained under a permit, or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be subject to penalties under 33 U.S.C. 1319(c)(4), AS 12.55.035(c)(1)(B), (c)(2) and (c)(3), and AS 46.03.790(g).
- 1.12.2 In accordance with 18 AAC 83.385, an APDES permit application must be signed as follows:
 - 1.12.2.1 For a corporation, a responsible corporate officer shall sign the application; in this subsection, a responsible corporate officer means:
 - 1.12.2.1.1 A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation; or
 - 1.12.2.1.2 The manager of one of more manufacturing, production, or operating facilities, if
 - 1.12.2.1.2.1 The manager is authorized to make management decisions that govern the operation of the regulated facility, including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental statutes and regulations;
 - 1.12.2.1.2.2 The manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and
 - 1.12.2.1.2.3 Authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
 - 1.12.2.2 For a partnership or sole proprietorship, by the general partner or the proprietor, respectively, shall sign the application.
 - 1.12.2.3 For a municipality, state, federal, or other public agency, either a principal executive officer or ranking elected official shall sign the application; in this subsection, a principal executive officer of an agency means:
 - 1.12.2.3.1 The chief executive officer of the agency; or
 - 1.12.2.3.2 A senior executive officer having responsibility for the overall operations of a principal geographic unit or division of the agency.
- 1.12.3 Any report required by an APDES permit, and a submittal with any other information requested by the Department, must be signed by a person described in Appendix A, Part 1.12.2, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1.12.3.1 The authorization is made in writing by a person described in Appendix A, Part 1.12.2;

- 1.12.3.2 The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, including the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility; or an individual or position having overall responsibility for environmental matters for the company; and
- 1.12.3.3 The written authorization is submitted to the Department to the Permitting Program address in Appendix A, Part 1.1.1.
- 1.12.4 If an authorization under Appendix A, Part 1.12.3 is no longer effective because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Appendix A, Part 1.12.3 must be submitted to the Department before or together with any report, information, or application to be signed by an authorized representative.
- 1.12.5 Any person signing a document under Appendix A, Part 1.12.2 or Part 1.12.3 shall certify as follows:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

1.13 Proprietary or Confidential Information

- 1.13.1 A permit applicant or permittee may assert a claim of confidentiality for proprietary or confidential business information by stamping the words "confidential business information" on each page of a submission containing proprietary or confidential business information. The Department will treat the stamped submissions as confidential if the information satisfies the test in 40 CFR §2.208, adopted by reference at 18 AAC 83.010, and is not otherwise required to be made public by state law.
- 1.13.2 A claim of confidentiality under Appendix A, Part 1.13.1 may not be asserted for the name and address of any permit applicant or permittee, a permit application, a permit, effluent data, sewage sludge data, and information required by APDES or NPDES application forms provided by the Department, whether submitted on the forms themselves or in any attachments used to supply information required by the forms.
- 1.13.3 A permittee's claim of confidentiality authorized under Appendix A, Part 1.13.1 is not waived if the Department provides the proprietary or confidential business information to the EPA or to other agencies participating in the permitting process. The Department will supply any information obtained or used in the administration of the state APDES program to the EPA upon request under 40 CFR §123.41, as revised as of July 1, 2005. When providing information submitted to the Department with a claim of confidentiality to the EPA, the Department will notify the EPA of the confidentiality claim. If the Department provides the EPA information that is not claimed to be confidential, the EPA may make the information available to the public without further notice.

1.14 Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any action or relieve a permittee

from any responsibilities, liabilities, or penalties to which the permittee is or may be subject to under state laws addressing oil and hazardous substances.

1.15 Cultural and Paleontological Resources

If cultural or paleontological resources are discovered because of this disposal activity, work that would disturb such resources is to be stopped, and the Office of History and Archaeology, a Division of Parks and Outdoor Recreation of the Alaska Department of Natural Resources (<http://www.dnr.state.ak.us/parks/oha/>), is to be notified immediately at (907) 269-8721.

1.16 Fee

A permittee must pay the appropriate permit fee described in 18 AAC 72.

1.17 Other Legal Obligations

This permit does not relieve the permittee from the duty to obtain any other necessary permits from the Department or from other local, state, or federal agencies and to comply with the requirements contained in any such permits. All activities conducted and all plan approvals implemented by the permittee pursuant to the terms of this permit shall comply with all applicable local, state, and federal laws and regulations.

2.0 Special Reporting Obligations

2.1 Planned Changes

- 2.1.1 The permittee shall give notice to the Department as soon as possible of any planned physical alteration or addition to the permitted facility if:
 - 2.1.1.1 The alteration or addition may make the facility a “new source” under one or more of the criteria in 18 AAC 83.990(44); or
 - 2.1.1.2 The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged if those pollutants are not subject to effluent limitations in the permit or to notification requirements under 18 AAC 83.610.
- 2.1.2 If the proposed changes are subject to plan review, then the plans must be submitted at least 30 days before implementation of changes (see 18 AAC 15.020 and 18 AAC 72 for plan review requirements). Written approval is not required for an emergency repair or routine maintenance.
- 2.1.3 Written notice must be sent to the Permitting Program address in Appendix A, Part 1.1.1.

2.2 Anticipated Noncompliance

- 2.2.1 A permittee shall give seven days’ notice to the Department before commencing any planned change in the permitted facility or activity that may result in noncompliance with permit requirements.
- 2.2.2 Written notice must be sent to the Compliance and Enforcement Program address in Appendix A, Part 1.1.2.

2.3 Transfers

- 2.3.1 A permittee may not transfer a permit for a facility or activity to any person except after notice to the Department in accordance with 18 AAC 83.150. The Department may modify or revoke and reissue the permit to change the name of the permittee and incorporate such other requirements under 33 U.S.C. 1251-1387 (Clean Water Act) or state law.
- 2.3.2 Written notice must be sent to the Permitting Program address in Appendix A, Part 1.1.1.

2.4 Compliance Schedules

- 2.4.1 A permittee must submit progress or compliance reports on interim and final requirements in any compliance schedule of a permit no later than 14 days following the scheduled date of each requirement.
- 2.4.2 Written notice must be sent to the Compliance and Enforcement Program address in Appendix A, Part 1.1.2.

2.5 Corrective Information

- 2.5.1 If a permittee becomes aware that it failed to submit a relevant fact in a permit application or submitted incorrect information in a permit application or in any report to the Department, the permittee shall promptly submit the relevant fact or the correct information.
- 2.5.2 Information must be sent to the Permitting Program address in Appendix A, Part 1.1.1.

2.6 Bypass of Treatment Facilities

2.6.1 Prohibition of Bypass

Bypass is prohibited. The Department may take enforcement action against a permittee for any bypass, unless:

- 2.6.1.1 The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- 2.6.1.2 There were no feasible alternatives to the bypass, including use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. However, this condition is not satisfied if the permittee, in the exercise of reasonable engineering judgment, should have installed adequate back-up equipment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance; and
- 2.6.1.3 The permittee provides notice to the Department of a bypass event in the manner, as appropriate, under Appendix A, Part 2.6.2.

2.6.2 Notice of bypass

- 2.6.2.1 For an anticipated bypass, the permittee submits notice at least 10 days before the date of the bypass. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the conditions of Appendix A, Parts 2.6.1.1 and 2.6.1.2.
 - 2.6.2.2 For an unanticipated bypass, the permittee submits 24-hour notice, as required in 18 AAC 83.410(f) and Appendix A, Part 3.4, Twenty-four Hour Reporting.
 - 2.6.2.3 Written notice must be sent to the Compliance and Enforcement Program address in Appendix A, Part 1.1.2.
- 2.6.3 Notwithstanding Appendix A, Part 2.6.1, a permittee may allow a bypass that:

- 2.6.3.1 Does not cause an effluent limitation to be exceeded, and
- 2.6.3.2 Is for essential maintenance to assure efficient operation.

2.7 Upset Conditions

- 2.7.1 In any enforcement action for noncompliance with technology-based permit effluent limitations, a permittee may claim upset as an affirmative defense. A permittee seeking to establish the occurrence of an upset has the burden of proof to show that the requirements of Appendix A, Part 2.7.2 are met.
- 2.7.2 To establish the affirmative defense of upset, the permittee must demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that:
 - 2.7.2.1 An upset occurred and the permittee can identify the cause or causes of the upset;
 - 2.7.2.2 The permitted facility was at the time being properly operated;
 - 2.7.2.3 The permittee submitted 24-hour notice of the upset, as required in 18 AAC 83.410(f) and Appendix A, Part 3.4, Twenty-four Hour Reporting; and
 - 2.7.2.4 The permittee complied with any mitigation measures required under 18 AAC 83.405(e) and Appendix A, Part 1.5, Duty to Mitigate.
- 2.7.3 Any determination made in administrative review of a claim that noncompliance was caused by upset, before an action for noncompliance is commenced, is not final administrative action subject to judicial review.

2.8 Existing Manufacturing, Commercial, Mining, and Silvicultural Discharges

- 2.8.1 In addition to the reporting requirements under 18 AAC 83.410, an existing manufacturing, commercial, mining, and silvicultural discharger shall notify the Department as soon as that discharger knows or has reason to believe that any activity has occurred or will occur that would result in:
 - 2.8.1.1 The discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - 2.8.1.1.1 One hundred micrograms per liter (100 µg/L);
 - 2.8.1.1.2 Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile, 500 micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol, and one milligram per liter (1 mg/L) for antimony;
 - 2.8.1.1.3 Five times the maximum concentration value reported for that pollutant in the permit application in accordance with 18 AAC 83.310(c)-(g); or
 - 2.8.1.1.4 The level established by the Department in accordance with 18 AAC 83.445.
 - 2.8.1.2 Any discharge, on a non-routine or infrequent basis, of a toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - 2.8.1.2.1 Five hundred micrograms per liter (500 µg/L);
 - 2.8.1.2.2 One milligram per liter (1 mg/L) for antimony;

- 2.8.1.2.3 Ten times the maximum concentration value reported for that pollutant in the permit application in accordance with 18 AAC 83.310(c)-(g); or
- 2.8.1.2.4 The level established by the Department in accordance with 18 AAC 83.445.

3.0 Monitoring, Recording, and Reporting Requirements

3.1 Representative Sampling

A permittee must collect effluent samples from the effluent stream after the last treatment unit before discharge into the receiving waters. Samples and measurements must be representative of the volume and nature of the monitored activity or discharge.

3.2 Reporting of Monitoring Results

The permittee shall summarize monitoring results on the annual report form or approved equivalent. The permittee shall submit its annual report at the interval specified in the permit. The permittee shall sign and certify all annual reports and other reports in accordance with the requirements of Appendix A, Part 1.12, Signatory Requirement and Penalties. The permittee shall submit the legible originals of these documents to the ADEC Compliance and Enforcement Program at the address in Appendix A, Part 1.1.2.

3.3 Additional Monitoring by Permittee

If the permittee monitors any pollutant more frequently than the permit requires using test procedures approved in 40 CFR Part 136, adopted by reference at 18 AAC 83.010, or as specified in this permit, the results of that additional monitoring must be included in the calculation and reporting of the data submitted in the DMR or annual report required by Appendix A, Part 3.2. All limitations that require averaging of measurements must be calculated using an arithmetic means unless the Department specifies another method in the permit. Upon request by the Department, the permittee must submit the results of any other sampling and monitoring regardless of the test method used.

3.4 Twenty-four Hour Reporting

A permittee shall report any noncompliance event that may endanger health or the environment as follows:

- 3.4.1 A report must be made:
 - 3.4.1.1 Orally within 24 hours after the permittee becomes aware of the circumstances, and
 - 3.4.1.2 In writing within five days after the permittee becomes aware of the circumstances.
- 3.4.2 A report must include the following information:
 - 3.4.2.1 A description of the noncompliance and its causes, including the estimated volume or weight and specific details of the noncompliance;
 - 3.4.2.2 The period of noncompliance, including exact dates and times;
 - 3.4.2.3 If the noncompliance has not been corrected, a statement regarding the anticipated time the noncompliance is expected to continue; and
 - 3.4.2.4 Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- 3.4.3 An event that must be reported within 24 hours includes:
- 3.4.3.1 An unanticipated bypass that exceeds any effluent limitation in the permit (see Appendix A, Part 2.6, Bypass of Treatment Facilities).
 - 3.4.3.2 An upset that exceeds any effluent limitation in the permit (see Appendix A, Part 2.7, Upset Conditions).
 - 3.4.3.3 A violation of a maximum daily discharge limitation for any of the pollutants listed in the permit as requiring 24-hour reporting.
- 3.4.4 The Department may waive the written report on a case-by-case basis for reports under Appendix A, Part 3.4 if the oral report has been received within 24 hours of the permittee becoming aware of the noncompliance event.
- 3.4.5 The permittee may satisfy the written reporting submission requirements of Appendix A, Part 3.4 by submitting the written report via e-mail, if the following conditions are met:
- 3.4.5.1 The Noncompliance Notification Form or equivalent form is used to report the noncompliance;
 - 3.4.5.2 The written report includes all the information required under Appendix A, Part 3.4.2;
 - 3.4.5.3 The written report is properly certified and signed in accordance with Appendix A, Parts 1.12.3 and 1.12.5.;
 - 3.4.5.4 The written report is scanned as a PDF (portable document format) document and transmitted to the Department as an attachment to the e-mail; and
 - 3.4.5.5 The permittee retains in the facility file the original signed and certified written report and a printed copy of the conveying email.
- 3.4.6 The e-mail and PDF written report will satisfy the written report submission requirements of this permit provided the e-mail is received by the Department within five days after the time the permittee becomes aware of the noncompliance event and the e-mail and written report satisfy the criteria of Part 3.4.5. The e-mail address to report noncompliance is:
dec-wqreporting@alaska.gov

3.5 Other Noncompliance Reporting

A permittee shall report all instances of noncompliance not required to be reported under Appendix A, Parts 2.4 (Compliance Schedules), 3.3 (Additional Monitoring by Permittee), and 3.4 (Twenty-four Hour Reporting) at the time the permittee submits monitoring reports under Appendix A, Part 3.2. (Reporting of Monitoring Results). A report of noncompliance under this part must contain the information listed in Appendix A, Part 3.4.2 and be sent to the Compliance and Enforcement Program address in Appendix A, Part 1.1.2.

4.0 Penalties for Violations of Permit Conditions

Alaska laws allow the State to pursue both civil and criminal actions concurrently. The following is a summary of Alaska law. Permittees should read the applicable statutes for further substantive and procedural details.

4.1 Civil Action

Under AS 46.03.760(e), a person who violates or causes or permits to be violated a regulation, a lawful

order of the Department, or a permit, approval, or acceptance, or term or condition of a permit, approval or acceptance issued under the program authorized by AS 46.03.020 (12) is liable, in a civil action, to the State for a sum to be assessed by the court of not less than \$500 nor more than \$100,000 for the initial violation, nor more than \$10,000 for each day after that on which the violation continues, and that shall reflect, when applicable:

- 4.1.1 Reasonable compensation in the nature of liquated damages for any adverse environmental effects caused by the violation, that shall be determined by the court according to the toxicity, degradability, and dispersal characteristics of the substance discharged, the sensitivity of the receiving environment, and the degree to which the discharge degrades existing environmental quality;
- 4.1.2 Reasonable costs incurred by the State in detection, investigation, and attempted correction of the violation;
- 4.1.3 The economic savings realized by the person in not complying with the requirements for which a violation is charged; and
- 4.1.4 The need for an enhanced civil penalty to deter future noncompliance.

4.2 Injunctive Relief

- 4.2.1 Under AS 46.03.820, the Department can order an activity presenting an imminent or present danger to public health or that would be likely to result in irreversible damage to the environment be discontinued. Upon receipt of such an order, the activity must be immediately discontinued.
- 4.2.2 Under AS 46.03.765, the Department can bring an action in Alaska Superior Court seeking to enjoin ongoing or threatened violations for Department-issued permits and Department statutes and regulations.

4.3 Criminal Action

Under AS 46.03.790(h), a person is guilty of a Class A misdemeanor if the person negligently:

- 4.3.1 Violates a regulation adopted by the Department under AS 46.03.020(12);
- 4.3.2 Violates a permit issued under the program authorized by AS 46.03.020(12);
- 4.3.3 Fails to provide information or provides false information required by a regulation adopted under AS 46.03.020(12);
- 4.3.4 Makes a false statement, representation, or certification in an application, notice, record, report, permit, or other document filed, maintained, or used for purposes of compliance with a permit issued under or a regulation adopted under AS 46.03.020(12); or
- 4.3.5 Renders inaccurate a monitoring device or method required to be maintained by a permit issued or under a regulation adopted under AS 46.03.020(12).

4.4 Other Fines

Upon conviction of a violation of a regulation adopted under AS 46.03.020(12), a defendant who is not an organization may be sentenced to pay a fine of not more than \$10,000 for each separate violation (AS 46.03.790(g)). A defendant that is an organization may be sentenced to pay a fine not exceeding the greater of: (1) \$200,00; (2) three times the pecuniary gain realized by the defendant as a result of the offense; or (3) three times the pecuniary damage or loss caused by the defendant to another, or the property of another, as a result of the offense (AS 12.55.035(c)(B), (c)(2), and (c)(3)).

APPENDIX B ACRONYMS

AAC	Alaska Administrative Code
APDES	Alaska Pollutant Discharge Elimination System
BMPs	Best Management Practices
CFR	Code of Federal Regulations
CWA	Clean Water Act
DEC	Alaska Department of Environmental Conservation
DNR	Alaska Department of Natural Resources
EPA	U.S. Environmental Protection Agency
FR	Federal Register
GP	General Permit
gpd	Gallons per Day
ml/L	Milliliters per Liter
MDL	Method Detection Limit
ML	Minimum Level
NOI	Notice of Intent
NTU	Nephelometric Turbidity Unit
µg/L	Micrograms per Liter
U.S.C.	United States Code
WQS or WQC	Water Quality Standards or Water Quality Criteria

APPENDIX C DEFINITIONS

Alaska Pollutant Discharge Elimination System (APDES) ^a	The state's program, approved by EPA under 33 U.S.C. 1342(b), for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits and imposing and enforcing pretreatment requirements under 33 U.S.C. 1317, 1328, 1342, and 1345
Aquifer Pump Test	The process of conducting a water quality or water quantity test on a drilled water well or geophysical well to determine well yield, quality of water, or hydrogeological conditions which produces a discharge of ground water to the surface or to waters of the U.S.
Best Management Practices (BMPs)	Schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the discharge of pollutants to Waters of the U.S. (U.S.). BMPs also include treatment requirements, operating procedures, and practice to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.
Clean Water Act (CWA) ^a	The federal law codified at 33 U.S.C. 1251-1387, also referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972
Criterion ^b	A set concentration or limit of a water quality parameter that, when not exceeded, will protect an organism, a population of organisms, a community of organisms, or a prescribed water use with a reasonable degree of safety.
DEC-Identified Contaminated Site or Groundwater Plume	A contaminated site or groundwater plume with an "Active" or "Cleanup Complete-Institutional Controls" status identified by DEC Contaminated Sites Program. For assistance in locating mapped contaminated sites or listing of groundwater plumes, see http://dec.alaska.gov/Water/wnpspc/stormwater/edhsgp.html .
Department ^a	The Alaska Department of Environmental Conservation
Discharge ^a	When used without qualification, means the discharge of a pollutant
Effluent ^b	The segment of a wastewater stream that follows the final step in a treatment process and precedes discharge of the wastewater stream to the receiving environment
Estimated	A way to estimate the discharge volume. Approvable estimations include, but are not limited to, the number of persons per day at the facility, seepage volume, noncompliance event volume and weight, etc.
Flushing	The practice of discharging stored water from a pipeline or water storage tank to conduct maintenance activities.
Grab Sample	A single instantaneous sample collected at a particular place and time that represents the composition of wastewater only at that time and place
Hydrostatic Test Water	Water placed in tanks, utility lines, pipelines, etc. (new/unused or used) and raised to greater than atmospheric pressure, in order to check for leaks and/or the structural integrity of these facilities. Hydrostatic test water also includes water placed in tanks, pipelines, etc. to test for leaks without raising pressure to above atmospheric pressure. The flushing of tanks, utility lines, pipelines, etc. would also meet the definition of hydrostatic test water.
Maximum Daily Discharge Limitation ^a	Means the highest allowable "daily discharge"

a) See 18 AAC 83

b) See 18 AAC 70.990

c) See 40 CFR Part 136

d) See EPA Technical Support Document

Method Detection Limit (MDL) ^c	Means the minimum concentration of a substance (analyte) that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix containing the analyte
Minimum Level (ML) ^d	Means the concentration at which the entire analytical system must give a recognizable signal and an acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method-specified sample weights, volumes, and processing steps have been followed. This level is used as the compliance level if the effluent limit is below it.
Month	The time period beginning and ending on the first and last day of a calendar month.
Nephelometric Turbidity Unit (NTU)	An expression of the optical property that causes light to be scattered and absorbed rather than transmitted in a straight line through the water
Permittee	A company, organization, association, entity, or person who is issued a wastewater permit and is responsible for ensuring compliance, monitoring, and reporting as required by the permit
pH	Means a measure of the hydrogen ion concentration of water or wastewater; expressed as the negative log of the hydrogen ion concentration in mg/L. A pH of 7 is neutral. A pH less than 7 is acidic, and a pH greater than 7 is basic.
Potable Water Distribution Systems Releases	Sources of flows from drinking water storage, supply, and distribution systems including flows from pressure releases, planned system maintenance, and fire hydrant flushing all conducted as part of routine operations of the system.
Receiving Water body	Means lakes, bays, sounds, ponds, impounding reservoirs, springs, wells, rivers, streams, creeks, estuaries, marshes, inlets, straits, passages, canals, the Pacific Ocean, Gulf of Alaska, Bering Sea, and Arctic Ocean, in the territorial limits of the state, and all other bodies of surface water, natural or artificial, public or private, inland or coastal, fresh or salt, which are wholly or partially in or bordering the state or under the jurisdiction of the state. (See “Waters of the U.S.” at 18 AAC 83.990(77))
Settleable Solids ^b	Solid material of organic or mineral origin that is transported by and deposited from water, as measured by the volumetric Imhoff cone method and at the method detection limits specified in method 2540(F), <i>Standard Methods for the Examination of Water and Wastewater</i> , 18th edition (1992), adopted by reference in 18 AAC 70.020(c)(1)
Sheen ^b	Means an iridescent appearance on the water surface
Total Residual Chlorine	Means chlorine remaining in water or wastewater at the end of a specified contact period as combined or free chlorine
Waters of the United States or Waters of the U.S.	Has the meaning given in 18 AAC 83.990(77)
Week	The time period of Sunday through Saturday

a) See 18 AAC 83

b) See 18 AAC 70.990

c) See 40 CFR Part 136

d) See EPA Technical Support Document

APPENDIX D FORMS

Notice of Intent

Notice of Termination

Monthly Discharge Monitoring Report

- a) See 18 AAC 83
- b) See 18 AAC 70.990
- c) See 40 CFR Part 136
- d) See EPA Technical Support Document

Permit #: _____

Notice of Intent (NOI) for Hydrostatic or Aquifer Pump Testing Discharges to be authorized under an APDES Hydrostatic or Aquifer Pump Testing Discharges General Permit



Submission of this Notice of Intent (NOI) constitutes notice that the party identified in Section I of this form requests authorization to discharge pursuant to the APDES Hydrostatic or Aquifer Pump Testing Discharges GP. Submission of this NOI also constitutes notice that the party identified in Section I of this form meets the eligibility requirements of the Hydrostatic or Aquifer Pump Testing Discharges GP for the project identified in Section III of this form. Permit coverage is required prior to commencement of the hydrostatic or aquifer pump testing discharges activity until you are eligible to terminate coverage as detailed in the Hydrostatic or Aquifer Pump Testing Discharges GP. To obtain authorization, you must submit a complete and accurate NOI form. Refer to the instructions at the end of this form.

I. Applicant Information

Organization:					
Contact Person:					
Mailing Address:	Street (PO Box):				
	City:		State:		Zip:
	Phone:		Fax (optional):		
	Email:				

II. Billing Contact Information

Organization:					
Contact Person:					
Mailing Address:	Street (PO Box):				
☐ <i>Check if same as Applicant Information.</i>	City:		State:		Zip:
	Phone:		Fax (optional):		
	Email:				

III. Project/Site Information

Project/Site Name:					
Project Description:					
Estimated Project Start Date:			Estimated Project Completion Date:		
Project Location	Street:				
	City:		State:	Alaska	Zip:
	Borough or Similar Government Subdivision:				
	Latitude:		Determined By:	☐ GPS ☐ USGS topographic map	
	Longitude:			☐ Other:	
	If you used a USGS topographic map, what was the scale?				

IV. Discharge Information

Discharge Flow Rates:	Maximum anticipated discharge flow rate		gallons per day (GPD)
	Average anticipated discharge flow rate		gallons per day (GPD)
	Total anticipated discharge		gallons
	Discharge velocity at the end of pipe		feet per second (fps)
General Description of Hydrostatic or Aquifer Pump Testing Activities:			
Identify the names(s) of waterbodies to which you will discharge to:			
Is the discharge to land?			☐ Yes ☐ No
If you have aquifer pump testing discharges to Waters of the U.S.; have you submitted the required total metals analysis for the parameters listed in Table 5 with your NOI?			☐ Yes ☐ No
If "Yes" have you contacted the DEC-Contaminated Sites Group?			☐ Yes ☐ No

Permit #: _____

Do you have aquifer pump testing discharges either to land or water which are located within a 1,500 feet of an "Active DEC identified contaminated site or groundwater plume"?

**A contaminated site or groundwater plume with an "Active" or "Cleanup Complete-Institutional Controls" status identified by DEC Contaminated Sites Program. For assistance in locating mapped contaminated sites and listing of groundwater plumes see <http://dec.alaska.gov/Water/wnpspc/stormwater/edhsqp.html>.*

☐ Yes☐ No

If Yes, describe the BMPs to be implemented in your certified BMP plan to insure pumping does not affect the contaminated area.

Has all permit required additional documentation described in Part 2.2 of the permit for aquifer pump testing discharges located within a 1,500 feet of an active DEC mapped contaminated site or plume been submitted with the NOI for review by DEC?

☐ Yes☐ No☐ N/A

If the discharge is to a fish bearing stream has the Alaska Department of Fish and Game-Office of Habitat been contacted?

☐ Yes☐ No☐ N/A

If the hydrostatic testing or aquifer pump testing withdraws 30,000 gallons per day or greater from the ground or a water body has the Alaska Department of Natural Resources-Division of Mining, Land, and Water been contacted to determine if a Temporary Water Use Permit is required?

☐ Yes☐ No☐ N/A

V. BMP Plan required to describe how the wastewater discharge will be managed

Has a BMP Plan been developed in accordance to Part 2.2.7 of the Hydrostatic and Aquifer Pump Testing general permit?

☐ Yes☐ No

Has the certified BMP Plan been submitted to DEC with the NOI?

☐ Yes☐ No

VI. Certification Information

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Printed Name

Title

Organization

Signature

Date

Phone

Email

Application Preparer (Complete if NOI was prepared by someone other than the certifier)

Printed Name

Title

Organization

Phone

Email

VII. Documents Attachments

Documents attached with this application:

Instructions for Completing a Notice of Intent (NOI) Form for an Hydrostatic or Aquifer Pump Testing Discharges Discharge Under an APDES Hydrostatic Testing or Aquifer Pump Testing General Permit.

Who Must File an NOI Form:

The following situations will require NOI submittal; applicants which discharge eligible hydrostatic or aquifer pump testing discharges to waters of the U.S. and aquifer pump testing discharges to the land of 30,000 gallon per day or greater or pump testing located within a 1,500 feet of an active DEC mapped contaminated site or plume.

Completing the Form

Obtain and read a copy of the APDES Hydrostatic and Aquifer Pump Testing general permit. Type or print, in the appropriate areas only. "NA" can be entered in areas that are not applicable. If you have any questions about how or when to use this form, contact the DEC Storm Water Program at (907) 269-6285 or online at <http://dec.alaska.gov/water/wnpspc/stormwater>.

Section I. Applicant Information

The applicant that is conducting the hydrostatic or aquifer pump testing and has responsibility for on-site operations necessary to assure compliance to the permit shall complete and submit an NOI.

Section II. Billing Contact Information

Provide the name of the contact person, and the legal name of the firm, public organization, or any other entity that is responsible for accounts payable for this project. Also provide the billing contact's mailing address, telephone number, fax number (optional) and email address. Correspondence for billing purposes will be sent to this address. If the billing contact is that same as the applicant, check the box and continue to Section III Project/Site Information.

Section III. Project/Site Information

Enter the official or legal name and complete street address, including city, state, zip code, and borough or similar government subdivision of the project or site. If the project or site lacks a street address, indicate the general location of the site (e.g., Intersection of State Highways 1 and 2). Complete site information must be provided for permit coverage to be granted.

The applicant must also provide the latitude and longitude of the project area either in degrees, minutes, seconds; degrees, minutes, decimal; or decimal format. The latitude and longitude of your project area can be determined in several different ways, including through the use of global positioning system (GPS) receivers, U.S. Geological Survey (U.S.G.S.) topographic or quadrangle maps, and EPA's web-based siting tools, among others. Refer to <http://cfpub.epa.gov/npdes/stormwater/latlong.cfm> for further guidance on the use of these methodologies. For consistency, DEC requests that measurements be taken from the approximate center of the discharge point. Applicants must specify which method they used to determine latitude and longitude. If a U.S.G.S. topographic map is used, applicants are required to specify the scale of the map used. Enter the estimated start and completion dates using four digits for the year (i.e., 05/27/2009).

Section IV. Discharge Information

Enter the name(s) of receiving water bodies to which the hydrostatic or aquifer pump testing project will discharge. These should be the first bodies of water that the discharge will reach. (Note: If you discharge to more than one water body, please indicate all such waters in the space provided and attach a separate sheet if necessary.) For example, if the discharge leaves your site and travels through a roadside swale or a storm sewer and then enters a stream that flows to a river, the stream would be the receiving water body. Waters of the U.S. include lakes, streams, creeks, rivers, wetlands, impoundments, estuaries, bays, oceans, and other surface bodies of water within the confines of the U.S. and U.S. coastal waters. Waters of the U.S. do not include man-made structures created solely for the purpose of wastewater treatment. U.S.G.S. topographical maps may be used to make this determination. If the map does not provide a name, use a format such as "unnamed tributary to Cross Creek". If you discharge into a municipal separate storm sewer system (MS4), you must identify the water body into

which that portion of the storm sewer discharges. That information should be readily available from the operator of the MS4.

Indicate the anticipated discharge flow rate, average flow rate, and the total anticipated discharge with your estimated discharge velocity at the discharge point. Information shall also be provided to determine if the discharge is to a land disposal area and if the aquifer pump testing discharge volume will equal or exceed 30,000 gallons per day. Additional state agency contact may be necessary which should be noted in the NOI.

Section V. BMP Plan

In accordance to Part 2.2.7 of the permit all hydrostatic testing including flushing and aquifer pump testing discharges which require NOI submittal are required to submit a BMP plan to describe how the wastewater discharge will be managed. Questions were added to the NOI to specify that a BMP plan shall be developed, certified, and submitted with the NOI.

Section VI. Certification Information

The NOIs, must be signed as follows:

- (1) For a corporation, a responsible corporate officer shall sign the NOI, a responsible corporate officer means:
 - (A) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation; or
 - (B) the manager of one or more manufacturing, production, or operating facilities, if
 - (i) the manager is authorized to make management decisions that govern the operation of the regulated facility, including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental statutes and regulations;
 - (ii) the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and
 - (iii) authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
- (2) For a partnership or sole proprietorship, the general partner or the proprietor, respectively; or
- (3) For a municipality, state, or other public agency, either a principal executive officer or ranking elected official shall sign the application; in this subsection, a principal executive officer of an agency means
 - (A) The chief executive officer of the agency; or
 - (B) A senior executive officer having responsibility for the overall operations of a principal geographic unit or division of the agency.

Include the name, title, and email address of the person signing the form and the date of signing. An unsigned or undated NOI form will not be considered valid application for permit coverage. If the NOI was prepared by someone other than the certifier (for example, if the NOI was prepared by a consultant for the certifier's signature), include the name, organization, telephone number and email address of the NOI preparer.

Instructions for Completing a Notice of Intent (NOI) Form
for an Hydrostatic or Aquifer Pump Testing Discharges Discharge Under an
APDES Hydrostatic Testing or Aquifer Pump Testing General Permit.

Where to File NOI form:

DEC encourages you to complete the NOI form electronically via the Internet. DEC's Online Application System (OASys) can be found at <http://dec.alaska.gov/water/wnpspc/stormwater/APDESeNOI.html>.

Filing electronically is the fastest way to obtain permit coverage and help ensure that your NOI is complete. If you choose not to file electronically, you must send the NOI to the address listed below.

If you file by mail, please submit the original form with a signature in ink. DEC will not accept a photocopied signature for NOIs submitted by mail. Remember to retain a copy for your records.

NOIs sent by mail:

Alaska Dept. of Environmental Conservation
Wastewater Discharge Authorization Program
555 Cordova Street
Anchorage, AK 99501
Phone: (907) 269-6285

Notice of Termination (NOT) of Coverage for Hydrostatic or Aquifer Pump Testing Discharges authorized under an APDES Hydrostatic and Aquifer Pump Testing General Permit



Submission of this Notice of Termination (NOT) constitutes notice that the party identified in Section II of this form is no longer authorized to discharge hydrostatic or aquifer pump testing discharges under the APDES program for the site identified in Section III of this form. All necessary information must be included on the form. Coverage under the APDES Hydrostatic and Aquifer Pump Testing General Permit is terminated at midnight of the day the NOT is signed. The NOT must be submitted within 30 days upon completion of all hydrostatic or aquifer pump testing discharges. Refer to the instructions at the end of this form for information on submitting a NOT.

I. Permit Information

Permit Tracking Number:

Enter date when all hydrostatic or aquifer pump testing activities ceased.

Have all BMP measures temporarily installed or used to manage the discharge been removed?	Yes	No
---	-----	----

II. Applicant Information

Organization:

Contact Person:

Mailing Address:

Street (PO Box):

City:

State:

Zip:

Phone:

Fax(optional):

Email:

III. Project/Site Information

Project/Site Name:

Project Street/Location:

City:

State: Alaska

Zip:

Borough or similar government
subdivision:

IV. Certification Information

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Printed Name:

Title:

Organization:

Signature:

Date:

Email:

Instructions for Completing a Notice of Termination Form for a Hydrostatic and Aquifer Pump Testing General Permit

Who May File an NOT Form:

Permittees presently covered under the Alaska Pollutant Discharge Elimination System (APDES) General Permit for Hydrostatic or Aquifer Pump Testing Discharges authorized under the Hydrostatic and Aquifer Pump Testing GP may submit an NOT form when all hydrostatic or aquifer pump testing activities have ceased. Only those permittees who submitted an NOI to receive discharge authorization are required to submit an NOT.

Completion of the testing activities means all hydrostatic or groundwater pumping discharges related to aquifer pump testing have ceased and no discharges to the ground or a water body are occurring. The termination shall be filed within 30 days upon completion of all activity which produces an authorized discharge covered under the Hydrostatic and Aquifer Pump Testing GP. All BMP measures put in place to manage the discharge shall also be removed prior to submittal of the NOT.

Completing the Form

Type or print, in the appropriate areas only. "NA" can be entered in areas that are not applicable. If you have any questions about how or when to use this form, contact the ADEC Storm Water Program at (907) 269-6285 or online at <http://dec.alaska.gov/water/wnpspc/stormwater/APDESeNOI.html>.

Section I. Permit Number

Enter the existing APDES Hydrostatic and Aquifer Pump Testing General Permit Tracking Number assigned to the project by DEC. If you do not know the tracking number, you can find the tracking number assigned to your facility on ADEC's Water Permit Search: <http://dec.alaska.gov/Applications/Water/WaterPermitSearch/Search.aspx>.

Section II. Applicant Information

a. Provide the legal name of the person, firm, public organization, or any other entity conducting the discharge activities described in this application and is covered by the permit tracking number identified in Section I. The entity responsible for conducting either the hydrostatic or aquifer pump testing activities is the legal entity that controls the site operation, rather than the site manager.

b. Enter the applicant's complete mailing address, telephone number, email address, and fax number.

Section III. Project/Site Information

Enter the official or legal name and complete street address, including city, state, zip code, and borough or similar government subdivision of the project or site. If the project or site lacks a street address, indicate the general location of the site (e.g., Intersection of State Highways 1 and 2). Complete site information must be provided for termination of permit coverage to be valid.

Section IV. Certification Information

The NOTs, must be signed as follows:

(1) For a corporation, a responsible corporate officer shall sign the NOT, a responsible corporate officer means:

(A) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation; or

(B) the manager of one or more manufacturing, production, or operating facilities, if

(i) the manager is authorized to make management decisions that govern the operation of the regulated facility, including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental statutes and regulations;

(ii) the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and

(iii) authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

(2) For a partnership or sole proprietorship, the general partner or the proprietor, respectively; or

(3) for a municipality, state, or other public agency, either a principal executive officer or ranking elected official shall sign the application; in this subsection, a principal executive officer of an agency means

(A) the chief executive officer of the agency; or

(B) a senior executive officer having responsibility for the overall operations of a principal geographic unit or division of the agency.

Include the name, title, and email address of the person signing the form and the date of signing. An unsigned or undated NOT form will not be considered valid termination of permit coverage.

Where to File NOT form:

ADEC encourages you to complete the NOT form electronically via the Internet. ADEC's Online Application System (OASys) can be found at <http://dec.alaska.gov/water/wnpspc/stormwater/APDESeNOI.html>. Filing electronically is the fastest way to terminate permit coverage and help ensure that your NOT is complete. If you choose not to file electronically, you must send the NOT to the address listed below.

If you file by mail, please submit the original form with a signature in ink. ADEC will not accept a photocopied signature for NOTs submitted by mail. Remember to retain a copy for your records.

NOTs sent by mail:

Alaska Dept. of Environmental Conservation

Wastewater Discharge Authorization Program

555 Cordova Street

Anchorage, AK 99501

Phone: (907) 269-6285

NAME:
ADDRESS:

FACILITY
LOCATION
ATTN:

FROM

TO

Hydrostatic and Aquifer Pump Testing General Permit DMR					
AKG003000			001 A		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
MONTH DAY YEAR			MONTH DAY YEAR		

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQ. OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
Turbidity Discharge Parameter Code: 00070 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		NTU		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	(See Permit)	NTU	-	Before Discharge and Weekly
Turbidity Background Parameter Code: 00070 Mon Site No: 001 A Stage Code: = EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		NTU		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	*****	NTU	-	Before Discharge and Weekly
pH Parameter Code: 00400 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-		-		Std U.		GRAB
	PERMIT REQUIREMENT	na	na	na	6.5	na	8.5	Std U.	-	Before Discharge and Weekly
Settleable Solids Discharge Parameter Code: 00545 Mon Site No: 00A1 Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		mL/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	0.2	mL/L	-	Monthly
Settleable Solids Background Parameter Code: 00545 Mon Site No: 00A1 Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		mL/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	*****	mL/L	-	Monthly
Total Aqueous Hydrocarbon Parameter Code: 22456 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		µg/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	15	µg/L	-	Before Discharge
Total Aromatic Hydrocarbon Parameter Code: 30383 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		µg/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	10	µg/L	-	Before Discharge
Total Residual Chlorine (Hydrostatic only) Parameter Code: 50060 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		mg/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	0.10	mg/L	-	Before Discharge and Weekly
Total Dissolved Solids (Aquifer pump testing only) Parameter Code: 12488 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		mg/L		GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	500	mg/L	-	Before Discharge

NAME:
ADDRESS:

FACILITY
LOCATION
ATTN:

Hydrostatic and Aquifer Pump Testing General Permit DMR		
AKG003000		001 A
PERMIT NUMBER		DISCHARGE NUMBER
MONITORING PERIOD		
MONTH DAY YEAR	TO	MONTH DAY YEAR

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO.EX	FREQ. OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
Visible Sheen Parameter Code: 45613 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-	-	-	-	-		Y/N			GRAB
	PERMIT REQUIREMENT	na	na	na	na	na	No	Y/N	-	Daily	GRAB
Total Project Flow Parameter Code: 82220 Mon Site No: 001A Stage Code: 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	-		gal./d	-	-	-	gal/d			ESTMT'D
	PERMIT REQUIREMENT	na		Total gallons	na	na	na	na	-	Daily	ESTMT'D
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				SIGNATURE OF PRINCIPAL EXECUTIVE			TELEPHONE		DATE
TYPED OR PRINTED										OFFICER OR AUTHORIZED AGENT	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 MONITORING LOCATION "1" IS EFFLUENT
 ver June 2014